Consolidated Edison Company of New York, Inc. Indian Point Station Broadway & Bleakley Avenue Buchanan, NY 10511 Telephone (914) 737-8116

July 12, 1989

Re:

Indian Point Unit No. 2 Docket No. 50-247

Document Control Desk US Nuclear Regulatory Commission Mail Station P1-137 Washington, DC 20555

SUBJECT: Reactor Vessel Inservice Inspection

By letter dated October 16, 1984, the NRC forwarded a safety evaluation regarding the ultrasonic indication detected in the reactor vessel during the 1984 refueling outage. Section V, Page 18 of the safety evaluation stated that "...at the end of the next ten year period (ending June 30, 1994) Consolidated Edison should submit for staff evaluation a fracture mechanics analysis (of the reactor vessel indication) that is based on an updated state-of-knowledge of the effect of neutron irradiation on the fracture properties of the IP-2 vessel materials".

A fracture mechanics analysis was performed during 1984 as part of an overall evaluation of the vessel indication. That analysis was used as a basis for the 1984 NRC conclusion that the vessel was acceptable for continued service subject to accomplishing augmented inspections.

As a result of the augmented vessel examinations conducted in 1987, the NRC, by letter dated July 12, 1988, concluded that the indication meets the acceptance criteria of ASME Section XI and that augmented inspections may be discontinued. Since the indication meets the acceptance criteria of ASME Section XI, fracture mechanics analysis is not necessary nor required to "accept" the indication and paragraph IWB-3122.4 of ASME XI "Acceptance by Evaluation" is not applicable.

Therefore, it is Con Edison's conclusion that it is no longer necessary to submit an additional fracture mechanics analysis in 1994 as recommended in the 1984 NRC safety evaluation since the 1987 vessel examinations demonstrated that the indication was acceptable without the need for such an analysis.

Should you or your staff have any questions please contact Mr. Jude G. Del Percio, Manager, Regulatory Affairs.

Very truly yours,

8907260307 890712 PDR ADOCK 05000247 PDC

A 041

cc: Mr. William Russell
Regional Administrator - Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1498

Mr. Donald S. Brinkman, Project Manager Project Directorate I-1 Division of Reactor Projects I/II US Nuclear Regulatory Commission Mail Stop 14B-2 Washington, DC 20555

Senior Resident Inspector US Nuclear Regulatory Commission PO Box 38 Buchanan, NY 10511