1 4 1					LIC	ENSE	E EVEI	NT REP	ORT (LER)		U.S. NUC	LEAR RLI 'ROVED (PIRES: 87	GULATO DMB NO. 31/66	17 EOnmei 3180-0164	MICH
ACILITY		Trad			······································						DOCKET		11		PLOY	711
TITLE 141		1110		Point Unit	<u>No. 2</u>					<u> </u>	0 5	0 0	0 2 1	4 7	1 OF	Q 3
	Cer	ntral	Cont	trol Room	Characa	1 12 4	1+	T			• • •					
LVL	-	161	0011	LEA HUMBER IS			ILEIS	- LOW	Meth	y1-lodic	le Ads	orpti	on E	ffici	lency	
mùnîn	WATA DAY TEAN YEAR SEQUENTIAL			NVBON	MONTH DAY TAAN		YAAN	OTHER PA			ACILITIES INVOLVED ISI					
									IDEMISI							
1								· -						0 0		<u>_</u>
06	2 3	87	8 7	0 0 8	00	07	2 3	8 7			· · · · :	•	0.55.		•	
Ori	ENITAN		THIS AL	OAT IS SUBMITTED	PURBUANT T	-		ATE OF 10	CFA \$. 10	heut ens er men	el los lou		0 101	0 0	-	
PONLI LIVE 1101		0_0	20. 20. 20. 20. 20. 20.	409 (+) (1) (1) 409 (+) (1) (11) 409 (+) (1) (11) 409 (+) (1) (1+) 409 (+) (1) (1+)		00.36 in 00.36 in 00.3 in 00.7 in 00.7 in 10.7 in	CONTACT	fOR This		00.73is1(2)(14) 00.73is1(2)(14) 00.73is1(2)(14) 00.73is1(2)(14) 00.73is1(2)(14) 00.73is1(2)(14)))(A))(D)		73.1 73.1 73.1 011 501	I E (b) I E (c) Ini E Al (Spon I and Ini I al	iny in Abu Toas, MAC	Pact Furth
	В	rani	slav	Raskovic	Fraina				•		-	TELEPHONE NUMBER				
			514V	Rasković,	rugine	er			•			A CODE	. .			
				COMPLETE	ONE LINE FOR	ACH C	OMPONIN	T PAILURE	DAACBIAA	0 IN THUS	9	14	5 2	6 [-	1513	<u> 6 </u>
CAUSE	SYSTEM	COMP	ÚNENT	MANUFAC TUMEN	NEPONTABLE TO NPADE			CAUSE	SVETLM	COMPONENT		NUFAC- UREN	TO N	TABLE		
x	VII	F _l L		M 3 3 5	N					1 1 1						
X	VLI	FL		M 3 3 5	N				1							
				BUPPLEME	NTAL ALPOAT	EXPECT	10 (14		······	•	╾┤─┸			MUNTA	DAY	TYEAR
YE	\$ 111 ym, c	umpiere £	RECTED	SUBMISSION DATE	7	-						EXPECTL SUBMISSI DATE (SI	.D On			

On June 3, 1987, as part of a routine surveillance, charcoal in both charcoal filters (FLT) in the Central Control Room (CCR) Filtration System was replaced, and a representative sample of used charcoal from each of two filters was sent to Callery Chemical Corporation, Evans City, PA, for analysis. On June 23, 1987, the laboratory analysis results were received, revealing that the "as found" adsorption efficiency for methyl-iodide was 93.66% for filter No. 1 and 79.07% for filter No. 2. Since the charcoal in both charcoal filters had been replaced on June 3, 1987, there was no need for further corrective action. The health and safety of the public were not affected.

IEZ

8707310105 87072

ADOCK

PDR

050002

1

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

NUCLEAN NEULIAIONS COMMISSION

EXPIRES 6'31 05

CILITY NAME (1)	DOCALT NUMBER 131	······································	PAGE 13		
		LEA NUMBER 161			
		VLAR SEGUENTA. RESIGN			
Indian Point Unit No. 2	0 5 0 0 0 0 2 4 7	817 - 010 1 8 - 010	0 2 0 5 0 3		
	╋╼╼┻╍╼╄ <u>╼╼</u> ┠╼╼╂╍╍╂╼┉ <u>┠</u> ╼╍ <u>┨</u>				

Plant and System Identification:

Westinghouse 4-loop pressurized water reactor.

Identification of Occurrence:

Inability of CCR charcoal filters' charcoal to meet design adsorption efficiency.

Event Date: June 23, 1987

Past Similar Occurrences: LER 83-029, LER 83-021

Description of Occurrence:

On June 3, 1987, charcoal in both charcoal filters in the Central Control Room Filtration System was replaced and a representative sample of used charcoal from each of two filters was sent to Callery Chemical Corporation for analysis. On June 23, 1987 the laboratory analysis results were received, revealing that the "as found" adsorption efficiency for methyl-iodide was 93.66% for filter No. 1 and 79.07% for filter No. 2.

Analysis of Occurrence:

An original acceptance criterion of 90% for the adsorption efficiency of in-service charcoal for methyl-iodide, was established in the original FSAR. The original charcoal adsorber design specified a 1" bed. In 1982, the acceptance criterion was revised by Technical Specification amendment (Section 4.5.E) to conform with Regulatory Guide 1.52. Since post-TMI analyses allowed an assumption of 85% efficiency in meeting the personnel dose limits, application of Regulatory Guide 1.52, Rev. 2, was interpreted to require demonstration, in the laboratory, of a 97% minimum adsorption efficiency.

The Regulatory Guide 1.52 criterion is based upon at least a 2" charcoal bed (ANSI 509-1976), whereas the IP-2 CCR charcoal bed is 1". Based on the differences between the IP-2 design and the standard test configuration, the margin previously available no longer existed.

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO 3150-0104

	· · · · · · · · · · · · · · · · · · ·
ACILITY NAME IN	LER NUMBER (6) PAGE (3)
	VIAR SEQUENTA. N. SICA
Indian Point Unit No. 2 0 5 0 0 0 2 4	7 817 - 010 8 - 010 0 3 of 013

Self-contained breathing apparatus and protective clothing provided to the operators as compensatory measures under the original licensing of the plant, as well as potassium-iodide (KI) pills continue to be stored in the Central Control Room. Procedures in the CCR address their use by the Central Control Room personnel when appropriate.

Cause of Occurrence:

The adsorption efficiency of the charcoal was lower than anticipated. Also, the current charcoal acceptance criteria is more stringent than the original design basis for the charcoal filter.

Corrective Action:

Both charcoal filters were replaced with fresh charcoal on June 3, 1987. A study is being initiated to identify and address options for meeting the current acceptance criterion. We expect to complete this study in approximately nine months.

Murray Seiman Vice President

)

Consolidated Edison Company of New York, Inc. Indian Point Station Broadway & Bleakley Avenue Buchanan, NY 10511 Telephone (914) 737-8116

July 23, 1987

Re: Indian Point Unit No. 2 Docket No. 50-247

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555

Subject: LER 87-008-00

Dear Sirs:

The attached Licensee Event Report LER 87-008-00 is hereby submitted in accordance with the requirements of 10 CFR Part 50.73.

Very truly yours,

Many Selman

Attachment

cc: Mr. William Russell
Regional Administrator - Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Senior Resident Inspector U.S. Nuclear Regulatory Commission P.O. Box 38 Buchanan, NY 10511

1E22