

Stephen B. Bram
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 737-8116

May 24, 1988

Re: Indian Point Unit No. 2
Docket No. 50-247

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: 30-day Report, Inoperable Fire Barriers

In accordance with Technical Specification 3.13.C.2.(a)(b), the following 30-day report regarding inoperable fire barriers is submitted.

During a test on April 19, 1988, several penetration fire barriers between the Primary Auxiliary Building (PAB) and the electrical tunnel were found to be inoperable.

During another test on April 27, 1988, several penetration fire barriers between the Central Control Room (CCR) floor and the cable spreading room were found to be inoperable.

During another test on May 5, 1988 several fire barriers between the CCR and the cable spreading room, the switchgear room and the cable spreading room were found to be inoperable.

During the period of inoperability, compensatory action, as prescribed by the Technical Specification, in the form of an hourly fire watch is being performed. All fire barrier repairs are presently scheduled but will not be completed within the time allotted by the applicable Technical Specification. The fire barrier repairs will be completed by July 31, 1988.

This report fulfills the reporting requirements for all inoperable penetration fire barriers.

If you or your staff have any questions, please contact us.

Very truly yours,



8806140241 880524
PDR ADOCK 05000247
S DCD

JE22
11

cc: Mr. William Russell
Regional Administrator - Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1498

Ms. Marylee M. Slosson, Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14B-2
Washington, DC 20555

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, NY 10511