

Stephen B. Brar
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 737-8116

January 18, 1989

Re: Indian Point Unit No. 2
Docket No. 50-247


Mr. Paul Swetland
Section Chief
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1498

SUBJECT: Notification of Inoperable Fire Pumps

This is in confirmation of a verbal communication between IP-2 and Region I on January 18, 1989 regarding the following:

"In order to perform a post maintenance test of fire booster pump No. 11, it was necessary to render the three pumps inoperable for the duration of the test. Technical Specification 3.13.A.3.b requires NRC notification for events where all three fire pumps are inoperable simultaneously."

Very truly yours,



cc: Document Control Desk
U.S. Nuclear Regulatory Commission
Mail Station Pl-137
Washington, DC 20555

Mr. William Russell
Regional Administrator - Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1498

Ms. Marylee M. Slosson, Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14B-2
Washington, DC 20555

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, NY 10511

8901270269 890118
PDR ADDCK 05000247
S FDC

IE22
1/0