

January 13, 1988

Docket No. 50-247

MEMORANDUM FOR: T. Murley* J. Partlow R. Capra
J. Snizek* F. Congel W. Butler
F. Miraglia* J. Roe R. Wessman
ADT* S. Black* J. Stolz
S. Varga* B. Boger* E. Adensam
D. Crutchfield* G. Lainas* H. Berkow
L. Shao* AD RIV/SP PD II-3
C. Rossi* G. Holahan H. B. Clayton
J. Richardson W. Lanning W. Troskoski
Operations Ctr.** R. Cooper A. Thadani

THRU: Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects, I/II

DISTRIBUTION
Docket File
NRC PDR
PDI-1 RDg.
MSlosson

FROM: Marylee Slosson, Project Manager
Project Directorate I-1
Division of Reactor Projects, I/II

SUBJECT: INDIAN POINT 2 STEAM GENERATOR DRY OUT

Following the Steam Generator Dry Out Event and as documented in a Confirmatory Action Letter issued on January 7, 1988, Consolidated Edison agreed not to take the plant critical until authorized by the Regional Administrator. The Augmented Inspection Team (AIT) dispatched to Indian Point 2 on January 7 to investigate the event held an exit meeting on January 12. Based upon the results of the inspection, the licensee was informed that several action items must be completed prior to the Regional Administrator authorizing restart. First, Consolidated Edison must submit a letter to the NRC discussing short-and long-term corrective actions. Second, the utility must meet with the NRC staff to discuss the action plan. The utility must demonstrate the rationale used in determining its corrective actions. It must demonstrate the effectiveness of short-term actions and justify why long-term actions should not be completed prior to restart.

Marylee M. Slosson, Project Manager
Project Directorate I-1
Division of Reactor Projects, I/II

* THESE COPIES MUST BE HANDCARRIED

PDI-*MS*
MSlosson
1/13/88

8801190340 880113
PDR ADDCK 05000247
S PDR