March 18, 1988

Docket No. 50-247

DISTRIBUTION Docket File NRCPDR HBClayton Local PDR

LICENSEE: Consolidated Edison Company of New York, Inc. MSlosson ACRS(10) RCapra PSwetland FACILITY: Indian Point Nuclear Generating Unit No. 2 OGC EJordan PDI-1 Rdg. SUBJECT: MEETING SUMMARY CONCERNING FEBRUARY 9, 1988 MEETING TO DISCUSS CONSOLIDATED EDISON'S INTENTION TO SUBMIT AN AMENDMENT APPLICATION FOR POWER UPRATE

A meeting was held on February 9, 1988 to discuss Consolidated Edison's intention to submit an amendment application to increase the Indian Point Nuclear Generating Unit No. 2 power rating. A list of meeting attendees, the meeting agenda and the handouts are attached.

The purpose of the meeting was to discuss the review process involved to support the amendment application which Consolidated Edison is considering submitting in the summer of 1988. The review process includes systems reviews, equipment reviews, accident analyses and balance of plant reviews.

The utility indicated that if it submits the amendment application, it is requesting an approximate seven month turn-around.

Marylee M. Slosson, Project Manager Project Directorate I-1 Division of Reactor Projects, I/II

Enclosures: As stated

cc: See next page

PDI-1 🕅 MS1osson **B/ K188**



Mr. Stephen B. Bram Consolidated Edison Company of New York, Inc.

cc: Mayor, Village of Buchanan 236 Tate Avenue Buchanan, New York 10511

Ms. Donna Ross New York State Energy Office 2 Empire State Plaza 16th Floor Albany, New York 12223

Mr. Jude Del Percio Manager of Regulatory Affairs Consolidated Edison Company of New York, Inc. Broadway and Bleakley Avenue Buchanan, New York 10511

Senior Resident Inspector U.S. Nuclear Regulatory Commission Post Office Box 38 Buchanan, New York 10511

Mr. Brent L. Brandenburg
Assistant General Counsel
Consolidated Edison Company
of New York, Inc.
4 Irving Place - 1822
New York, New York 10003

Indian Point Nuclear Generating Station 1/2

Director, Technical Development Programs State of New York Energy Office Agency Building 2 Empire State Plaza Albany, New York 12223

Mr. Peter Kokolakis, Director Nuclear Licensing Power Authority of the State of New York 123 Main Street White Plains, New York 10601

Mr. Walter Stein
Secretary - NFSC
Consolidated Edison Company of New York, Inc.
4 Irving Place - 1822
New York, New York 10003

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

LIST OF ATTENDEES MEETING HELD FEBRUARY 9, 1988

Name

Marylee M. Slosson M. J. Campagnone Paul Malick R. H. McFetridge Roy Kim Organization NRC/NRR NUS Corp. ConEd Westinghouse Westinghouse

NRC/IP-2 STRETCH RATING MEETING AGENDA

- 1. Brief overview of previous NRC approved stretch ratings
- 2. Timing and Chronology of IP-2 Uprating
 - NRC submittal date -- 8/88
 - Requested NRC approval date -- 3/89

3. Design Parameter Review

- Systems Impact
- Equipment Impact
 - Accident Analysis
 - BOP

Licensing Process

Upratings

Bob McFetridge

710A DW10763.036

UPRATINGS PROVIDE INCREMENTAL ELECTRIC GENERATION IN A COST EFFECTIVE MANNER

- 5% to 10% increases are feasible
- Primarily analytical effort
- Relatively low capital investment
- Increased power on-line in less than three years

710A DW10753 039



Westinghouse Has Provided Upratings Equal to a 2-Loop Plant

13 Units Uprated for 1855 MWt or 620 MWe'

1180 0023233.015

13 WESTINGHOUSE PLANTS HAVE IMPLEMENTED UPRATINGS (2.2% to 26.3%)

	Upr	ate	
Plant	From (MWt)	To (MWt)	When?
Yankee Rowe	485	600	After commercial operation
San Onofre 1	1210	1351	During design
Haddam Neck	1425	1800	After commercial operation
Point Beach 1	1395	1518	During design
R.E. Ginna	1320	1520	After commercial operation
Turkey Point 3 & 4	2100	2200	During design
H.B. Robinson 2	2200	2300	After commercial operation
D.C. Cook 2	3250	3403	During design/licensing
Sena	905	1040	After commercial operation
Salem 1	3350	3423	After commercial operation
North Anna 1&2 710 D010753.041	2785	2905	After commercial operation



APPROX. MWe INCREASE

UPRATING EVALUATION AND IMPLEMENTATION CONTRACTS SINCE 1980

	ENGINEEF	RING	EVALU	JATIONS
--	----------	------	-------	---------

(1980)	TURKEY POINT 3 & 4	2
(1980)	NORTH ANNA 1 & 2	2
(1982)	NORTH ANNA 1 & 2	2
(1983)	SALEM 1	
(1984)	RINGHALS 2	1
(1984)	SURRY 1 & 2	
(1085)	CALLAWAY 1	-

2208	MWt/785	psia	MWt/829	psia	94
2785	MWt/850	psia 2787	MWt/900	psia	5
2787	MWt/900	psia 2910	MWt/850	psia	32
3350	MWt/805	psia 🛶 3423	MWt/805	psia	24
2440	MWt/870	psia+ 2660	MWt/850	psia	69
2441	MWt/785	psia → 2554	MWt/785	psia	36
3425	MWt/1000) psia-3579	MWt/950	psia	48

IMPLEMENTATION PROGRAMS

(1981) NORTH ANNA 1 & 2	2785 MWt/850 psia — 2787 MWt/900 psia	5
(1983) NORTH ANNA 1 & 2	2787 MWt/900 psia> 2910 MWt/850 psia	32
(1984) SALEM 1	3350 MWt/805 psia> 3423 MWt/805 psia	24
(1986) CALLAWAY 1	3425 MWt/1000 psia → 3579 MWt/950 psia	48
(1987) SURRY 1 & 2	2441 MWt/785 psia -+2554 MWt/785 psia	36

GENERIC UPRATING LICENSING DOCUMENT



Purpose

- Have established NRC ground rules for uprating
 - Provide uprating methodology
 - Power related aspects will be reviewed
 - Plant's current licensing criteria, codes and standards apply
 - Analysis will utilize current analytical techniques

Benefits

- Utility's exposure on current operating license limited
- Provides positive licensing environment for uprating

Status

- Submitted to NRC February, 1983, (WCAP-10263)
- NRC reviewed without specific docket
- First presentation to staff on October 4, 1983
- Numerous subsequent presentations
- NRC has licensed uprating based on approach

833 D013860.009

WHAT IS THE TYPICAL UPRATING PROCESS ?

• DEVELOP TARGET PLANT CONFIGURATION

- ESTABLISH NEEDS
- CUSORY ASSESSMENT OF AVAILABLE MARGINS & UTILIZATION
- SELECT PRELIMINARY PARAMETERS/CONFIGURATION
- PERFORM LIMITING ANALYSES/EVALUATIONS
- ACCIDENTS
- SYSTEMS
- COMPONENTS
- BOP INTERFACES
- PERFORM NON LIMITING ANALYSES/EVALUATIONS
- ACCIDENTS
- SYSTEMS
- COMPONENTS
- BOP INTERFACES
- OBTAIN REGULATORY APPROVAL

• OPERATE AT UPRATED CONDITIONS





FIRST ORDER PERFORMANCE SENSITIVITIES SUPPORT INITIAL "OPERATING WINDOW" DEVELOPMENT

PERFORMANCE

- 1°F Tavg
- 4% S/G plugging
- 5% S/G plugging
- 10 psi steam pressure

=7.5 psi steam

- =1% primary flow
- =1.5°F Tavg
 - =1% steam volume change

DNB

1°F	Tin		=1%	DNB
1%	primary	flow	=1%	DNB
1%	power		=2%	DNB

LOCA

• 1% S/G plugging

=0.01 reduction in FQ limit

PLUGGING

• 1 S/G tube plug

=Approx. 20 S/G tube sleeves

INDIAN POINT UNIT 2 3083.4 MWŁ STRETCH RATING BOUNDING PARAMETERS FOR INPUT TO REPLACEMENT STEAM GENERATOR LOCA ANALYSIS

ORIGINAL U		ATED
	LOW TEMP.	HIGH TEMP.
EXISTING	EXISTING 44	REPLACEMENT 44F
2758	3083.4	3083.4
89,700	80,700	80,700
776	578+	768+
596.0	582.2*	611.7+
569.5	549.0*	579.7*
543.0	515.8+	547.7*
0.0	25.0	25.0
	RIGINAL EXISTING 2758 89,700 776 596.0 569.5 543.0 0.0	RIGINAL UPR LOW TEMP. EXISTING EXISTING 44 2758 3083.4 89,700 80,700 776 578* 596.0 582.2* 569.5 549.0* 543.0 515.8* 0.0 25.0

***NOTE:** The design parameters in the table are based on the minimum T-cold and maximum T-hot extremes which bound a range of conditions to be used for analysis purposes. These parameters do not reflect anticipated actual operating conditions.

UPRATING ENCOMPASSES ALL ASPECTS OF THE NSSS



633-DW13660.001

UPRATING - NSSS SYSTEMS IMPACT

• Establish final plant parameters

833 DW 13860 00

- Verify adequacy of steam dumps & S/G valving
- Verify adequacy of pressurizer valving
- Verify adequacy of CVCS & RHR systems
- Provide NSSS heat loads on component cooling water system

UPRATING - NSSS SYSTEMS IMPACT

- Revise RCS loop analysis
- Gamma heating/neutron fluence of reactor vessel/ internals
- Normal radiation sources & accident releases
- Establish RCS control & protection systems setpoints
- Evaluate transient performance
- Prepare technical specifications

UPRATING - NSSS EQUIPMENT IMPACT

Verify structural integrity of components at uprated conditions:

- Steam Generators
- Reactor Vessel/Internals
- Reactor Coolant Pumps
- Reactor Coolant Loop Piping
- Pressurizer
- Control Rod Drive Mechanism
- CVCS (Heat Exchangers, etc.)
- RHR (Heat Exchangers, Pumps, etc.)
- SIS (Pumps, Tanks, etc.)
- Other NSSS Auxiliary Systems Components

833 DW13860 004

UPRATING - NSSS ACCIDENT ANALYSES

- Perform all required non-LOCA analyses for FSAR chapter 15
- Perform spectra of large and small break LOCA analyses
- Perform S/G tube rupture analysis
- Perform LOCA & steamline break mass/energy release analyses

833 0013860 005

UPRATING ALSO CONSIDERS NSSS/BOP INTERFACES



Secondary Systems

- Main steam and steam dumps
- Condensate and feedwater
- Circulating water
- Condenser
- Moisture separator/reheater and feedwater heaters
- Heater drains

Plant Cooling Water Systems

- Intake cooling water
- Turbine plant cooling water
- Component cooling water

Auxiliary Feedwater System

Ventilation Systems

- Containment ventilation and cooling
- Plant ventilation

833 DW13860 008

UPRATING ALSO CONSIDERS NSSS/BOP INTERFACES

Electrical System

- Motors
- Switchgear
- Transformers
- I&C
- **Containment Integrity**
- LOCA
- Steamline Break
- **Turbine Generator**
- Steam Turbine
- Electrical Generator

833 DW3860 007

SYNERGY IS ACHIEVED			•				
B	Y	COMBINING PROGRAMS	THOT REDUC- TION	TUBE PLUG- GING	UPRAT ING	FUEL CHANGE	PLEX
	1.	PRIMARY/SECONDARY PLANT PARAMETERS	***	**	***	*	
	2.	LOGA ANALYSES	**	***	***	**	
	3.	NON-LOCA ACCIDENT ANALYSES	*	*	***	**	
	4.	MASS/ENERGY RELEASES	**	*	*		
	5.	LOCA HYDRAULIC FORCING FUNCTIONS	**	*	*	**	
	6.	TECHNICAL SPECIFICATIONS	*	*	**	*	
	7.	COMPONENT DESIGN TRANSIENTS	***	*	**	*	***
	8.	CONTROL/PROTECTION SYS. SETPOINTS	**	*	*	*	
	9.	FUEL	*	**	***	**	
	10.	STEAM GENERATOR	***	**	**	*	***
	11.	REACTOR VESSEL	**	*	**	*	***
	12.	REACTOR INTERNALS	*	*	**	**	**
	13.	CRDM	*	*	1 🖈 -	*	**
	14.	PRESSURIZER AND VALVES	***	*	**		***
	15.	REACTOR COOLANT PUMP	*	*	*	*	**
	16.	REACTOR COOLANT PIPING	**	*	*	*	**
	17.	PIPING AND EQUIPMENT SUPPORTS	***	*	*	*	**
	18.	AUXILIARY EQUIPMENT	*	*	*	*	**
	19.	INSTRUMENTATION	**	*	*	*	***
	20.	S/G MOISTURE CARRYOVER	**	**	***		
	21.	STEAM TURBINE	**	**	**		***
	22.	ELECTRICAL GENERATOR			**		***
	23.	FEEDWATER SYSTEM	*	*	**		**
	24.	STEAM SYSTEMS AND VALVING	**	*	**		**
	25.	CONDENSATE SYSTEM	*	*	**		**
	26.	BOP ELECTRICAL SYSTEMS			**		***
	27.	DOSE ANALYSES			**		
	28.	ENVIRONMENTAL IMPACT STATEMENT			*		*
	29	ENVIRONMENTAL QUALIFICATION	*	*	*		***

★ MINOR IMPACT ★★ MODERATE IMPACT

*** MAJOR IMPACT

Utilities Are Actively Pursuing Upratings



- 13 Westinghouse plants have implemented upratings (2.2% to 26.3%)
- Westinghouse took the lead to establish uprating ground rules (WCAP-10263)
- The NRC is proactive on uprating
- North Anna 1 & 2 and Salem 1 achieved upratings during 1986
- Callaway 3579 Mwt Approval expected in 1988
- Adds 30 to 60 MWe of Generation
 - Low Capital
 - 2 to 3 Years

11180 GG23233.018