

Stephen B. Bram  
Vice President

Consolidated Edison Company of New York, Inc.  
Indian Point Station  
Broadway & Bleakley Avenue  
Buchanan, NY 10511  
Telephone (914) 737-8116

November 19, 1990

Re: Indian Point Units No. 1 and 2  
Docket Nos. 50-03 and 50-247

Document Control Desk  
US Nuclear Regulatory Commission  
Mail Station P1-137  
Washington, DC 20555

SUBJECT: Response to Inspection Report No. 50-247/90-24

As indicated in the subject report, Con Edison agreed to provide a schedule for identifying the contents of all tanks located in Indian Point Unit No. 1 which are no longer in use, and which contain spent resins or radioactively contaminated waste water.

This effort will require a complete survey of tanks within the facility, obtaining representative samples of waste materials and performing chemical and radiological analyses of those samples. The nine tanks specifically mentioned in the inspection report will be included in this effort.

Since it is anticipated that many of the tanks involved will be associated with inactive systems, we intend to carefully plan the sampling process to assure that valid samples are obtained while minimizing personnel exposure. To allow such careful planning and consistent with the need to prepare and implement plans for the upcoming Indian Point Unit 2 refueling outage, we anticipate completion of this effort by March 31, 1991. We will inform you in a timely manner, should any changes to this schedule or workscope be required.

Should you or your staff have any questions regarding this matter, please contact Mr. Charles W. Jackson, Manager, Nuclear Safety and Licensing.

Very truly yours,



cc: Mr. Thomas T. Martin  
Regional Administrator - Region I  
US Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Francis J. Williams Jr., Project Manager  
Project Directorate I-1  
Division of Reactor Projects I/II  
US Nuclear Regulatory Commission  
Mail Stop 14B-2  
Washington, DC 20555

Senior Resident Inspector  
US Nuclear Regulatory Commission  
PO Box 38  
Buchanan, NY 10511

9011290155 901119  
PDR ADOCK 05000247  
PDC

TEOG  
110