

Stephen E. Quinn
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 734-5340

August 29, 1995

Re: Indian Point Unit No. 2
Docket No. 50-247

Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

SUBJECT: Proposed Amendment to Technical Specifications
Regarding Steam Generator Tube Slewing Commitments

Consolidated Edison Company of New York, Inc. (Con Edison) transmits herewith one (1) signed original and two (2) copies of "Application of Amendment to Operating License", sworn to on August 29, 1995. This application proposes an amendment to the Indian Point Unit No. 2 Technical Specifications that would incorporate commitments made by Con Edison to the NRC by Enclosure 1 to the letter dated April 5, 1995 concerning the installation of laser welded steam generator tube sleeves. This letter was Con Edison's response to an NRC request for additional information (RAI) concerning tube slewing. Based on the commitments made in this letter as well as previously transmitted information, Amendment 183 to the Indian Point Unit No. 2 Technical Specifications was issued to permit the use of slewing as a method of tube repair.

Con Edison's response to RAI Item 3 resulted in a commitment to perform additional testing to establish the design life of sleeves and to confirm that leakage detection requirements will be met. If the results of this testing are not accepted by the NRC by the end of the second fuel cycle in which sleeves are installed, the tubes containing the sleeves in question shall be removed from service. As this commitment is a basis of a plant Technical Specification, Con Edison submits that a specific license amendment is not required for this commitment.

Technical Specification sections 3.1.F and 4.13 are transmitted in entirety due to an update in format. The changes to these sections are indicated with revision bars in the margin.

650002

9509050118 950829
PDR ADDCK 05000247
P PDR

ADD 1/1

ATTACHMENT A
PROPOSED TECHNICAL SPECIFICATIONS

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.
INDIAN POINT UNIT NO. 2
DOCKET NO. 50-247
AUGUST, 1995