

Stephen E. Quinn
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 734-5340

September 13, 1996

Re: Indian Point Unit No. 2
Docket No. 50-247


Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

SUBJECT: Revised Table 2 of Letter Request for Plant Specific Approval of
Best Estimate Large Break LOCA Analysis and Proposed
Changes to the Technical Specifications to Utilize For Indian
Point Unit No. 2.

Con Edison submitted the subject material to NRC by letter dated August 14, 1996. The purpose of this letter is to submit a revised Table 2 (Attachment to the aforementioned letter) which corrects copying errors and adds the following reference: letter, N. J. Liparulo (Westinghouse) to F. R. Orr (USNRC), "Re-Analysis Work Plans using Final Best Estimate Methodology", NSD-NRC-96-4746, June 13, 1996. The changes to Table 2 do not affect any other part of the submittal and do not change the conclusion of the Safety Assessment.

Should you have any questions regarding this matter, please contact Mr. Charles W. Jackson, Manager, Nuclear Safety and Licensing.

Very truly yours,



cc: Mr. Hubert J. Miller
Regional Administrator - Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Jefferey F. Harold, Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
US Nuclear Regulatory Commission
Mail Stop 14B-2
Washington, DC 20555

Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

230083

9609230268 960913
PDR ADOCK 05000247
P PDR

1/1
A001

Table 2 (Revision 1)

BEST ESTIMATE LARGE BREAK LOCA RESULTS

	Value	Criteria
50th Percentile PCT (°F)*	<1700	Not Applicable
95th Percentile PCT (°F)*	<2150	2200
Maximum Cladding Oxidation (%)	<17	17
Maximum Hydrogen Generation (%)	<1	1
Coolable Geometry	Core Remains Coolable	Core Remains Coolable
Long Term Cooling	Core Remains Cool in Long Term	Core Remains Cool In Long Term

* Calculated as described in the following reference: Letter, N. J. Liparalo (Westinghouse) to F. R. Orr (USNRC) "Re-Analysis Work Plans Using Final Best Estimate Methodology", NSD-NRC-96-4746, June 13, 1996.