

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	N	Y	I	P	S	B	2	0	0	-	0	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4	5
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34
LICENSEE CODE						LICENSE NUMBER						LICENSE TYPE						CAT 58									

01	L	6	0	5	0	0	0	2	8	6	7	0	6	2	9	8	1	0	8	0	7	2	8	8	0	9
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33
REPORT SOURCE		DOCKET NUMBER						EVENT DATE						REPORT DATE												

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 WHILE OPERATING AT 100 PERCENT POWER, UPON COMPLETION OF THE DIESEL
 03 GENERATOR MECHANICAL OVERSPEED TRIP TEST 3PT-Q7, THE OPERATOR WAS UNABLE
 04 TO RESET THE TRIP LEVER ON 32 DIESEL GENERATOR. THE DIESEL GENERATOR WAS
 05 THEN DECLARED INOPERABLE AT 1330 HOURS ON JUNE 29, 1980. THE REMAINING
 06 GENERATORS WERE TESTED AND VERIFIED OPERABLE IN ACCORDANCE WITH
 07 TECHNICAL SPECIFICATION 3.7.B.1. PLANT PERFORMANCE WAS NOT AFFECTED BY
 08 THIS INCIDENT. NO SIMILAR EVENTS HAVE BEEN REPORTED TO DATE.

09	E	E	11	E	12	B	13	C	K	T	B	R	K	14	E	15	Z	16							
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25							
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE											
17	3	0	21	22	23	0	1	0	24	25	26	27	0	3	28	29	L	30	31	0	32				
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.															
33	3	18	34	Z	19	35	Z	20	36	0	0	0	0	22	N	23	N	24	N	25	A	1	5	2	26
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER									

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THE ALCO MODEL 2361242 TRIP LEVER COULD NOT BE RESET DUE TO AN UNSECURED
 11 MODEL 24610913 TRIP LATCH SPRING WHICH HAD LOST ITS ATTACHING SCREW. THE
 12 SPRING WAS REATTACHED TO THE RETAINING WALL AND SECURED WITH A NEW SCREW
 13 AND NUT. IN ADDITION, THE NUT WAS FURTHER RETAINED WITH "LOCKTITE". THE
 14 GENERATOR WAS PLACED IN SERVICE AT 1850 HOURS ON JUNE 29, 1980.

15	E	28	1	0	0	29	NA	30	B	31	OPERATOR OBSERVATION	32		
7	8	9	10	11	12	13	14	15	16	17	18	19		
FACILITY STATUS		% POWER						OTHER STATUS		METHOD OF DISCOVERY			DISCOVERY DESCRIPTION	
16	Z	33	34	NA	35	NA	36	NA	37	38	NA	39		
ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE		PERSONNEL EXPOSURES NUMBER		TYPE		DESCRIPTION		
17	0	0	0	37	Z	38	NA	39	0	0	0	40	NA	
PERSONNEL EXPOSURES		PERSONNEL INJURIES		LOSS OF OR DAMAGE TO FACILITY		PUBLICITY ISSUED		PERSONNEL EXPOSURES DESCRIPTION		PERSONNEL INJURIES DESCRIPTION		LOSS OF OR DAMAGE TO FACILITY DESCRIPTION		
18	0	0	0	40	NA	41	NA	42	Z	43	NA	44	NA	
PERSONNEL INJURIES		LOSS OF OR DAMAGE TO FACILITY		PUBLICITY ISSUED		PERSONNEL EXPOSURES DESCRIPTION		PERSONNEL INJURIES DESCRIPTION		LOSS OF OR DAMAGE TO FACILITY DESCRIPTION		PUBLICITY ISSUED DESCRIPTION		
19	Z	42	NA	43	NA	44	NA	45	NA	46	NA	47	NA	
PERSONNEL EXPOSURES DESCRIPTION		PERSONNEL INJURIES DESCRIPTION		LOSS OF OR DAMAGE TO FACILITY DESCRIPTION		PUBLICITY ISSUED DESCRIPTION		PERSONNEL EXPOSURES DESCRIPTION		PERSONNEL INJURIES DESCRIPTION		LOSS OF OR DAMAGE TO FACILITY DESCRIPTION		
20	N	44	NA	45	NA	46	NA	47	NA	48	NA	49	NA	
PUBLICITY ISSUED		PERSONNEL EXPOSURES DESCRIPTION		PERSONNEL INJURIES DESCRIPTION		LOSS OF OR DAMAGE TO FACILITY DESCRIPTION		PUBLICITY ISSUED DESCRIPTION		PERSONNEL EXPOSURES DESCRIPTION		PERSONNEL INJURIES DESCRIPTION		

800 731 0430