

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NY IPS 3 200-0000000+00 3411114 5

CON'T REPORT SOURCE L 05000286 7071680 8081280 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 WHILE AT HOT SHUTDOWN, AN OPERATOR MAKING A CONTAINMENT ENTRY NOTICED THE MOTOR COOLER ON FAN COOLER UNIT NO. 31 TO BE LEAKING. THE UNIT WAS IMMEDIATELY SHUT DOWN AND ISOLATED, AND MAINTENANCE FORCE WAS NOTIFIED. THIS INCIDENT FALLS UNDER THE JURISDICTION OF TECHNICAL SPECIFICATION 3.3.B.1.B., WHICH REQUIRES ALL FIVE FAN COOLER UNITS TO BE OPERATIONAL. AS THE PLANT WAS SUBCRITICAL AT THE TIME, NO IMMEDIATE ACTION WAS NECESSARY UNDER THE TECHNICAL SPECIFICATION.

09 SYSTEM CODE SB 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE BLOWER 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16 LER/RO REPORT NUMBER 17 EVENT YEAR 30 21 22 SHUTDOWN METHOD Z 21 HOURS 22 ATTACHMENT SUBMITTED N 23 NRPD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER W I 20 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27 THE REACTOR CONTAINMENT FAN COOLER UNIT MOTOR HEAT EXCHANGER (WESTINGHOUSE, STYLE 247C518G1) WAS REPLACED AND THE UNIT WAS RETURNED TO SERVICE WITHIN THE TIME LIMIT SET BY TECHNICAL SPECIFICATIONS 3.3.B.2.A. AND 3.3.B.3.C. NO SIMILAR EVENTS HAVE BEEN REPORTED TO DATE.

15 FACILITY STATUS G 28 % POWER 000 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION OPERATOR OBSERVATION 32

16 ACTIVITY CONTENT RELEASED OF RELEASE 7 33 7 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

17 PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION NA 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE 7 42 DESCRIPTION NA 43

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45 8008180413 NRC USE ONLY