

POWER AUTHORITY OF THE STATE OF NEW YORK
INDIAN POINT NO. 3 NUCLEAR POWER PLANT

P. O. BOX 215 BUCHANAN, N. Y. 10511

TELEPHONE: 914-739-8200



August 29, 1980

IP-JPD-9843

Docket No. 50-286

License No. DPR-64

Boyce H. Grier, Director
Office of Inspection and Enforcement
Region 1
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: I. E. Bulletin 80-15

Dear Mr. Grier:

Please be advised that the actions required to be taken by I. E. Bulletin 80-15 have been completed and the results summarized below.

Action Item 1

On June 26, 1980, a direct inspection of the Emergency Notification System at Indian Point 3 was conducted. From this inspection it was verified that the Emergency Notification System Station Package is located at the Central Telephone Offices in Peekskill, New York with back up power provided by batteries and Emergency Diesel at that location.

Action Item 2

Not applicable to Indian Point 3.

Action Item 3

On August 12, 1980, all extensions of the Emergency Notification System at Indian Point 3 were tested with the Station Package on back up power provided at the telephone company central offices. Satisfactory communication was established between Indian Point 3 and the Nuclear Regulatory Commission Operations Center on all four Emergency Notification System extensions of the Indian Point 3 circuit.

Action Item 4

Not applicable to Indian Point 3.

8010010673

Q

7

Boyce H. Grier

Page Two


August 29, 1980
IP-JPD-9843

Action Item 5

Indian Point 3 Administrative Procedure Number 8, Reporting of Significant Occurrences, was revised to include the requirement to notify the Nuclear Regulatory Commission Operations Center by commercial telephone, or relayed message, within one hour of the time that one or more extensions of the Emergency Notification System located at Indian Point 3 are found to be inoperable.

An estimated six hours was spent on the conduct of review of this bulletin.

Very truly yours,


S. S. Zulla
Resident Manager

JPD/bam

cc: U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D. C. 20555

Resident Inspector T. Rebelowski

State of New York)
County of Westchester) ss:

On this 29th day of August, 1980, personally appeared before me
S. S. Zulla, known to me as the person who executed the above document.



RUTHANNE B. BOWMAN
Notary Public, State of New York
No. 4651904, Westchester County
Commission Expires March 30, 1981