

LICENSEE EVENT REPORT

CONTROL BLOCK: _____

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	Y	I	P	S	B	2	0	0	-	0	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4	5	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36
LICENSEE CODE														LICENSE NUMBER										LICENSE TYPE				CAT 58	

0	1	L	6	0	5	0	0	0	2	8	6	7	1	1	1	5	8	0	8	1	2	1	1	8	0	9			
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36
CON'T		REPORT SOURCE		DOCKET NUMBER										EVENT DATE				REPORT DATE											

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | WHILE AT COLD SHUTDOWN, REVIEW OF SURVEILLANCE TEST 3PC-R4 (PRESSURIZER
 0 3 | PRESSURE CALIBRATION) INDICATED THAT PRESSURE TRANSMITTER PT-456B WAS
 0 4 | OUT OF SPECIFICATION IN THE NON-CONSERVATIVE DIRECTION. UNDER THESE
 0 5 | CONDITIONS, THE HIGH PRESSURE TRIP ASSOCIATED WITH PT-456 WOULD BE
 0 6 | NON-CONSERVATIVE BY 1 PSI. TECHNICAL SPECIFICATION 2.3.1.B.(B) REQUIRES
 0 7 | THE HIGH PRESSURE TRIP SETPOINT TO BE LESS THAN OR EQUAL TO 2385 PSIG.
 0 8 | ACTUAL SETPOINT WAS CALCULATED AT 2386 PSIG.

0	9	I	B	11	E	12	E	13	I	N	S	T	R	U	14	I	15	Z	16							
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26							
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE														
17	LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.																
18	E	19	Z	20	Z	21	0	0	0	22	0	3	L	32	0											
33	ACTION TAKEN	34	FUTURE ACTION	35	EFFECT ON PLANT	36	SHUTDOWN METHOD	37	HOURS	40	ATTACHMENT SUBMITTED	41	NPRD-4 FORM SUB.	42	PRIME COMP. SUPPLIER	43	COMPONENT MANUFACTURER	44	F	45	I	46	8	47	0	48

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A FOXBORO NR PRESSURE TRANSMITTER (MODEL NO. F11GM-SAF1, TRANSMITTER
 1 1 | PT-456) WAS ADJUSTED TO WITHIN SPECIFICATION REQUIREMENTS. THE CAUSE OF
 1 2 | THE EVENT WAS DETERMINED TO BE INSTRUMENT DRIFT. A SIMILAR EVENT
 1 3 | OCCURRED ON AUGUST 1, 1978(LER 78-021/03L-0).

1	5	G	28	0	0	0	29	NA	30	B	31	SURVEILLANCE TEST	32																
7	8	9	10	11	12	13	14	15	16	17	18	19	20																
FACILITY STATUS														% POWER				OTHER STATUS				METHOD OF DISCOVERY				DISCOVERY DESCRIPTION			
1	6	Z	33	Z	34	NA	35	NA	36	NA	37	NA	38																
7	8	9	10	11	12	13	14	15	16	17	18	19	20																
ACTIVITY CONTENT														AMOUNT OF ACTIVITY				LOCATION OF RELEASE											
1	7	0	0	0	37	Z	38	NA	39	NA	40	NA	41																
7	8	9	10	11	12	13	14	15	16	17	18	19	20																
PERSONNEL EXPOSURES														PERSONNEL INJURIES				LOSS OF OR DAMAGE TO FACILITY											
1	8	0	0	0	40	NA	41	NA	42	NA	43	NA	44																
7	8	9	10	11	12	13	14	15	16	17	18	19	20																
PERSONNEL EXPOSURES														LOSS OF OR DAMAGE TO FACILITY				PUBLICITY											
1	9	Z	42	NA	43	NA	44	NA	45	NA	46	NA	47																
7	8	9	10	11	12	13	14	15	16	17	18	19	20																
ACTIVITY CONTENT														PUBLICITY				ISSUED DESCRIPTION											
2	0	N	44	NA	45	8	0	1	2	1	5	0	1	3	5														
7	8	9	10	11	12	13	14	15	16	17	18	19	20																

8012150135

FLOYD W. GUMBLE

NAME OF PREPARER

PHONE:

914-739-8200, X217

NRC USE ONLY