

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.8001



Robert J. Barrett
Site Executive Officer

September 19, 1997
IPN-97-127

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

SUBJECT: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
**Completion of Generic Letter 96-01 Activities;
Testing of Safety-Related Logic Circuits**


- REFERENCES:
1. U.S. Nuclear Regulatory Commission Generic Letter 96-01;
"Testing of Safety-Related Logic Circuits," dated January 10, 1996.
 2. NYPA letter IPN-96-045, W. J. Cahill, Jr. to U.S. NRC;
"Response to Generic Letter 96-01," dated April 16, 1996.
 3. NYPA letter IPN-97-100, Robert J. Barrett to U.S. NRC;
"Incomplete Testing of Safety-Related Logic Circuits,"
(Licensee Event Report 97-011-00), dated July 28, 1997.

Dear Sir:

This letter is to inform you that the New York Power Authority has completed the requested actions of Generic Letter 96-01 (Reference 1) as previously committed in Reference 2. The Authority performed a drawing-to-procedure comparison review to determine if surveillance procedures for specified logic circuits adequately fulfill Technical Specification testing requirements. The review included logic circuits and test procedures for the reactor protection system, engineered safety feature actuation system, and emergency diesel generator load shedding / load sequencing logic. Several surveillance test procedures were revised based on the results of the comparison review. Logic circuit testing using the revised procedures was completed during August 1997 while Indian Point 3 was shut down for Refueling Outage 9.

Reference 3 contains additional information regarding review findings that were reported in accordance with 10 CFR 50.73. The Authority is making no new commitments in this letter. If you have any questions, please contact Mr Ken Peters.

Very truly yours,


Robert J. Barrett
Site Executive Officer
Indian Point 3 Nuclear Power Plant

300095




9709300347 970919
PDR ADOCK 05000286
P PDR

1/0
A067

State of New York)
)
County of Westchester)

James Comiotes, being duly sworn, deposes and says:

I am the acting Site Executive Officer of the Indian Point 3 Nuclear Power Plant of which the Power Authority of the State of New York is the owner and operator under Facility Operating License DPR-64. I have read the foregoing "Completion of Generic Letter 96-01 Activities; Testing of Safety-Related Logic Circuits" and know the contents thereof; and that the statements and matters set forth therein are true and correct to the best of my knowledge, information and belief.



James Comiotes

Subscribed and sworn to before me

this 19 day of September 1997.

Barbara Ann Taggart
Notary Public

BARBARA ANN TAGGART
NOTARY PUBLIC, State of New York
No. 4851437
Qualified in Putnam County
Commission Expires Jan. 27, 1998

cc: Regional Administrator
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector's Office
Indian Point Unit 3
U.S. Nuclear Regulatory Commission
P.O. Box 337
Buchanan, NY 10511

Mr. George F. Wunder, Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14 B2
Washington, DC 20555