

ATTACHMENT III TO IPN-97-168

**Core Operating Limits Report - Revision 3**

NEW YORK POWER AUTHORITY  
INDIAN POINT 3 NUCLEAR POWER PLANT  
DOCKET NO. 50-286  
DPR-64

9712220162 971212  
PDR ADOCK 05000286  
P PDR

**New  
York  
Power  
Authority  
Indian Point 3**

Procedure Use Is:

- Continuous
- Reference
- Information

Control Copy: \_\_\_\_\_

Effective Date: 3/29/95

**POP-2.3, Revision: 3**

**CORE OPERATING LIMITS REPORT FOR CYCLE 9**

<u>R.T. Thomas</u>	<u>3/7/95</u>
Writer	Date
<u>C. J. Reinger</u>	<u>3/8/95</u>
Reviewer	Date

Approved By:

<u>[Signature]</u>	<u>3/22/95</u>
Procedure Sponsor, DM/Designee	Date



95-056  
PORC Meeting Number

**GENERAL REVISION**

**CORE OPERATING LIMITS  
REPORT FOR CYCLE 9**

No: POP-2.3

Rev: 3

Page 1 of 5

**TABLE OF CONTENTS**

<b><u>Section</u></b>	<b><u>Title</u></b>	<b><u>Page</u></b>
1.0	PURPOSE .....	2
2.0	PRECAUTIONS AND LIMITATIONS .....	2
3.0	PREREQUISITES .....	2
4.0	PROCEDURE .....	2
5.0	REFERENCES .....	3
6.0	RECORDS AND DOCUMENTATION .....	3
	Attachment 1, Height Dependent FQ Multiplier K(Z) .....	4
	Attachment 2, Control Rod Insertion Limits VS. Relative Power .....	5

**CORE OPERATING LIMITS  
REPORT FOR CYCLE 9**

No: POP-2.3

Rev: 3

Page 2 of 5

**1.0 PURPOSE**

Presents cycle specific safety limits for the current operating cycle.

**2.0 PRECAUTIONS AND LIMITATIONS**

The data presented in this report applies to Cycle 9 Only and SHALL NOT be used for other operating cycles.

**3.0 PREREQUISITES**

None

**4.0 PROCEDURE**

The following are Cycle Specific Safety Limits:

<u>Limit</u>	<u>Corresponding T.S.</u>
4.1 Hot Channel Factors at Rated Thermal Power	
4.1.1 $F_Q^{RTP} = 2.32$	3.10.2.1
4.1.2 $F_{\Delta H}^{RTP} = 1.56$	3.10.2.1
4.2 Height Dependent $F_Q$ Multiplier $K(Z)$ , referred to as "fraction" (REFER to Attachment 1)	3.10.2.1
4.3 Power Factor Multiplier for $F_{\Delta H} = PF_{\Delta H} = 0.3$	3.10.2.1
4.4 Axial Flux Difference Band Width = $\pm 5\%$	3.10.2.4 3.10.2.6.1
4.5 Axial Flux Difference Envelope Limits at 90% power = -11%, +11%	3.10.2.6.1
4.6 Axial Flux Difference Envelope Increase for each 2% of rated power below 90% power = $\pm 1\%$	3.10.2.6.1
4.7 Shutdown Bank Position for Criticality = Fully Withdrawn	3.10.4.1
4.8 Control Bank Insertion Limits = (REFER to Attachment 2)	3.10.4.2

**CORE OPERATING LIMITS  
REPORT FOR CYCLE 9**

No: POP-2.3

Rev: 3

Page 3 of 5

**5.0 REFERENCES**

**5.1 Commitment Documents**

None

**5.2 Development Documents**

5.2.1 NRC Generic Letter 88-16

5.2.2 Technical Specifications

5.2.3 Indian Point Plant Unit 3 Cycle 9 Reload Safety Evaluation,  
May 1992

**5.3 Interface Documents**

None

**6.0 RECORDS AND DOCUMENTATION**


None

**CORE OPERATING LIMITS  
REPORT FOR CYCLE 9**

No: POP-2.3      Rev: 3

Page 4 of 5

**ATTACHMENT 1  
HEIGHT DEPENDENT FQ MULTIPLIER K(Z)  
(Page 1 of 1)**



Applies to FQ of 2.32

**CORE OPERATING LIMITS  
REPORT FOR CYCLE 9**

No: POP-2.3

Rev: 3

Page 5 of 5

**ATTACHMENT 2  
CONTROL ROD INSERTION LIMITS VS. RELATIVE POWER  
(Page 1 of 1)**

