

Mr. James Knubel  
Chief Nuclear Officer  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, NY 10601

September 8, 1999

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 3 - ISSUANCE OF  
AMENDMENT RE: REACTOR TRIP ON TURBINE TRIP (TAC NO. MA4696)

Dear Mr. Knubel:

The Commission has issued the enclosed Amendment No. 192 to Facility Operating License No. DPR-64 for the Indian Point Nuclear Generating Unit No. 3. The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated January 28, 1999, as supplemented by letter dated May 4, 1999. The amendment changes the reactor trip on turbine trip from at or above 10 percent rated power to at or above the P-8 setpoint.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

George F. Wunder, Project Manager, Section 1  
Project Directorate 1  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

9909100145 990908  
PDR ADOCK 05000286  
P PDR

Docket No. 50-286

Enclosures: 1. Amendment No. 192 to DPR-64  
2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION:

~~Docket File~~

PUBLIC

PDI-1 R/F

E. Adensam (E-mail)

S. Bajwa

S. Little

G. Wunder

OGC

G. Hill (2 copies)

W. Beckner

S. Sun

ACRS

M. Oprendeck, RGN-I

R. Scholl (E-mail SE only)

cc: Plant Service list

Y  
11  
DF01

003780834  
100051

**NRC FILE CENTER COPY**

DOCUMENT NAME: G:\PDI-1\IP3\Amda4696.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PDI-1/PA	PDI-1/LA	OGC	PDI-1/SC
NAME	GWunder:lcc	SLittle	R. Bachmann	SBajwa
DATE	08/23/99	08/23/99	08/31/99	09/3/99

OFFICIAL RECORD COPY



NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

September 8, 1999

Mr. James Knubel  
Chief Nuclear Officer  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, NY 10601

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 3 - ISSUANCE OF  
AMENDMENT RE: REACTOR TRIP ON TURBINE TRIP (TAC NO. MA4696)

Dear Mr. Knubel:

The Commission has issued the enclosed Amendment No.192 to Facility Operating License No. DPR-64 for the Indian Point Nuclear Generating Unit No. 3. The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated January 28, 1999, as supplemented by letter dated May 4, 1999. The amendment changes the reactor trip on turbine trip from at or above 10 percent rated power to at or above the P-8 setpoint.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink, appearing to read "George F. Wunder", is written over a horizontal line.

George F. Wunder, Project Manager, Section 1  
Project Directorate 1  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-286

Enclosures: 1. Amendment No. 192 to DPR-64  
2. Safety Evaluation

cc w/encls: See next page

Indian Point Nuclear Generating Station  
Unit No. 3

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Gerald C. Goldstein  
Assistant General Counsel  
Power Authority of the State  
of New York  
1633 Broadway  
New York, NY 10019

Mr. Eugene W. Zeltmann, President  
and Chief Operating Officer  
Power Authority of the State  
of New York  
99 Washington Ave., Suite # 2005  
Albany, NY 12210-2820

Mr. Robert J. Barrett  
Site Executive Officer  
Indian Point 3 Nuclear Power Plant  
P.O. Box 215  
Buchanan, NY 10511

Ms. Charlene D. Faison  
Director Nuclear Licensing  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, NY 10601

Mr. F. William Valentino, President  
New York State Energy, Research,  
and Development Authority  
Corporate Plaza West  
286 Washington Ave. Extension  
Albany, NY 12203-6399

Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

Resident Inspector  
Indian Point 3 Nuclear Power Plant  
U.S. Nuclear Regulatory Commission  
P.O. Box 337  
Buchanan, NY 10511

Mr. John McCann  
Nuclear Safety and Licensing  
Consolidated Edison Company  
of New York, Inc.  
Broadway and Bleakley Avenues  
Buchanan, NY 10511

Mayor, Village of Buchanan  
236 Tate Avenue  
Buchanan, NY 10511

Mr. Richard L. Patch, Director  
Quality Assurance  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, NY 10601

Mr. Paul Eddy  
New York State Dept. of  
Public Service  
3 Empire State Plaza, 10th Floor  
Albany, NY 12223

Mr. Harry P. Salmon, Jr.  
Vice President - Engineering  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, NY 10601

Mr. Eric Beckjord  
2909 29<sup>th</sup> St. NW  
Washington, DC 20008-3416