



UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545

SAFETY EVALUATION BY THE DIRECTORATE OF LICENSING
SUPPORTING AMENDMENT NO. 12 TO LICENSE NO. DPR-26
CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.
DOCKET NO. 50-247
INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

Introduction

In their letter of July 1, 1974, Consolidated Edison Company of New York, Inc. proposed a change to the Technical Specifications appended to Facility Operating License No. DPR-26 to provide for an expanded program of inservice inspection of the Indian Point Unit 2 pressure vessel.

Evaluation

We have reviewed each of the proposed changes in requirements for inservice inspection and have determined that the proposed new requirements will result in a significantly improved and more conservative inservice inspection program. We have also reviewed the proposed inservice program with respect to the ASME Boiler and Pressure Vessel Code Section XI (January 1, 1970) and have determined that it acceptably meets our requirements on an interim basis since the next inservice inspection will be accomplished during the next refueling shutdown in early 1976. Prior to that time, we will again review the Indian Point Unit 2 primary system inservice inspection program for consistency with current Commission requirements and the proposed (August 30, 1974) inservice inspection requirements for the steam generator tubes which we are now reviewing.

Conclusion

We have concluded that based on the consideration that the change will result only in an improved and more conservative inservice inspection program (1) the change does not involve a significant increase in the probability or consequences of accidents previously considered and does not involve a significant decrease in a safety margin, the change does not

8111050821 741231
PDR ADOCK 05000247
P PDR

involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Peter B Erickson

Peter B. Erickson
Operating Reactors Branch #3
Directorate of Licensing

Peter B Erickson

for

George Lear, Chief
Operating Reactors Branch #3
Directorate of Licensing

Date: DEC 31 1974