

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the matter of )  
)  
CONSOLIDATED EDISON COMPANY )  
OF NEW YORK, INC. )  
(Indian Point Station, )  
Unit No. 2) )

Docket No. 50-247

APPLICATION FOR AMENDMENT  
TO OPERATING LICENSE


Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission ("NRC"), Consolidated Edison Company of New York, Inc. ("Con Edison"), as holder of Facility Operating License No. DPR-26, hereby applies for amendment of the Technical Specifications contained in Appendix A of that license and a change to the Licensing Basis that allows:

- analog channel allowed outage times of 72 hours
- analog channel test bypass times of 12 hours
- logic cabinet and master relay allowed outage times of 24 hours
- On-line testing and maintenance of instrumentation

The proposed Technical Specification pages which support this amendment to Technical Specification Section 3.5.3, Basis for Instrument Operating Conditions (pages 3.5-2 to 3.5-6) and Tables 3.5-2 through 3.5-4, are provided as Attachment A. The Technical Specification pages in Attachment A also include editorial changes to properly align Columns 3 and 4 at No. 11 in Table 3.5-2 and relocate No. 18a in Table 3.5-2 to Table 3.5-3 where it will become No. 6. Attachment B to this application for amendment reflects the safety assessment supporting this change as well as the conclusion that the proposed change does not constitute a significant hazards consideration as defined in 10 CFR 50.92(c). Attachment C contains the determination of WCAP-14333 applicability to Indian Point Unit 2. Attachment D addresses Tier 2 and Tier 3 requirements as identified in WCAP-14333. Attachments C and D contain information proprietary to Westinghouse Electric Company. Attachment E provides a summary of the proposed changes. Attachment F contains the Affidavit for Withholding, the proprietary information notice, and the copyright notice in accordance with the requirements of 10 CFR 2.790. Attachment G contains the non-proprietary versions of Attachments C and D. Attachment H contains a list of commitments associated with the proposed change.

9907120169 990505  
PDR ADOCK 05000247  
P PDR

As required by 10 CFR 50.91(b)(1), a copy of this application and our analysis concluding that the proposed change does not constitute a significant hazards consideration has been provided to the appropriate New York State official designated to receive such amendments.

BY: 

James S. Baumstark  
Vice President

Subscribed and sworn to  
before me this 5<sup>th</sup> day  
of May, 1999

  
Notary Public

**KAREN L. LANCASTER**  
Notary Public, State of New York  
No. 60-4643659  
Qualified In Westchester County  
Term Expires 9/30/99