

James S. Baumstark
Vice President
Nuclear Engineering

Consolidated Edison Company of New York, Inc.
Indian Point 2 Station
Broadway & Bleakley Avenue
Buchanan, New York 10511

Internet: baumstarkj@coned.com
Telephone: (914) 734-5354
Cellular: (914) 391-9005
Pager: (917) 457-9698
Fax: (914) 734-5718

November 30, 1998

Re: Indian Point Unit No. 2
Docket No. 50-247

Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555-0001

Subject: Revised Response to Request for Additional Information - Generic
Letter 92-01, "Reactor Vessel Structural Integrity," for Indian Point
Unit No. 2. (TAC No. MA0547)


Reference: 1) Con Edison Letter to USNRC dated July 22, 1998
2) USNRC Letter to Con Edison dated April 15, 1998

The purpose of this letter is to provide new information which supplements Consolidated Edison Company of New York's, Inc. (Con Edison's) original response (Reference 1) to the NRC's request for additional information dated April 15, 1998 regarding Generic Letter 92-01 (Reference 2).

As a result of new information provided by Combustion Engineering (CE) in Report CE NPSD-1119, Revision 1, dated July 1998 entitled, "Updated Analysis for Combustion Engineering Fabricated Reactor Vessel Welds Best Estimate Copper and Nickel Content," we are submitting the following additional information. Table 1, which was submitted in Reference 1, has been revised to reflect slightly lowered nickel content for weld wire heats 34B009 and W5214 from 1.038% to 1.007%. The Indian Point Unit 2 limiting material, the plate from heat B2002-3, remains unaffected. Additionally, weld heat W5214, which is in our capsule program, had a ratio adjustment applied. A copy of CE report CE NPSD-1119 was previously provided to your Mr. Matthew Mitchell for information.

Con Edison is making no new regulatory commitments in this correspondence. Should you or your staff have any concerns regarding this matter, please contact Mr. Charles W. Jackson, Manager, Nuclear Safety & Licensing.

Very truly yours,



9812090101 981130
PDR ADDCK 05000247
P PDR

080076

11
AD 28

C: Mr. Hubert J. Miller
Regional Administrator-Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Jefferey F. Harold, Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
US Nuclear Regulatory Commission
Mail Stop 14B-2
Washington, DC 20555

Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

TABLE 1

Facility: Indian Point Unit No. 2

Vessel Manufacturer: Combustion Engineering

Information Requested on RPV Weld and/or Limiting Materials

RPV Weld Wire Heat	Best-Estimate Copper	Best-Estimate Nickel	EOL ID Fluence ($\times 10^{19}$)	Assigned Material Chemistry Factor (CF)	Method of Determining CF ⁽²⁾	Initial RT _{NDT} (RT _{NDT(U)})	σ_t	σ_Δ	Margin	ART or RT _{PTS} at EOL
34B009	0.192	1.007	1.2108	221.26	Table	-56 F	17	28	65.51	242.58
W5214	0.213	1.007	0.8526	244.67	Surveillance	-56 F	17	14	44.05	221.80
B2002-3 plate	0.20	0.59	1.2108	182.58	Surveillance	21 F	0	8.5	17.00	230.32

(1) or the material identification of the limiting material as requested in Section 1.0 (1.)

(2) determined from tables or from surveillance data

Note: Values changed are in bold type