

Stephen E. Quinn
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 734-5340

December 15, 1995

Re: Indian Point Station
Docket No. 50-247

Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

Dear Sir:

Enclosed is the Monthly Operating Report for Indian Point Unit No. 2 for
the month of November, 1995.

Very truly yours,



Enclosure

cc: Mr. Thomas T. Martin
Regional Administrator - Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

020016

9601020085 951130
PDR ADOCK 05000247
R PDR

IE 29
11

SUMMARY OF OPERATING EXPERIENCE

November, 1995

The unit operated at 100% reactor power for the entire month of November.

OPERATING DATA REPORT

DOCKET NO. 50-247
 DATE Dec. 12, 1995
 COMPLETED BY A. Reed
 TELEPHONE (914) 734-5155

OPERATING STATUS

1. Unit Name: Indian Point Unit #2
2. Reporting Period: November 1995
3. Licensed Thermal Power (MWt): 3071.4
4. Nameplate Rating (Gross MWe): 1310
5. Design Electrical Rating (Net MWe): 986
6. Maximum Dependable Capacity (Gross MWe): *985
7. Maximum Dependable Capacity (Net MWe): *951

Notes

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level To Which Restricted, If Any(Net MWe):

10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>720</u>	<u>8016</u>	<u>187753</u>
12. Number Of Hours Reactor Was Critical	<u>720</u>	<u>5140.79</u>	<u>133475.65</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>316.25</u>	<u>4434.77</u>
14. Hours Generator On-Line	<u>720</u>	<u>4844.25</u>	<u>130153.59</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2211408</u>	<u>13897519</u>	<u>359792270</u>
17. Gross Electrical Energy Generated (MWH)	<u>720795</u>	<u>4439171</u>	<u>110748732</u>
18. Net Electrical Energy Generated (MWH)	<u>695581</u>	<u>4239316</u>	<u>106024150</u>
19. Unit Service Factor	<u>100.0</u>	<u>60.4</u>	<u>69.3</u>
20. Unit Availability Factor	<u>100.0</u>	<u>60.4</u>	<u>69.3</u>
21. Unit Capacity Factor (Using MDC Net)	<u>101.6</u>	<u>56.4</u>	<u>64.3</u>
22. Unit Capacity Factor (Using DER Net)	<u>98.0</u>	<u>53.6</u>	<u>62.5</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>3.5</u>	<u>6.3</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
--	----------	----------

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-247

UNIT I.P. Unit #2

DATE 12/12/95

COMPLETED BY A. Reed

MONTH November 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>966</u>	17	<u>954</u>
2	<u>967</u>	18	<u>959</u>
3	<u>965</u>	19	<u>973</u>
4	<u>965</u>	20	<u>970</u>
5	<u>966</u>	21	<u>958</u>
6	<u>971</u>	22	<u>969</u>
7	<u>969</u>	23	<u>969</u>
8	<u>971</u>	24	<u>967</u>
9	<u>971</u>	25	<u>969</u>
10	<u>971</u>	26	<u>969</u>
11	<u>969</u>	27	<u>968</u>
12	<u>967</u>	28	<u>968</u>
13	<u>968</u>	29	<u>970</u>
14	<u>945</u>	30	<u>964</u>
15	<u>959</u>	31	<u>N/A</u>
16	<u>968</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt. (9/77)

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-247

UNIT I.P. Unit #2

DATE 12/12/95

COMPLETED BY A. Reed

TELEPHONE (914) 734-5155

REPORT MONTH November 1995

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
NONE									

1
F: Forced
S: Scheduled

2
Reason:
A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training & Licensee Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3
Method:
1 - Manual
2 - Manual Scram.
3 - Automatic Scram.
4 - Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets of Licensee Event Report (LER) File (NUREG-0161)

(9/77)

5
Exhibit 1 - Same Source

MAJOR SAFETY-RELATED CORRECTIVE MAINTENANCE

<u>MWO</u>	<u>System</u>	<u>Component</u>	<u>Date Completed</u>	<u>Work Performed</u>
70009	GAS	GASA	11/29/95	Completed alteration modification.
81157	CWP	26CWP	11/29/95	Changed relay on 26 CWP, in association with 22 battery charger.