

Paul H. Kinkel
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 734-5340
Fax: (914) 734-5923

April 15, 1998

Re: Indian Point Station
Docket No. 50-247

Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

Dear Sir:

Enclosed is the Monthly Operating Report for Indian Point Unit No. 2 for March 1998.

Very truly yours,

Paul H. Kinkel

Enclosure

cc: Mr. Hubert J. Miller
Regional Administrator - Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

Mr. Paul Eddy
State of New York Department of Public Service
3 Empire Plaza
Albany, NY 12223

220038

//
IE 24

9804220453 980331
PDR ADOCK 05000247
R PDR

AVERAGE DAILY POWER LEVEL

DOCKET NO. 50-247
 UNIT I.P. Unit #2
 DATE 04/03/98
 COMPLETED BY K. Krieger
 TELEPHONE (914)734-5146

MONTH March 1998

DAY	AVERAGE DAILY POWER LEVEL (Mwe-Net)	DAY	AVERAGE DAILY POWER LEVEL (Mwe-Net)
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	0
16	0		

INSTRUCTIONS

On this format, list the average daily unit power level in Mwe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

DOCKET NO. 50-247
 UNIT I.P. Unit #2
 DATE 04/03/98
 COMPLETED BY K. Krieger
 TELEPHONE (914)734-5146

REPORT MONTH March 1998

No.	Date	Type(1)	Duration (Hours)	Reason(2)	Method of Shutting Down Reactor	Licensee Event Report #	System Code (4)	Component Code (5)	Cause & Corrective Action to Prevent Recurrence
7	971015	S	672	B	1	97-24	ED	(CKT BKR) A	Continuing outage. Unit remains in cold shutdown.

(1)

F: Forced
S: Scheduled

(2)

Reason :
 A: Equipment Failure (Explain)
 B: Maintenance or Test
 C: Refueling
 D: Regulatory Restriction
 E: Operator Training & License Examination
 F: Administrative
 G: Operational Error (Explain)
 H: Other (Explain)

(3)

Method:
 1-Manual
 2- Manual Scram.
 3-Automatic Scram.
 4-Other Explain

(4)

Exhibit G-Instructions for Preparation of
 Data Entry Sheets for Licensee Event
 Report (LER) File (NUREG-0161)

(5)

Exhibit I - Same Source

(9/77)

SUMMARY OF OPERATING EXPERIENCE

March 1998

Unit 2 remained in cold shutdown for the entire month of March for a scheduled plant betterment outage. Work performed on major safety-related equipment included: removal of part-length control rod housings and capping of same, periodic maintenance of number 22 Emergency Diesel Generator (EDG), and periodic maintenance of number 21 Containment Fan Cooler Unit.

MAJOR SAFETY RELATED MAINTENANCE

W.O. #	SYSTEM	COMPONENT	DATE COMPLETED	WORK PERFORMED
98-98450	CA	Part Length Control Rod Housing	on-going	removal of part-length control rod housings and capping of same
98-96641	SB	21 Fan Cooler Unit	3/3/98	performed periodic maintenance
98-96656	EE	22 Emergency Diesel Generator	3/21/98	performed periodic maintenance