

OPERATING DATA REPORT

DOCKET NO. 50-247

DATE Nov. 4, 1998

COMPLETED BY K. Krieger

TELEPHONE (914)734-5146

OPERATING STATUS

Notes

1. Unit Name : Indian Point Unit #2
 2. Reporting Period : April 1998
 3. Licensed Thermal Power (Mwt) : 3071.4
 4. Nameplate Rating (Gross Mwe) : 1008
 5. Design Electrical Rating (Net Mwe) : 986
 6. Maximum Dependable Capacity (Gross Mwe) : * 965
 7. Maximum Dependable Capacity (Net Mwe) : * 931

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons :

* Summer ratings effective April 5, 1998.

9. Power Level To Which Restricted, If Any (Net Mwe) : _____

10. Reasons For Restrictions, If Any : _____

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	<u>719</u>	<u>2879</u>	<u>208920</u>
12. Number of Hours Reactor Was Critical	<u>0</u>	<u>0</u>	<u>146361.17</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>4566.64</u>
14. Hours Generator On-Line	<u>0</u>	<u>0</u>	<u>142746.88</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>397462837</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>122877285</u>
18. Net Electrical Energy Generated (MWH)	<u>- 2391</u>	<u>-10451</u>	<u>117642190</u>
19. Unit Service Factor	<u>0</u>	<u>0</u>	<u>68.3</u>
20. Unit Availability Factor	<u>0</u>	<u>0</u>	<u>68.3</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0</u>	<u>0</u>	<u>63.7</u>
22. Unit Capacity Factor (Using DER Net)	<u>0</u>	<u>0</u>	<u>61.8</u>
23. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>9.7</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup : Currently scheduled for June 13, 1998

26. Units In Test Status (Prior to Commercial Operation) :

Forecast

Achieved

INITIAL CRITICALITY

N/A

N/A

INITIAL ELECTRICITY

N/A

N/A

COMMERCIAL OPERATION

N/A

N/A

(9/77)

9811250161 981116
 PDR ADDOCK 05000247
 R PDR

DOCKET NO. 50-247
 UNIT I.P. Unit #2
 DATE 11/04/98
 COMPLETED BY K. Krieger
 TELEPHONE (914)734-5146

REPORT MONTH April 1998

No.	Date	Type(1)	Duration (Hours)	Reason(2)	Method of Shutting Down Reactor	Licensee Event Report #	System Code (4)	Component Code (5)	Cause & Corrective Action to Prevent Recurrence
7	971015	F	719	A	1	97-24	ED	(CKT BKR) A	Continuing outage. Unit remains in cold shutdown.

(1)
 F: Forced
 S: Scheduled

(2)
 Reason :
 A: Equipment Failure (Explain)
 B: Maintenance or Test
 C: Refueling
 D: Regulatory Restriction
 E: Operator Training & License Examination
 F: Administrative
 G: Operational Error (Explain)
 H: Other (Explain)

(3)
 Method:
 1-Manual
 2- Manual Scram.
 3-Automatic Scram.
 4-Other Explain

(4)
 Exhibit G-Instructions for Preparation of
 Data Entry Sheets for Licensee Event
 Report (LER) File (NUREG-0161)

(5)
 Exhibit I - Same Source

(9/77)