

OPERATING DATA REPORT

DOCKET NO. 50-247
 DATE Nov. 4, 1998
 COMPLETED BY K. Krieger
 TELEPHONE (914)734-5146

OPERATING STATUS

Notes

1. Unit Name : Indian Point Unit #2
2. Reporting Period : July 1998
3. Licensed Thermal Power (Mwt) : 3071.4
4. Nameplate Rating (Gross Mwe) : 1008
5. Design Electrical Rating (Net Mwe) : 986
6. Maximum Dependable Capacity (Gross Mwe) : 985
7. Maximum Dependable Capacity (Net Mwe) : 931

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons :

9. Power Level To Which Restricted, If Any (Net Mwe) : _____

10. Reasons For Restrictions, If Any : _____

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	<u>744</u>	<u>5087</u>	<u>211128</u>
12. Number of Hours Reactor Was Critical	<u>0</u>	<u>0</u>	<u>146361.17</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>4566.64</u>
14. Hours Generator On-Line	<u>0</u>	<u>0</u>	<u>142746.88</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>397462837</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>122877285</u>
18. Net Electrical Energy Generated (MWH)	<u>- 5120</u>	<u>-21491</u>	<u>117631150</u>
19. Unit Service Factor	<u>0</u>	<u>0</u>	<u>67.6</u>
20. Unit Availability Factor	<u>0</u>	<u>0</u>	<u>67.6</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0</u>	<u>0</u>	<u>63.0</u>
22. Unit Capacity Factor (Using DER Net)	<u>0</u>	<u>0</u>	<u>61.1</u>
23. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>10.9</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup : Currently scheduled for August 30, 1998

26. Units In Test Status (Prior to Commercial Operation) :

	Forecast	Achieved
INITIAL CRITICALITY	<u>N/A</u>	<u>N/A</u>
INITIAL ELECTRICITY	<u>N/A</u>	<u>N/A</u>
COMMERCIAL OPERATION	<u>N/A</u>	<u>N/A</u>

(9/77)

9811250166 981116
 PDR ADOCK 05000247
 R PDR

DOCKET NO. 50-247
 UNIT: I.P. Unit #2
 DATE 11/04/98
 COMPLETED BY K. Krieger
 TELEPHONE (914)734-5146

REPORT MONTH July 1998

No.	Date	Type(1)	Duration (Hours)	Reason(2)	Method of Shutting Down Reactor	Licensee Event Report #	System Code (4)	Component Code (5)	Cause & Corrective Action to Prevent Recurrence
7	971015	F	744	A	1	97-24	ED	(CKT BKR) A	Continuing outage. Unit remains in cold shutdown.

(1)
 F: Forced
 S: Scheduled

(2) Reason :
 A: Equipment Failure (Explain)
 B: Maintenance or Test
 C: Refueling
 D: Regulatory Restriction
 E: Operator Training & License Examination
 F: Administrative
 G: Operational Error (Explain)
 H: Other (Explain)

(3) Method:
 1-Manual
 2- Manual Scram.
 3-Automatic Scram.
 4-Other Explain

(4) Exhibit G-Instructions for Preparation of
 Data Entry Sheets for Licensee Event
 Report (LER) File (NUREG-0161)

(5) Exhibit I - Same Source

(9/77)