

Consolidated Edison Company of New York, Inc.  
4 Irving Place, New York, N Y 10003  
Telephone (212) 460-2533

November 20, 1980

RECEIVED DISTRIBUTION  
SERVICE UNIT

AM 11 49

DEC 1

US NRC  
DISTRIBUTION SERVICE  
BRANCH

Mr. Boyce H. Grier, Director  
Office of Inspection and Enforcement  
Region I  
U.S. Nuclear Regulatory Commission  
631 Part Avenue  
King of Prussia, PA 19406

RE: 30-Day Report (ETSR 5.6.2.1.b.) Concerning Oil  
Discharge from Indian Point Unit No. 2  
(Docket No. 50-247)

Dear Mr. Grier:

In accordance with site Environmental Technical Specification Requirement 2.3.3.1, the following report regarding an accidental oil spill is submitted.

On October 24, 1980, while the Unit was in the cold shutdown condition, a small quantity of oil collected in the five foot elevation conventional plant sump and with water from the sump was automatically pumped into the circulating water discharge canal, with approximately three to five gallons of oil passing through the outfall structure into the river. The source of the oil was from maintenance activities on the fifteen foot elevation. The spill was discovered as a result of visual observation of the common discharge canal and the river near the discharge.

To correct this situation the following action was taken. The sump pump was shutdown and the sump area cleaned. An oil boom was deployed outside the outfall structure and absorbent pads were used to remove the oil. Required notifications concerning the spill were made.


C003  
5/10

No adverse effects on biota are expected nor were any such effects observed in the area of concern in the river near the outfall structure.

Operations and maintenance personnel have been re-instructed to promptly clean up any oil spills.

If there are any questions about this report, please contact me.

Very truly yours,



John D. O'Toole  
Assistant Vice President

Attachments

cc: Mr. Harold R. Denton  
Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Mr. T. Rebelowski, Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 38  
Buchanan, N.Y. 10511

Mr. Louis Condra  
Director of Regulatory Affairs  
New York State Department of  
Environmental Conservation  
50 Wolf Road  
Albany, N.Y. 12233

Mr. Cesare Manfredi, Associate Sanitary Engineer  
New York State Department of  
Environmental Conservation  
202 Mamaroneck Avenue  
White Plains, N.Y. 10601