

APR 07 1993

Docket No. 50-247

Mr. Stephen Bram
Vice President - Nuclear Power
Consolidated Edison Company of
New York, Inc.
Indian Point Station
Broadway and Bleakley Avenue
Buchanan, New York 10511

Dear Mr. Bram:

SUBJECT: NRC REGION I INSPECTION REPORT NO. 50-247/93-03

This letter transmits the findings of the safety inspection conducted by Mr. H. Kaplan of this office on February 8-11, 1993, and March 9-12, 1993, at the Indian Point Nuclear Generating Station, Unit 2, Buchanan, New York.

The inspection covered several areas which are important to safety and the integrity of the pressure boundary. These were the steam generator upper girth weld, steam generator eddy current tube inspection, and the inservice inspection program. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel and observation of activities in progress.

The ultrasonic inspection of the upper girth weld in steam generator #21 did not disclose any rejectable indications in the recently deposited weld metal. The ISI program was found to be well organized and in accordance with code requirements as demonstrated by surface (MT) and volumetric examinations (UT) of a boiler feed line weld. Preliminary eddy current inspection results of the steam generator tubes indicated that tube degradation was minimal and had not increased significantly since 1984. No violations or deviations were found during the inspection.

OFFICIAL RECORD COPY
A:IP9303.HK

9304130092 930407
PDR ADDCK 05000247
Q PDR

TEC 11/1

APR 07 1993

Mr. Stephen Bram

2

Your cooperation with us is appreciated.

Sincerely,

Jacque P. Durr, Chief
Engineering Branch
Division of Reactor SafetyEnclosure: Region I

Inspection Report No. 50-247/93-03

cc w/encl:

C. Jackson, Manager, Nuclear Safety and Licensing

B. Brandenburg, Assistant General Counsel

P. Kokolakis, Director, Nuclear Licensing

C. Donaldson, Esquire, Assistant Attorney General, New York Department of Law
Director, Energy & Water Division, Department of Public Service, State of New York

W. Stein, Secretary - NFSC

K. Abraham, PAO (2)

Public Document Room (PDR)

Local Public Document Room (LPDR)

Nuclear Safety Information Center (NSIC)

NRC Resident Inspector

State of New York, SLO Designee

OFFICIAL RECORD COPY
A:IP9303.HK

APR 07 1993

Mr. Stephen Bram

3

bcc w/encl:

Region I Docket Room (with concurrences)

C. Cowgill, DRP

J. Yerokun, DRP

L. Nicholson, DRP

S. Greenlee, DRP

G. Hunegs, SRI - IP-2

V. McCree, OEDO

R. Capra, NRR

M. Williams, NRR

DRS/EB SALP Coordinator

D. Holody, EO

W. Lanning, DRS

RI:DRS

Kaplan

LR

3/30/93

RI:DRS

Gray

Elfa.

3/30/93

RI:DRS

Durr

4/6/93

OFFICIAL RECORD COPY
A:IP9303.HK