ENCLOSURE 1

NOTICE OF VIOLATION

Consolidated Edison Company of New York, Inc.
Indian Point Nuclear Generating Station Unit 2

Docket No. 50-247
License No. DPR-26

During an NRC inspection conducted from January 1 through February 9, 1998, violations of NRC requirements were identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," NUREG-1600, the violations are listed below:

A. Technical Specification (TS) Section 6.8.1 requires that written procedures be implemented covering activities referenced in Regulatory (Safety) Guide 1.33, November 1972. Appendix A of Regulatory Guide 1.33 recommends written procedures that govern procedure adherence. Station Administrative Order (SAO)-133, "Procedure, Technical Specification and License Adherence and Use Policy," section 5.1.1, states that procedures shall be followed. SAO-702,"Control of Ignition Sources," Section 4.3.3, states that a fire watch shall be present during all work activities (i.e. work involving an ignition source) and that fire watch responsibilities are delineated in SAO-705, "Fire Watch Tour."

Contrary to the above, on January 6, 1998, a maintenance worker performed grinding (an ignition source activity) absent the required fire watch, and the fire watch left his assigned post to retrieve a tool from the tool room.

This is a Severity Level IV Violation (Supplement I)

B. 10 CFR Part 50, Appendix B, Criterion V, states in part, that activities affecting quality shall be prescribed by drawings of a type appropriate to the circumstance and shall be accomplished in accordance with these drawings. Drawings shall include appropriate quantitative or qualitative acceptance criteria for determining that important activities have been satisfactorily accomplished.

Contrary to this requirement, an inaccurate drawing contributed to the installation of an improperly sized relay in the control circuitry for the 23 emergency diesel generator. During post-modification testing on January 29, 1998, the relay was damaged and required the diesel to be secured from testing.

This is a Severity Level IV Violation (Supplement I)

Pursuant to the provisions of 10 CFR 2.201, Consolidated Edison Company of New York, Inc., is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region I, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of receipt of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation or severity level, (2) the

9804030252 980325
PDR ADOCK 05000247
Q PDR

corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. Your response may reference or include previous docketed correspondence, if the correspondence adequately addresses the required response. Where good cause is shown, consideration will be given to extending the response time.

If you contest this enforcement action, you should also provide a copy of your response to the Director, Office of Enforcement, United States Nuclear Regulatory Commission, Washington, DC 20555-0001.

Because your response will be placed in the NRC Public Document Room (PDR), to the extent possible, it should not include any personal privacy, proprietary, or safeguards information, so that it can be placed in the PDR without redaction. If personal privacy or proprietary information is necessary to provide an acceptable response, then please provide a bracketed copy of your response that identifies the information that should be protected and a redacted copy of your response that deletes such information. If you request withholding of such material, you must specifically identify the portions of your response that you seek to have withheld and provide in detail the bases for your claim of withholding (e.g., explain why the disclosure of information will create an unwarranted invasion of personal privacy or provide the information required by 10 CFR 2.790(b) to support a request for withholding confidential commercial or financial information). If safeguards information is necessary to provide an acceptable response, please provide the level of protection described in 10 CFR 73.21.

Dated at King of Prussia, PA
this 25th day of March, 1998