

## LevyCountyRAIsPEm Resource

---

**From:** Anderson, Brian  
**Sent:** Tuesday, February 16, 2010 11:42 AM  
**To:** LevyCountyRAIsPEm Resource  
**Subject:** REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 081 RELATED TO SRP SECTION 2.5.2 FOR THE LEVY COUNTY UNITS 1 AND 2 COMBINED LICENSE APPLICATION  
**Attachments:** LNP-RAI-LTR-081.doc  
**Importance:** High

**Hearing Identifier:** Levy\_County\_COL\_eRAIs  
**Email Number:** 81

**Mail Envelope Properties** (B46615B367D1144982B324704E3BCEED214E2AC11F)

**Subject:** REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 081 RELATED TO SRP SECTION 2.5.2 FOR THE LEVY COUNTY UNITS 1 AND 2 COMBINED LICENSE APPLICATION  
**Sent Date:** 2/16/2010 11:42:02 AM  
**Received Date:** 2/16/2010 11:42:07 AM  
**From:** Anderson, Brian

**Created By:** Brian.Anderson@nrc.gov

**Recipients:**  
"LevyCountyRAIsPEm Resource" <LevyCountyRAIsPEm.Resource@nrc.gov>  
Tracking Status: None

**Post Office:** HQCLSTR01.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	3	2/16/2010 11:42:07 AM
LNP-RAI-LTR-081.doc	62970	

**Options**  
**Priority:** High  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**

February 16, 2010

Mr. Garry Miller  
General Manager, Nuclear Plant Development  
Progress Energy Florida, Inc.  
PO Box 1551  
411 Fayetteville Street Mall  
Raleigh, NC 27602

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 081 RELATED TO  
SRP SECTION 2.5.2 FOR THE LEVY COUNTY NUCLEAR PLANT, UNITS 1  
and 2 COMBINED LICENSE APPLICATION

Dear Mr. Miller:

By letter dated July 28, 2008, as supplemented by a letter dated September 12, 2008, Progress Energy Florida, Inc. submitted its application to the U. S. Nuclear Regulatory Commission (NRC) for a combined license (COL) for two AP1000 advanced passive pressurized water reactors pursuant to 10 CFR Part 52. The NRC staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within 30 days of the date of this letter. If changes are needed to the final safety analysis report, the staff requests that the RAI response include the proposed wording changes.

If you have any questions or comments concerning this matter, you may contact me at 301-415-9967.

Sincerely,

**/RA/**

Brian C. Anderson, Lead Project Manager  
AP1000 Projects Branch 1  
Division of New Reactor Licensing  
Office of New Reactors

Docket Nos. 52-029  
52-030

eRAI Tracking No. 4283

Enclosure:  
Request for Additional Information

If you have any questions or comments concerning this matter, you may contact me at 301-415-9967.

Sincerely,

**/RA/**

Brian C. Anderson, Lead Project Manager  
AP1000 Projects Branch 1  
Division of New Reactor Licensing  
Office of New Reactors

Docket Nos. 52-029  
52-030

eRAI Tracking No. 4283

Enclosure:  
Request for Additional Information

Distribution:

Public	SCoffin	TSimms	WBieganousky
RidsNroDnrINwe1	JSebrosky	SGoetz	GStirewalt
RidsNroLAKGoldstein	BHughes	DHabib	RKaras
RidsOgcMailCenter	MComar	JMartin	CMunson
RidsAcrsAcnw_MailCenter	DMcGovern	TSpicher	VGraizer
RidsRgn2MailCenter	RJoshi	BAnderson	

NRO-002

OFFICE	RGS1/BC	NWE1/PM	NWE1/L-PM
NAME	RKaras *	BAnderson *	BAnderson*
DATE	01/22/10	01/23/10	02/16/10

\*Approval captured electronically in the electronic RAI system.

**OFFICIAL RECORD COPY**

**Request for Additional Information**  
**Levy County, Units 1 and 2**  
**Progress Energy Florida, Inc.**  
**Docket No. 52-029 and 52-030**  
**SRP Section: 02.05.02 - Vibratory Ground Motion**  
**Application Section: 2.5.2**

**QUESTIONS for Geosciences and Geotechnical Engineering Branch 2 (RGS2)**

02.05.02-22

FSAR Subsections 2.5.2.2.2.5 and 2.5.2.4.1 state that you used the South Texas Project (STP) approach in updating the EPRI-SOG seismic source parameters for the Gulf Coast seismic zones. The STP 3 & 4 FSAR incorporated contributions from seismic sources in the Gulf of Mexico through an update of the seismicity catalog and the maximum magnitude probability distributions of Gulf of Mexico source zones for five of the six EPRI-SOG Earth Science Teams (ESTs) based on the occurrence of two moderate 2006 earthquakes ( $m_b$  5.5 and 6.1) in the Gulf of Mexico. The original probabilities and updates are shown in Levy FSAR Table 2.5.2-209.

In response to STP RAI 2.5.2-21 (ADAMS Accession No. ML092170354), the staff received details of the process that resulted in the updates to  $M_{max}$ . That RAI response (ML092710096) describes the STP approach and states that the SSHAC TI team's original recommendation was for a  $M_{max}$  distribution that ranged from magnitude ( $m_b$ ) 6.1 to 7.2 (6.1 [0.1], 6.6 [0.4], 6.9 [0.4], 7.2 [0.1]). The weighted average of this  $M_{max}$  distribution is  $m_b$  6.73. However, the SSHAC peer review panel did not approve of this  $M_{max}$  distribution on the bases that "the  $M_{max}$  value used by the USGS was not developed through a formal SSHAC process, was not intended to capture the 'legitimate range of technically supportable interpretations among the entire informed technical community' (NUREG/CR-6372, page 6), and was primarily developed to reflect hazard associated with the short return periods of building codes." Instead the SSHAC peer review panel recommended that the individual  $M_{max}$  distributions for five of the six ESTs Gulf source zones be updated. The weighted average of the updated  $M_{max}$  values for the five ESTs is  $m_b$  6.14.

Concerning the adopted  $M_{max}$  distributions for the Gulf of Mexico source zones, the staff requests the following:

1. Please provide details and the basis for updating  $M_{max}$  for the EPRI ESTs  $M_{max}$  distributions, as shown in FSAR Table 2.5.2-209. Include a description of the updated information that will be incorporated into the FSAR.
2. Provide justification for rejecting the USGS  $M_{max}$  value ( $m_b$  7.2) as representing a legitimate end member of the informed technical community.
3. Provide justification for not adopting the original TI team's  $M_{max}$  distribution. The TI team's original recommendation was for a  $M_{max}$  distribution that ranged from magnitude ( $m_b$ ) 6.1 to 7.2, not solely a single value  $m_b$  7.2, on which the USGS 2002 National Hazard Map places a weight of 1.0. There is a significant difference between the two weights (0.1 for TI team versus 1.0 for USGS) for the  $M_{max}$  value of  $m_b$  7.2.

4. The weighted average of the adopted Mmax distributions for the five ESTs that had updated values is just  $m_b$  6.14. This is about the same magnitude ( $m_b$  6.1) as the September 10, 2006 Gulf earthquake. Considering this result, provide justification for the modest updates to the Mmax values for five of the six ESTs Gulf Coast models.
5. In view of the two 2006 Gulf Coast earthquakes, describe how the limited Woodward Clyde Consultant's source model adequately characterizes the hazard for the Gulf.