

ATTACHMENT E

PROPOSED ADDITION TO THE CORE OPERATING LIMIT REPORT

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.
INDIAN POINT UNIT NO. 2
DOCKET NO. 50-247
JUNE, 1994

9406100194 940601
PDR ADCK 05000247
P PDR

Power Limits for Extended RPI Duration Bands and On-Line Calibration

Item	TS Sections	Limits
Maximum Power for on-line calibration	3.10.4.4 3.10 Basis	50% Power
Maximum Power for ± 24 Step Deviation	3.10.6.1 3.10 Basis	85% Power

PROP

PROPRIETARY INFORMATION

NOTICE

THE ATTACHED DOCUMENT CONTAINS OR IS CLAIMED TO CONTAIN PROPRIETARY INFORMATION AND SHOULD BE HANDLED AS NRC SENSITIVE UNCLASSIFIED INFORMATION. IT SHOULD NOT BE DISCUSSED OR MADE AVAILABLE TO ANY PERSON NOT REQUIRING SUCH INFORMATION IN THE CONDUCT OF OFFICIAL BUSINESS AND SHOULD BE STORED, TRANSFERRED, AND DISPOSED OF BY EACH RECIPIENT IN A MANNER WHICH WILL ASSURE THAT ITS CONTENTS ARE NOT MADE AVAILABLE TO UNAUTHORIZED PERSONS.

COPY NO. _____

DOCKET NO. _____

CONTROL NO. _____

REPORT NO. _____

REC'D W/LTR DTD. _____