WESTINGHOUSE NON-PROPRIETARY CLASS 3

INDIAN POINT UNIT 2 HEATUP AND COOLDOWN LIMIT CURVES FOR NORMAL OPERATION

P. A. Grendys

August 1996

Work Performed Under Shop Order IZGP-139

Prepared by the Westinghouse Electric Corporation for Consolidated Edison

Approved by:

D. E. Boyle, Manager / Reactor Equipment & Materials Engineering

WESTINGHOUSE ELECTRIC CORPORATION Systems and Major Projects Division P.O. Box 355 Pittsburgh, Pennsylvania 15230-0355

© 1996 Westinghouse Electric Corporation All Rights Reserved

9610160092 961002

ADDCK

PDR

0500024

PDR

PREFACE

This report has been technically reviewed and verified by:

E. Terek <u>E. Terk</u> W. H. Bamford ______

TABLE OF CONTENTS

Section	Title	<u>Page</u>
	LIST OF TABLES	iii
	LIST OF ILLUSTRATIONS	iv
1.0	INTRODUCTION	1
2.0	FRACTURE TOUGHNESS PROPERTIES	2
3.0	CRITERIA FOR ALLOWABLE PRESSURE-TEMPERATURE RELATIONSHIPS	4
4.0	CALCULATION OF ADJUSTED REFERENCE TEMPERATURE	10
5.0	HEATUP AND COOLDOWN PRESSURE-TEMPERATURE LIMIT CURVES	13
6.0	REFERENCES	21
APPENDI	X A - TABULATION OF PRESSURE AND K, VALUES FOR THE NEW APPENDIX G AND RAJU-NEWMAN METHODOLOGIES	A-0
APPENDL	K B - SUMMARY OF VESSEL AND MATERIAL PROPERTIES USED IN THE GENERATION OF THE HEATUP/COOLDOWN CURVES	· B- 0

LIST OF TABLES

<u>Table</u>	Title	Page
1	Indian Point Unit 2 Reactor Vessel Beltline Region Material Properties	3
2	Chemistry Factor Values Using Indian Point Unit 2 Surveillance Capsule Data	3
3	Fluence $(10^{19} \text{ n/cm}^2, \text{E} > 1.0 \text{ MeV})$ on the Pressure Vessel Clad/Base Metal Interface for Indian Point Unit 2	10
4	Calculation of ART Values for the Limiting Indian Point Unit 2 Reactor Vessel Material Intermediate Shell B2002-3	11
5	Summary of ART Values at the 1/4T and 3/4T Locations	12
6	21.63 EFPY Heatup and Cooldown Curve Data Points Using Appendix G (without Margins for Instrumentation Errors)	17
7	21.63 EFPY Heatup and Cooldown Curve Data Points Using Raju-Newman (without Margins for Instrumentation Errors)	20
A-1	Comparison Between ASME Appendix G and Raju-Newman P-T Limit Curves at Select Temperatures	A-1
A-2	ASME Appendix G Versus Raju-Newman Stress Intensity Factors - Steady State and Cooldown Curves	A-2
A-3	ASME Appendix G Versus Raju-Newman Stress Intensity Factors - Heatup Curves	A-3

LIST OF ILLUSTRATIONS

1

2

3

4

Indian Point Unit 2 Reactor Coolant System Heatup Limitations (Heatup Rates up to 100°F/hr) Applicable for the First 21.63 EFPY Using ASME Section XI, Appendix G Methodology (Without Margins for Instrumentation Errors) Includes vessel flange requirements of 180°F and 621 psig per 10CFR50, Appendix G.

Indian Point Unit 2 Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 100°F/hr) Applicable for the First 21.63 EFPY Using ASME Section XI, Appendix G Methodology (Without Margins for Instrumentation Errors) Includes vessel flange requirements of 180°F and 621 psig per 10CFR50, Appendix G.

Indian Point Unit 2 Reactor Coolant System Heatup Limitations (Heatup Rates up to 100°F/hr) Applicable for the First 21.63 EFPY Using the Raju-Newman Methodology (Without Margins for Instrumentation Errors) Includes vessel flange requirements of 180°F and 621 psig per 10CFR50, Appendix G.

Indian Point Unit 2 Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 100°F/hr) Applicable for the First 21.63 EFPY Using the Raju-Newman Methodology (Without Margins for Instrumentation Errors) Includes vessel flange requirements of 180°F and 621 psig per 10CFR50, Appendix G.

iv

Page

15

16

18

SECTION 1.0 INTRODUCTION

Heatup and cooldown limit curves are calculated using the adjusted RT_{NDT} (reference nil-ductility temperature) corresponding to the limiting beltline region material of the reactor vessel. The adjusted RT_{NDT} of the limiting material in the core region of the reactor vessel is determined by using the unirradiated reactor vessel material fracture toughness properties, estimating the radiation-induced ΔRT_{NDT} , and adding a margin. The unirradiated RT_{NDT} is designated as the higher of either the drop weight nil-ductility transition temperature (NDTT) or the temperature at which the material exhibits at least 50 ft-lb of impact energy and 35-mil lateral expansion (normal to the major working direction) minus 60°F.

 RT_{NDT} increases as the material is exposed to fast-neutron radiation. Therefore, to find the most limiting RT_{NDT} at any time period in the reactor's life, ΔRT_{NDT} due to the radiation exposure associated with that time period must be added to the unirradiated RT_{NDT} (IRT_{NDT}). The extent of the shift in RT_{NDT} is enhanced by certain chemical elements (such as copper and nickel) present in reactor vessel steels. The Nuclear Regulatory Commission (NRC) has published a method for predicting radiation embrittlement in Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials"⁽¹¹⁾. Regulatory Guide 1.99, Revision 2, is used for the calculation of Adjusted Reference Temperature (ART) values (IRT_{NDT} + ΔRT_{NDT} + margins for uncertainties) at the 1/4T and 3/4T locations, where T is the thickness of the vessel at the beltline region measured from the clad/base metal interface. The most limiting ART values are used in the generation of heatup and cooldown pressure-temperature limit curves.

SECTION 2.0

FRACTURE TOUGHNESS PROPERTIES

The fracture-toughness properties of the ferritic material in the reactor coolant pressure boundary are determined in accordance with the NRC Standard Review Plan^[2]. The pertinent chemical and mechanical properties of beltline region plate and weld materials of the Indian Point Unit 2 reactor vessel are presented in Table 1. This data was obtained from WCAP-12796^[3], *Heatup and Cooldown Limit Curves for the Consolidated Edison Company Indian Pint Unit 2 Reactor Vessel*, dated January 1991. (Per Art Ginsberg of Consolidated Edison, the same adjusted reference temperatures documented in WCAP-12796 are to be used in the generation of the current heatup and cooldown limit curves. Therefore, the pertinent vessel information presented in WCAP-12796 is also presented here for completeness.)

The chemistry factor (CF) values and margin terms also shown in Table 1 were determined in accordance with Tables 1 and 2 of Regulatory Guide 1.99, Revision 2. Chemistry factor (CF) values and margin terms in Table 1 that were based upon credible surveillance measurements are also given for the beltline region materials where this data was available. Table 2 presents the chemistry factor values based on surveillance data in addition to those calculated per Tables 1 and 2 of Regulatory Guide 1.99, Revision 2. (Complete calculations are presented in WCAP-12796.)

TABLE 1

Material	Cu (wt %)	Ni (wt %)	CF ^(g) (°F)	IRT _{NDT} ^(a) (°F)	M ^(b,c,d) (°F)
Intermediate Shell B2002-1 ^(f)	0.19	0.65	144 (108.85)	34	34 (17)
Intermediate Shell B2002-2 ^(f)	0.17	0.46	115 (115.86)	21	34 (17)
Intermediate Shell B2002-3 ^(f)	0.25	0.60	176 (183.02)	21	34 (17)
Lower Shell B2003-1	0.20	0.66	152	20	34
Lower Shell B2003-2	0.19	0.60	142	-20	34
Weld Metal	0.20	1.03	226 (236.01)	-56	66 (44.05)
Closure Head Flange (e)				60	
Vessel Flange ^(e)				60	

Indian Point Unit 2 Reactor Vessel Beltline Region Material Properties

NOTES:

(a) The initial RT_{NDT} (IRT_{NDT}) values for the plates are measured values; the initial RT_{NDT} value for the weld is generic.

- (b) Margin (M) as per Regulatory Guide 1.99, Revision 2; the standard deviation for the IRT_{NDT} margin term for the plates are assumed to be 0°F since the IRT_{NDT} values were obtained from conservative (i.e. "upper bound") test results.
- (c) Margin (M) as per Regulatory Guide 1.99, Revision 2; the standard deviation for the IRT_{NDT} margin term for the weld is 17°F.
- (d) Numbers is parenthesis () correspond to surveillance capsule data.
- (e) Initial RT_{NDT} values for the closure head flange and vessel flange will be considered for the adjustment of heatup/cooldown curves per 10 CFR Part 50, Appendix G.
- (f) Cu and Ni contents are based on the Capsule V report, SwRI Report 17-2108^[4] (revised) March 1990.
- (g) Chemistry Factor (CF) values are based on Regulatory Guide 1.99, Revision 2, Tables 1 and 2, and surveillance capsule data (shown in parenthesis).

TABLE 2

Chemistry Factor Values Using Indian Point Unit 2 Surveillance Capsule Data

Material	Chemistry Factor (°F)
Intermediate Shell B2002-1	108.85
Intermediate Shell B2002-2	115.86
Intermediate Shell B2002-3	183.02
Weld Metal	236.02



SECTION 3.0

CRITERIA FOR ALLOWABLE PRESSURE-TEMPERATURE RELATIONSHIPS

Appendix G to 10 CFR Part 50, "Fracture Toughness Requirements"^[5] specifies fracture toughness requirements for ferritic materials of pressure-retaining components of the reactor coolant pressure boundary of light water nuclear power reactors to provide adequate margins of safety during any condition of normal operation, including anticipated operational occurrences and system hydrostatic tests, to which the pressure boundary may be subjected over its service lifetime. The ASME Boiler and Pressure Vessel Code forms the basis for these requirements. Section XI, Division 1, "Rules for Inservice Inspection of Nuclear Power Plant Components"^[6], *Fracture Toughness Criteria for Protection Against Failure*, contains the conservative methods of analysis.

The ASME approach for calculating the allowable limit curves for various heatup and cooldown rates specifies that the total stress intensity factor, K_{I} , for the combined thermal and pressure stresses at any time during heatup or cooldown cannot be greater than the reference stress intensity factor, K_{Ia} , for the metal temperature at that time. K_{Ia} is obtained from the reference fracture toughness curve, defined in Appendix G of the ASME Code, Section XI. The K_{Ia} curve is given by the following equation:

$$K_{l_{0}} = 26.78 + 1.233 * e^{(0.0145(T - RTNDT + 160))}$$
(1)

where,

 K_{la} = reference stress intensity factor as a function of the metal temperature T and the metal reference nil-ductility temperature RT_{NDT}

Therefore, the governing equation for the heatup-cooldown analysis is defined in Appendix G of the ASME Code as follows:

$$C * K_{lm} + K_{ll} < K_{la} \tag{2}$$

where,

 K_{tm} = stress intensity factor caused by membrane (pressure) stress

 K_{it} = stress intensity factor caused by the thermal gradients

 K_{Ia} = function of temperature relative to the RT_{NDT} of the material

C = 2.0 for Level A and Level B service limits



New ASME Section XI, Appendix G Methodology^[6]

Appendix G was recently revised to incorporate the most recent elastic solutions for K_1 due to pressure and radial thermal gradients. The new solutions are based on finite element analyses for inside surface flaws performed at Oak Ridge National Laboratories and sponsored by NRC, and work published for outside surface flaws. These solutions provide results that are essentially the same as those obtained by using solutions previously developed by Raju and Newman^[7]

This revision now provides consistent computation methods for pressure and thermal K_1 for thermal gradient through the vessel wall at any time during the transient. Consistent with the original version of Appendix G, no contribution for crack face pressure is included in the K_1 due to pressure, and cladding effects are neglected.

Using these most recent elastic solutions in the low temperature region will provide some relief to restrictions associated with reactor operation at relatively low temperature. Although the relief is relatively small in terms of absolute allowable pressure, the benefits are substantial because even a small increase in the allowable pressure can be a significant percentage increase in the operating window at relatively low temperatures. Implementing this revision results in an economic and potential safety benefit (less likelihood of lifting LTOP pressure relieving devices) with no reduction in vessel integrity.

The following revisions were made to ASME Section XI, Appendix G: G-2214.1 Membrane Tension:

$$K_{lm} = M_m x \left(pR/t \right) \tag{3}$$

where M_m for an inside surface flaw is given by:

 $M_m = 1.85$ for $\sqrt{t} < 2$, $M_m = 0.926\sqrt{t}$ for $2 \le \sqrt{t} \le 3.464$, $M_m = 3.21$ for $\sqrt{t} > 3.464$

Similarly, M_m for an outside surface flaw is given by:

$$M_m = 1.77$$
 for $\sqrt{t} < 2$,
 $M_m = 0.893\sqrt{t}$ for $2 \le \sqrt{t} \le 3.464$,
 $M_m = 3.09$ for $\sqrt{t} > 3.464$,

and p = internal pressure, $R_i =$ vessel inner radius, and t = vessel wall thickness.

G-2214.3 Radial Thermal Gradient:

The maximum K_t produced by a radial thermal gradient for the postulated inside surface defect of G-2120 is $K_{tt} = 0.953 \times 10^{-3} \times CR \times t^{2.5}$, where CR is the cooldown rate in F/hr., or, for a postulated inside surface defect, $K_{tt} = 0.753 \times 10^{-3} \times HU \times t^{2.5}$, where HU is the heatup rate in F/hr.

The through-wall temperature difference associated with the maximum thermal K_1 can be determined from Fig. G-2214-1. The temperature at any radial distance from the vessel surface can be determined from Fig. G-2214-2 for the maximum thermal K_1 .

- (a) The maximum thermal K_1 relationship and the relationship in Fig. G-2214-1 are applicable only for the conditions given in G-2214.3(a)(1) and (2).
- (b) Alternatively, the K₁ for radial thermal gradient can be calculated for any thermal stress distribution and at any specified time during cooldown for a 1/4-thickness inside surface defect using the relationship:

$$K_{ll} = (1.0359C_0 + 0.6322C_1 + 0.4753C_2 + 0.3855C_3) * \sqrt{\pi a}$$
(4)

or, similarly, K_{tt} during heatup for a 1/4-thickness outside surface defect using the relationship:

$$K_h = (1.043C_0 + 0.630C_1 + 0.481C_2 + 0.401C_3) * \sqrt{\pi a}$$
(5)

where the coefficients C_0 , C_1 , C_2 and C_3 are determined from the thermal stress distribution at any specified time during the heatup or cooldown using the form:

$$\sigma(x) = C_0 + C_1 (x/a) + C_2 (x/a)^2 + C_3 (x/a)^3$$
(6)

and x is a dummy variable that represents the radial distance from the appropriate (i.e., inside or outside) surface to any point on the crack front and a is the maximum crack depth.

Raju-Newman Methodology^[7]

The Raju-Newman method calculates the stress intensity factor K_1 for a given surface flaw using the actual stress profile through the wall (e.g., reactor vessel wall thickness). The stress is normal to the plane of the flaw at the flaw location and its distribution through the wall is represented by a third order polynomial:

$$\sigma(x) = \sum_{j=0}^{3} A_{j} x^{j} = A_{0} + A_{1}x + A_{2}x^{2} + A_{3}x^{3}$$
(7)

where,

- is the distance through the wall measured from the flawed surface,

A_j - coefficients of the third order polynomial fit,

 σ - stress normal to the plane of the flaw

The stress intensity factors are determined by:

х

$$K_{j} = \sqrt{\frac{\pi a}{Q}} \sum_{j=0}^{3} G_{j}(a/c, a/t, t/R, \phi) A_{j}a^{j}$$
(8)

where,

- a flaw depth, (e.g., 1/4 thickness of reactor vessel wall for P-T limit curves),
- a/c ratio of crack depth to 1/2 crack length (a: semi-minor axis, c: semi-major axis),
- a/t ratio of crack depth to thickness of cylinder,
- t/R ratio of thickness to inside radius,
- ϕ crack front location in degrees,
- Q is the square of the complete elliptic integral of the second kind and is approximated by $Q = 1 + 1.464(a/c)^{1.65}$,
- G_j influence coefficient corresponding to the jth stress distribution

The Raju-Newman method results in very similar values of stress intensity factor to those calculated by the revised Appendix G method described above, as demonstrated in Appendix A of this report.

Calculation of P-T Limit Curves

At any time during the heatup or cooldown transient, K_{Ia} is determined by the metal temperature at the tip of a postulated flaw at the 1/4T and 3/4T location, the appropriate value for RT_{NDP} and the reference fracture toughness curve. The thermal stresses resulting from the temperature gradients through the vessel wall are calculated and then the corresponding (thermal) stress intensity factors, K_{IP} for the reference flaw are computed. From Equation 2, the pressure stress intensity factors are obtained and, from these, the allowable pressures are calculated.

For the calculation of the allowable pressure versus coolant temperature during cooldown, the reference flaw of Appendix G to the ASME Code is assumed to exist at the inside of the vessel wall. During cooldown, the controlling location of the flaw is always at the inside of the wall because the thermal gradients produce tensile stresses at the inside, which increase with increasing cooldown rates. Allowable pressure-temperature relations are generated for both steady-state and finite cooldown rate situations. From these relations, composite limit curves are constructed for each cooldown rate of interest.

The use of the composite curve in the cooldown analysis is necessary because control of the cooldown procedure is based on the measurement of reactor coolant temperature, whereas the limiting pressure is actually dependent on the material temperature at the tip of the assumed flaw. During cooldown, the 1/4T vessel location is at a higher temperature than the fluid adjacent to the vessel inner diameter. This condition, of course, is not true for the steady-state situation. It follows that, at any given reactor coolant temperature, the ΔT (temperature) developed during cooldown results in a higher value of K_{1a} at the 1/4T location for finite cooldown rates than for steady-state operation. Furthermore, if conditions exist so that the increase in K_{1a} exceeds K_{1t}, the calculated allowable pressure during cooldown will be greater than the steady-state value.

The above procedures are needed because there is no direct control on temperature at the 1/4T location and, therefore, allowable pressures may unknowingly be violated if the rate of cooling is decreased at various intervals along a cooldown ramp. The use of the composite curve eliminates this problem and ensures conservative operation of the system for the entire cooldown period.

Three separate calculations are required to determine the limit curves for finite heatup rates. As is done in the cooldown analysis, allowable pressure-temperature relationships are developed for steady-state conditions as well as finite heatup rate conditions assuming the presence of a 1/4T defect at the inside of the wall. The heatup results in compressive stresses at the inside surface that alleviate the tensile stresses produced by internal pressure. The metal temperature at the crack tip lags the coolant temperature; therefore, the K_{Ia} for the 1/4T crack during heatup is lower than the K_{Ia} for the 1/4T crack during steady-state conditions may exist so that the effects of compressive thermal stresses and lower K_{Ia} values do not offset each other, and the pressure-temperature curve based on steady-state conditions no longer represents a lower bound of all similar curves for finite heatup rates when the 1/4T flaw is considered. Therefore, both cases have to be analyzed in order to ensure that at any

coolant temperature the lower value of the allowable pressure calculated for steady-state and finite heatup rates is obtained.

The second portion of the heatup analysis concerns the calculation of the pressure-temperature limitations for the case in which a 1/4T flaw located at the 1/4T location from the outside surface is assumed. Unlike the situation at the vessel inside surface, the thermal gradients established at the outside surface during heatup produce stresses which are tensile in nature and therefore tend to reinforce any pressure stresses present. These thermal stresses are dependent on both the rate of heatup and the time (or coolant temperature) along the heatup ramp. Since the thermal stresses at the outside are tensile and increase with increasing heatup rates, each heatup rate must be analyzed on an individual basis.

Following the generation of pressure-temperature curves for both the steady state and finite heatup rate situations, the final limit curves are produced by constructing a composite curve based on a point-by-point comparison of the steady-state and finite heatup rate data. At any given temperature, the allowable pressure is taken to be the lesser of the three values taken from the curves under consideration. The use of the composite curve is necessary to set conservative heatup limitations because it is possible for conditions to exist wherein, over the course of the heatup ramp, the controlling condition switches from the inside to the outside, and the pressure limit must at all times be based on analysis of the most critical criterion.

10 CFR Part 50, Appendix G addresses the metal temperature of the closure head flange and vessel flange regions. This rule states that the metal temperature of the closure flange regions must exceed the material unirradiated RT_{NDT} by at least 120°F for normal operation when the pressure exceeds 20 percent of the preservice hydrostatic test pressure (3107 psig), which is 621 psig for Indian Point Unit 2.

Table 1 indicates that the limiting unirradiated RT_{NDT} of 60°F occurs in the closure head and vessel flange of the Indian Point Unit 2 reactor vessel, so the minimum allowable temperature of this region is 180°F at pressures greater than 621 psig. This limit (where the horizontal line indicates that the pressure shall not exceed 621 psig for temperatures less than 180°F) is shown as a notch in the curves, presented wherever applicable in Figures 1 through 4.

SECTION 4.0

CALCULATION OF ADJUSTED REFERENCE TEMPERATURE

From Regulatory Guide 1.99, Revision 2, the adjusted reference temperature (ART) for each material in the beltline region is given by the following expression:

$$ART = Initial RT_{NDT} + \Delta RT_{NDT} + Margin$$
⁽⁹⁾

Initial RT_{NDT} is the reference temperature for the unirradiated material as defined in paragraph NB-2331 of Section III of the ASME Boiler and Pressure Vessel Code^[8]. If measured values of initial RT_{NDT} for the material in question are not available, generic mean values for that class of material may be used if there are sufficient test results to establish a mean and standard deviation for the class.

 ΔRT_{NDT} is the mean value of the adjustment in reference temperature caused by irradiation and should be calculated as follows:

$$\Delta RT_{NDT} = CF * f^{(0.28 - 0.10 \log f)}$$
(10)

To calculate ΔRT_{NDT} at any depth (e.g., at 1/4T or 3/4T), the following formula must first be used to attenuate the fluence at the specific depth.

$$f_{(depth x)} = f_{surface} * e^{(-0.24x)}$$
(11)

where x inches (vessel beltline thickness is 8.625 inches) is the depth into the vessel wall measured from the vessel clad/base metal interface. The resultant fluence is then placed in Equation 10 to calculate the ΔRT_{NDT} at the specific depth. The fluence (E > 1.0 MeV) values on the pressure vessel clad/base metal interface for the Indian Point Unit 2 reactor vessel are presented in Table 3.

TABLE 3

Fluence (10^{19} n/cm², E > 1.0 MeV) on the Pressure Vessel Clad/Base Metal

Interface for Indian Point Unit 2^[3]

EFPY	0°	15°	30°	45° (a)
21.63	0.4260	0.6716	0.6778	0.9809

NOTE:

(a) Maximum point on the pressure vessel.

Margin is calculated as, $M = 2 \sqrt[4]{\sigma_i^2 + \sigma_{\Delta}^2}$. The standard deviation for the initial RT_{NDT} margin term, σ_i , is 0°F when the initial RT_{NDT} is a measured value, and 17°F when a generic value is available. The standard deviation for the ΔRT_{NDT} margin term, σ_{Δ} , is 17°F for plates or forgings, and 8.5°F for plates or forgings (half the value) when surveillance data is used. For welds, σ_{Δ} is equal to 28°F when surveillance capsule data is not used, and is 14°F (half the value) when credible surveillance capsule data is used. σ_{Δ} need not exceed one-half the mean value of ΔRT_{NDT} .

All materials in the beltline region of Indian Point Unit 2 reactor vessel were considered in determining the limiting material. Sample calculations to determine the ART values for Intermediate Shell B2002-3 are shown in Table 4. The resulting ART values for all beltline materials at the 1/4T and 3/4T locations are summarized in Table 5. From Table 5, it can be seen that the limiting material is Intermediate Shell B2002-3. The 1/4T and 3/4T ART values for Intermediate Shell B2002-3 will be used in the generation of the heatup and cooldown curves.

TABLE 4

Calculation of ART Values for the Limiting Indian Point Unit 2 Reactor Vessel Material -- Intermediate Shell B2002-3

Parameter		
Operating Time	21.63	EFPY
Location	1/4T ART	3/4T ART
Chemistry Factor, CF (°F)	176 (183.02)	176 (183.02)
Fluence, f $(10^{19} \text{ n/cm}^2)^{(a,b)}$	0.5846	0.2077
Fluence Factor, FF	0.85	0.58
$\Delta RT_{NDT} = CF \times FF (^{\circ}F)$	149.6 (155.5)	101.8 (105.9)
Initial RT _{NDT} , I (°F)	21	21
Margin, M (°F)	34 (17)	34 (17)
Adjusted Reference Temperature (ART), (°F) per Regulatory Guide 1.99, Revision 2	204.6 (193.5)	156.8 (143.9)

NOTES:

(a) Fluence, f, is based upon f_{surf} (10¹⁹ n/cm², E > 1.0 MeV) the peak fluence presented in Table 3.

(b) The Indian Point Unit 2 reactor vessel wall thickness is 8.625 inches at the beltline region.

(c) Numbers in parenthesis () were calculated using surveillance capsule data.

TABLE 5

	21.63 EFPY ART (a)				
Material	1/4T ART (°F)	3/4T ART (°F)			
Intermediate Shell B2002-1	(144)	(114)			
Intermediate Shell B2002-2	(137)	(105)			
Intermediate Shell B2002-3	(194) ^(b)	(144) ^(b)			
Lower Shell B2003-1	183	142			
Lower Shell B2003-2	135	96			
Weld Metal	(189)	(125)			

Summary of ART Values at the 1/4T and 3/4T Locations

NOTES:

(a) Numbers within () are using chemistry factor based on surveillance capsule data.

(b) Adjusted reference temperature (ART) values used to generate heatup/cooldown curves.

(Note: When two or more credible surveillance data sets become available, the data sets may be used to determine ART values as described in Regulatory Guide 1.99, Revision 2, Position 2.1. If the ART values based on surveillance capsule data are larger than those calculated per Regulatory Guide 1.99, Revision 2, Position 1.1, the surveillance data should be used. If the surveillance capsule data gives lower values, either may be used.)

SECTION 5.0

HEATUP AND COOLDOWN PRESSURE-TEMPERATURE LIMIT CURVES

Pressure-temperature limit curves for normal heatup and cooldown of the primary reactor coolant system have been calculated for the pressure and temperature in the reactor vessel beltline region using the methods^[9] discussed in Section 3.0 and 4.0 of this report.

Figure 1 presents the heatup curves without margins for possible instrumentation errors using heatup rates up to 100°F/hr applicable for the first 21.63 EFPY. Figure 2 presents the cooldown curves without margins for possible instrumentation errors using cooldown rates up to 100°F/hr applicable for 21.63 EFPY. Allowable combinations of temperature and pressure for specific temperature change rates are below and to the right of the limit lines shown in Figures 1 through 4. This is in addition to other criteria which must be met before the reactor is made critical, as discussed below in the following paragraphs. The pressure difference between the wide-range pressure transmitter and the limiting beltline region must be accounted for when using the pressure-temperature limits presented in Figures 1 through 4.

The reactor must not be made critical until pressure-temperature combinations are to the right of the criticality limit line shown in Figures 1 and 3. The straight-line portion of the criticality limit is at the minimum permissible temperature for the 2485 psig inservice hydrostatic test as required by Appendix G to 10 CFR Part 50. The governing equation for the hydrostatic test is defined in Appendix G to Section XI of the ASME Code as follows:

$$1.5 K_{lm} < K_{la}$$
 (12)

where,

 K_{Im} is the stress intensity factor covered by membrane (pressure) stress, $K_{Ia} = 26.78 + 1.233 e^{[0.0145 (T - RTNDT + 160)]}$

T is the minimum permissible metal temperature, and

 RT_{NDT} is the metal reference nil-ductility temperature.

The criticality limit curve specifies pressure-temperature limits for core operation to provide additional margin during actual power production as specified in Reference 5. The pressure-temperature limits for core operation (except for low power physics tests) are that the reactor vessel must be at a temperature equal to or higher than the minimum temperature required for the inservice hydrostatic test, and at least 40°F higher than the minimum permissible temperature in the corresponding

pressure-temperature curve for heatup and cooldown calculated as described in Section 3.0 of this report. Using the new ASME Section XI, Appendix G methodology for the calculation of K_1 , the minimum temperatures for the inservice hydrostatic leak tests for the Indian Point Unit 2 reactor vessel at 21.63 EFPY is 318°F. Using the Raju-Newman methodology, the minimum temperatures for the inservice hydrostatic leak tests for the Indian Point Unit 2 reactor vessel at 21.63 EFPY is 327°F. The vertical line drawn from these points on the pressure-temperature curve, intersecting a curve 40°F higher than the pressure-temperature limit curve, constitutes the limit for core operation for the reactor vessel.

Figures 1 through 4 define all of the above limits for ensuring prevention of nonductile failure for the Indian Point Unit 2 reactor vessel.

The data points used for the heatup and cooldown pressure-temperature limit curves shown in Figures 1 through 4 are presented in Tables 6 and 7.

MATERIAL PROPERTY BASIS

LIMITING MATERIAL: INTERMEDIATE SHELL B2002-3 LIMITING ART VALUES AT 21.63 EFPY: 1/4T, 194°F 3/4T, 144°F



FIGURE 1 Indian Point Unit 2 Reactor Coolant System Heatup Limitations (Heatup Rates up to 100°F/hr) Applicable for the First 21.63 EFPY Using ASME Section XI, Appendix G Methodology (Without Margins for Instrumentation Errors) Includes vessel flange requirements of 180°F and 621 psig per 10CFR50, Appendix G.

MATERIAL PROPERTY BASIS

LIMITING MATERIAL: INTERMEDIATE SHELL B2002-3 LIMITING ART VALUES AT 21.63 EFPY: 1/4T, 194°F 3/4T, 144°F



FIGURE 2 Indian Point Unit 2 Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 100°F/hr) Applicable for the First 21.63 EFPY Using ASME Section XI, Appendix G Methodology (Without Margins for Instrumentation Errors) Includes vessel flange requirements of 180°F and 621 psig per 10CFR50, Appendix G.



TABLE 6

21.63 EFPY Heatup and Cooldown Curve Data Points Using Appendix G (without Margins for Instrumentation Errors)

$\begin{array}{c cccc} Cooldown Curves \\ Steady State 20F \\ T P T P T P \\ 60 522 60 472 \\ 65 525 65 475 \\ 70 527 70 477 \\ 75 530 75 480 \\ 80 533 80 483 \\ 85 536 85 487 \\ 90 540 90 490 \\ 95 544 95 494 \\ 100 548 100 498 \\ 105 552 105 503 \\ 110 557 110 507 \\ 115 562 115 513 \\ 120 567 120 518 \\ 125 573 125 524 \\ 130 580 130 531 \\ 135 586 135 538 \\ 140 594 140 545 \\ 145 601 145 554 \\ 155 611 145 554 \\ 155 619 155 572 \\ 160 621 160 582 \\ 155 619 155 572 \\ 160 621 160 582 \\ 155 619 155 572 \\ 160 621 165 593 \\ 170 621 170 605 \\ 175 621 175 618 \\ 180 621 180 621 \\ 180 675 180 632 \\ 185 689 185 646 \\ 190 704 190 662 \\ 195 720 195 680 \\ 200 738 200 698 \\ 205 756 205 718 \\ 210 76 210 739 \\ 215 798 215 762 \\ 220 821 220 787 \\ 225 846 225 814 \\ 230 873 230 843 \\ 235 901 235 874 \\ 240 932 240 907 \\ 245 966 245 943 \\ 255 1040 255 1023 \\ 260 1081 260 1067 \\ 265 1126 25 115 \\ 100 125 981 \\ 255 1040 255 1023 \\ 260 1081 260 1067 \\ 245 966 245 943 \\ 255 1040 255 1023 \\ 260 1081 260 1067 \\ 245 966 245 943 \\ 255 1040 255 1023 \\ 260 1081 260 1067 \\ 245 966 245 943 \\ 255 1040 255 1023 \\ 260 1081 260 1067 \\ 245 966 245 943 \\ 255 1040 255 1023 \\ 260 1081 260 1067 \\ 245 966 245 943 \\ 255 1040 255 1023 \\ 260 1081 260 1067 \\ 245 966 245 943 \\ 255 1040 255 1023 \\ 260 1081 260 1067 \\ 245 966 245 943 \\ 255 1040 255 1023 \\ 280 1280 \\ 285 1340 \\ 290 1404 \\ 295 1472 \\ 300 1546 \\ 305 1625 \\ 310 1711 \\ 315 1803 \\ 320 1901 \\ 325 2244 \\ 0 \end{array}$	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	$\begin{array}{ccccc} 100F \\ T & P \\ 60 & 263 \\ 70 & 265 \\ 75 & 268 \\ 80 & 271 \\ 85 & 275 \\ 90 & 279 \\ 95 & 283 \\ 100 & 288 \\ 105 & 293 \\ 110 & 299 \\ 115 & 305 \\ 120 & 312 \\ 125 & 319 \\ 130 & 327 \\ 135 & 336 \\ 140 & 345 \\ 145 & 355 \\ 150 & 367 \\ 155 & 379 \\ 160 & 392 \\ 165 & 406 \\ 170 & 422 \\ 175 & 438 \\ 180 & 456 \\ 185 & 476 \\ 190 & 497 \\ 195 & 520 \\ 200 & 545 \\ 205 & 572 \\ 210 & 600 \\ 215 & 632 \\ 220 & 665 \\ 225 & 702 \\ 230 & 741 \\ 235 & 788 \\ 260 & 1050 \\ 265 & 1117 \\ \end{array}$	Heatup Curves60FTP6049465494704947549480494904949049490494105495110498115501120505125511130517135524140532145541155562160574165587170602175617180621180634185652190671195692200715205739210765215793220821225846230873235901240932245966250100125510402601081265112627011742751225280128028513402901404295147230015463151781320186232519493302042	Crit. Limit T P 318 0 318 525 318 527 318 515 318 501 318 497 318 495 318 495 318 495 318 495 318 495 318 495 318 505 318 505 318 511 318 505 318 511 318 524 318 524 318 551 318 552 318 541 318 562 318 574 318 562 318 617 318 662 318 617 318 662 318 617 318 652 318 715 318 739 318 765 318 739 318 765 318 773 318 701 318 821 318 846 318 1001 318 1001 318 1001 318 1001 318 1001 318 1001 318 1126 318 1174 318 1174 31	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	Crit. Limit T P 318 0 318 525 318 511 318 497 318 484 318 474 318 469 318 454 318 454 318 450 318 445 318 450 318 453 318 506 318 576 318 594 318 658 318 658 318 658 318 101 335 1245 340 1314 345 1344 345 1344 345 1344 345 1467 355 1553 360 1645 365 1743 370 1849 375 1962	Leak Test Limit T P 297 2000 318 2485
325 2007 330 2121 335 2244 340 2376			325 1949 330 2042 335 2143 340 2250 345 2366	370 2042 375 2143 380 2250 385 2366	330 1849 335 1962 340 2084 345 2214 350 2354 355 2480	370 1849 375 1962 380 2084 385 2214 390 2354 395 2480	

MATERIAL PROPERTY BASIS

LIMITING MATERIAL: INTERMEDIATE SHELL B2002-3 LIMITING ART VALUES AT 21.63 EFPY: 1/4T, 194°F 3/4T, 144°F



FIGURE 3 Indian Point Unit 2 Reactor Coolant System Heatup Limitations (Heatup Rates up to 100°F/hr) Applicable for the First 21.63 EFPY Using the Raju-Newman Methodology (Without Margins for Instrumentation Errors) Includes Vessel flange requirements of 180°F and 621 psig per 10CFR50, Appendix G.

MATERIAL PROPERTY BASIS

LIMITING MATERIAL: INTERMEDIATE SHELL B2002-3 LIMITING ART VALUES AT 21.63 EFPY: 1/4T, 194°F 3/4T. 144°F



FIGURE 4 Indian Point Unit 2 Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 100°F/hr) Applicable for the First 21.63 EFPY Using the Raju-Newman Method (Without Margins for Instrumentation Errors) Includes vessel flange requirements of 180°F and 621 psig per 10CFR50, Appendix G.



TABLE 7

21.63 EFPY Heatup and Cooldown Curve Data Points Using Raju-Newman (without Margins for Instrumentation Errors)

Cooldown C Steady State T P 60 524 65 526 70 529 75 532 80 535 85 538 90 542 95 545 100 549 105 554 110 559 115 564 120 569 125 575 130 581 135 588 140 595 145 603 150 612 155 621 160 621 165 621 165 621 165 621 160 621 165 621 170 621 175 662 180 677 185 691 190 706 195 722 200 740 205 758 210 779 215 800 220 823 225 848 230 875 235 904 240 935 245 968 250 1004 255 1043 260 1084 265 1129 270 1177 275 1228 280 1284 260 1084 265 1129 270 1477 275 1228 280 1284 260 1084 265 1129 270 1477 275 1228 280 1284 260 1084 265 1129 270 1477 275 1228 280 1284 265 1343 290 1408 295 1476 305 1630 315 1808	Curves 20F T P 60 475 65 478 70 480 75 483 80 486 85 489 90 493 95 497 100 501 105 505 110 516 120 521 125 527 130 534 135 541 140 549 145 557 150 566 155 575 160 585 165 596 170 608 175 621 180 635 185 650 195 683 200 702 205 722 210 743 215 766 220 911	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	60F P 60 375 65 377 70 379 75 382 80 385 85 389 90 393 95 397 100 401 105 406 110 411 115 417 120 423 125 429 135 444 140 413 150 472 155 482 160 470 170 520 170 520 170 520 170 520 180 550 180 550 185 567 190 586 200 627 205 605 200 627 205 761 200 735 235 831 245 912 250 957	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	Heatup Curves $60F$ PTP604956549570495754958049585495904951054961104981155011205061255111305171355241405331455421505521555631606211806341856521956932007152057392107662157942208482308752459682501004255143260108426511292751228280128428013962951451300151030515733101641	Critical Limit T P 327 0 327 526 327 527 327 501 327 501 327 497 327 495 327 495 327 495 327 495 327 496 327 501 327 501 327 506 327 511 327 517 327 524 327 517 327 524 327 552 327 552 327 552 327 563 327 575 327 575 327 634 327 715 327 739 327 766 327 794 327 848 327 693 327 766 327 794 327 848 327 904 327 904 327 904 327 1043 327 1284 327 1343 330 1396	100F P 60 445 65 445 70 445 75 445 80 445 95 445 90 445 105 445 100 445 105 445 120 445 120 445 120 445 130 446 135 448 140 450 145 454 150 458 155 464 160 470 165 478 170 486 180 506 180 506 180 506 200 545 200 560 235 710 240 739 230 636 225 659 230 804 250 804	Critical. Limit T P 327 0 327 526 327 528 327 528 327 511 327 497 327 485 327 475 327 466 327 459 327 454 327 450 327 454 327 450 327 446 327 446 327 446 327 448 327 446 327 448 327 446 327 448 327 446 327 448 327 446 327 448 327 446 327 448 327 454 327 446 327 458 327 458 327 458 327 456 327 506 327 577 518 327 506 327 518 327 560 327 577 327 584 327 615 327 616 327 616 327 617 327 616 327 617 327 616 327 617 327 617 327 617 327 617 327 617 327 617 327 617 327 616 327 617 327 616 327 617 327 616 327 617 327 616 327	Leak Test Limit T P 305 2000 327 2485
290 1408 295 1476 300 1550 305 1630 310 1716 315 1808 320 1907 325 2013 330 2127 335 2250 340 2383					$\begin{array}{cccccccccccccccccccccccccccccccccccc$	335 1390 335 1451 340 1510 345 1573 350 1641 355 1714 360 1793 365 1877 370 1967 375 2064 380 2169 385 2280 390 2401	290 1181 295 1246 300 1315 305 1389 310 1469 315 1554 320 1646 325 1744 330 1850 335 1963 340 2075 345 2171 350 2275 355 2386	330 1181 335 1246 340 1315 345 1389 350 1469 355 1554 360 1646 365 1744 370 1850 375 1963 380 2075 385 2171 390 2275 395 2386	

SECTION 6.0

REFERENCES

- Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials", U.S. Nuclear Regulatory Commission, May, 1988.
- Fracture Toughness Requirements", Branch Technical Position MTEB 5-2, Chapter 5.3.2 in <u>Standard Review Plan</u> for the Review of Safety Analysis Reports for Nuclear Power Plants, LWR Edition, NUREG-0800, 1981.
- WCAP-12796, "Heatup and Cooldown Limit Curves for the Consolidated Edison Company Indian Point Unit 2 Reactor Vessel", N. K. Ray, January 1991.
- 4. SwRI Project No. 17-2018 (Revised), "Reactor Vessel Material Surveillance Program for Indian Point Unit No. 2 Analysis of Capsule V", March 1990.
- 5. 10 CFR 50, Appendix G, "Fracture Toughness Requirements", Federal Register, Volume 60, No. 243, dated December 19, 1995.
- 6. ASME Boiler and Pressure Vessel Code, Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components", Appendix G, "Fracture Toughness Criteria for Protection Against Failure", 1996 Addendum (to be published in December 1996).
- I. S. Raju and J. C. Newman, Jr., "Stress Intensity Factor Influence Coefficients for Internal and External Surface Cracks in Cylindrical vessels", in <u>Aspect of Fracture Mechanics in Pressure</u> <u>Vessels and Piping</u>, ed. S. S. Palusamy and S. G. Sampath, PVP-Volume 58, ASME 1982.
- 1989 Section III, Division 1 of the ASME Boiler and Pressure Vessel Code, Paragraph NB-2331, "Material for Vessels".
- 9. WCAP-14040-NP-A, Revision 2, "Methodology Used to Develop Cold Overpressure Mitigating System Setpoints and RCS Heatup and Cooldown Limit Curves", J. D. Andrachek, January 1996.



APPENDIX A

TABULATION OF PRESSURE AND K₁ VALUES FOR THE NEW APPENDIX G AND RAJU-NEWMAN METHODOLOGIES

Coold	lown Curves									Heatup	Curves				
	Steady	State	20F		40F		60F		100F			60F		100F	
	App. G	Raju- New.	App. G	Raju- New.	App. G	Raju- New.	App. G	Raju- New.	App. G	Raju- New.		App. G	Raju- New.	App. G	Raju- New.
	Р	Р	P	Р	P	Р	Р	Р	Р	Р	Т	Р	Р	P	Р
60	522	524	472	475	421	425	369	375	261	269	60	494	495	445	445
100	548	549	498	501	447	452	395	401	288	296	100	494	495	445	445
150	610	612	562	566	514	519	466	472	367	376	150	551	552	458	458
200	738	740	698	702	659	664	620	627	545	555	200	715	715	560	560
250	1001	1004	981	986	964	970	949	957	931	943	250	1001	1004	803	804
265	1126	1129	1115	1120	1109	1115	1106	1114	1117	1129	300	1546	1510	1314	1315
270	1174	1177	1167	1172	1164	1171	1167	1175			340	2250	2169	2084	2075
275	1225	1228	1222	1228											
300	1546	1550													
340	2376	2383													

 TABLE A-1

 Comparison Between ASME Appendix G and Raju-Newman P-T Limit Curves at Select Temperatures

Cooldown	Water Temp.	ASME A	Appendix G	Raju-Newman		
	(Г)	1/4T K _{rr}	1/4T K _{IP}	1/4T K _{IT}	1/4T K _{IP}	
Steady State	60	0	14.2798	0	14.2798	
	100	0	14.9800	0	14.9800	
	150	0	16.6734	0	16.6734	
	200	0	20.1686	0	20.1686	
	250	0	27.3828	0	27.3828	
	300	0	42.2728	0	42.2728	
20°F/Hr.	60	2.85144	12.9168	2.77403	12.9555	
Cooldown	100	2.95196	13.6192	2.87182	13.6592	
	150	3.08146	15.3788	2.99780	15.4206	
	200	3.21394	19.0875	3.12668	19.1312	
	250	3.34944	26.8313	3.25851	. 26.8767	
	300	3.48802	42.9268	3.39333	42.9742	
40°F/Hr.	60	5.77743	11.5223	5.62053	11.6007	
Cooldown	100	5.98498	12.2287	5.82244	12.3100	
	150	6.24883	14.0654	6.07912	14.1502	
	200	6.51887	18.0142	6.34182	18.1027	
	250	6.79517	26.3488	6.61061	26.4411	
	300	7.07775	43.7879	6.88552	43.8840	
60°F/Hr.	60	8.78722	10.0923	8.54850	10.2117	
Cooldown	100	9.10406	10.8075	8.85672	10.9312	
	150	9.50754	12.7334	9.24924	12.8626	
	200	9.92051	16.9525	9.65098	17.0873	
	250	10.3423	25.9481	10.0613	26.0886	
	300	10.7694	44.8866	10.4768	45.0329	
100°F/Hr.	60	15.0711	7.1231	14.6614	7.3279	
cooldown	100	15.6173	7.8706	15.1927	8.0829	
	150	16.3089	10.0224	15.8655	10.2441	
	200	17.0021	14.8963	16.5398	15.1274	
	250	17.6708	25.4627	17.1904	25.7029	
	300	18.2502	47.8686	17.7541	48.1167	

TABLE A-2 ASME Appendix G Versus Raju-Newman Stress Intensity Factor Values Steady State and Cooldown Curves



•	
TABLE A-3	
INDEE A-5	
ASME Appendix G Versus Raju-Newman Stress Intens	ty Factor Values

Heatup Curves

Cooldown Rate	Water Temp.	ASME Appendix G			Raju-Newman				
	(1)	К _{іт} @ 1/4Т	К _{іт} @ 3/4T	К _{іР} @ 1/4Т	K _{IP} @ 3/4T	К _{іт} @ 1/4Т	К _{іт} @ 3/4Т	К _{ір} @ 1/4T	К _{ір} @ 3/4T
60 °F/Hr. Heatup	60	-1.0968	0.5960	14.7831	14.8049	-1.0429	0.5965	14.7562	14.8046
	100 .	-7.0929	5.3230	18.2750	13.0365	-6.7917	5.3211	18.1243	13.0375
	150	-8.6781	6.5715	20.4071	14.5381	-8.3111	6.5691	20.2236	14.5393
	200	-9.2249	6.9920	23.4742	18.8425	-8.8349	6.9895	23.2792	18.8438
	250	-9.6338	7.3025	29.4169	27.9174	-9.2266	7.2998	29.2133	27.9188
`	300	-10.0291	7.6018	41.3759	46.5448	-9.6052	7.5990	41.1639	46.5462
	340	-10.3484	7.8434	59.3419	74.6521	-9.9110	7.8406	59.1231	74.6535
100 °F/Hr. Heatup	60	-0.9954	0.4731	14.7272	14.8642 ·	-0.9439	0.4740	14.7014	14.8637
	100	-9.1226	6.7187	19.2114	12.1035	-8.7316	6.7165	19.0160	12.1046
	150	-12.9964	9.7812	22.2943	12.0742	-12.4451	9.7777	22.0187	12.0760
	200	-14.5894	11.0256	25.4989	14.7555	-13.9718	11.0216	25.1901	14.7575
	250	-15.5151	11.7373	30.9113	21.1851	-14.8586	11.7331	30.5830	21.1872
	300	-16.2447	12.2924	41.3927	34.6435	-15.5575	12.2880	41.0491	34.6457
	340	-16.7870	12.7030	56.9262	54.9433	-16.0768	12.6985	56.5712	54.9456

:

•••

APPENDIX B

SUMMARY OF VESSEL AND MATERIAL PROPERTIES USED IN THE GENERATION OF THE HEATUP/COOLDOWN CURVES

Pressure vessel inner radius = 86.719 inches Pressure vessel outer radius = 95.344 inches Beltline region wall thickness = 8.625 inches Limiting temperature for vessel flange = 180°F Limiting pressure for vessel flange = 621 psig

ATTACHMENT IV

ASME PROPOSED CHANGES TO SECTION XI APPENDIX G

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC. INDIAN POINT UNIT NO. 2 DOCKET NO. 50-247 OCTOBER, 1996

SEP 27 '96 15:19 FR WEC	412 374 6337 TO 819147378364 P.	P.01/15	
xel plan 1968-16[(hib) * xed	(Revised	R. 4/30/96	
sough the west		· · · · ·	
mound man burger (1) + 4 er			
C) < segred to * 1707 omem listimenent xet brief "filterog	ISI	94-40	

Proposed Revision to Appendix G Stress Intensity Factors

Appendix G is being revised to incorporate the most recent elastic solutions for K₁ due to pressure and redial thermal gradients. The new solutions are based on finite element analyses for inside surface flaws parformed at Oak Ridge National Laboratories and sponsored by NRC 1, and work published by EPRI for outside surface flaws 2. These solutions provide results that are essentially the same as those obtained by using solutions previously developed by Raju and Newman 3.

The proposed Section XI, Appendix G code change is atteched. Also included are the results from sample problems to calculate the allowable pressure temperature limits using the new method. for comparison with the current Appendix G approach.

This revision now provides consistent computation methods for pressure and thermal K_1 , and provides a method to compute thermal K_1 for any thermal gradient through the vessel wall at any time during the transient. Consistent with the original version of Appendix G no contribution for crack face pressure is included in the K_1 due to pressure, and dadding effects are neglected.

These new solutions are elastic solutions that do not include the plastic zone size correction in the current Code solutions for pressure stress. These new solutions better characterize the conditions for irradiated vessels in the low temperature region where the thermal stresses and silowable pressure are low. For these conditions the plastic zone size is negligible, and the elastic solutions are the technically correct solutions. Plastic zone size corrections and other high stress considerations are no longer used in Appendix G generally because applications where plastic conditions may be important for integrity evaluations are now addressed in other code appendices (e.g., uppar shelf toughness in Appendix K).

Using these most recent elastic solutions in the low temperature region will provide some relief to restrictions associated with reactor operation at relatively low temperature. Although the relief is relatively small in terms of absolute allowable pressure, the benefits are substantial because even a small increase in the allowable pressure can be a algolificant percentage increase in the operating window at relatively low temperatures. Implementing this revision results in an economic and potential safety benefit (less likelihood of lifting LTOP pressure relieving devices) with no reduction in vassel integrity.

- 1. J. A. Keeney and T. L. Dickson, "Stress-Intensity-Factor Influence Coefficients for Axially Oriented Semielliptical Inner-Surface Flaws in Clad Pressure Vessels (R/t=10)". ORNL/NRC/LTR-93/33, Revision 1, September 30, 1995.
- 2. Zehoor, A. <u>Ductile Fracture Handbook. Volume 3</u>, published jointly by EPRI, NP-6301-D and Novetech, N14-3, January, 1991.
- 3. I.S. Raju and J.C. Newman, Jr., " Stress Intensity Factors for Internal and External Surface Cracks in Cylindrical Vessels," Journal of Pressure Vessel Technology, Vol. 104, pp 283-298, November 1882.

ARTICLE G-1000 INTRODUCTION

This Appendix presents a procedure for obtaining the allowable loadings for ferritic pressure retaining materials in components. This procedure is based on the principles of linear elastic fracture mechanics. At each location being investigated a maximum postulated flaw is assumed. At the same location the *mode l stress intensity factor*¹ K, is produced by each of the specified loadings as calculated and the summation of the K₁ values is compared to a reference value K₁, which is the highest critical value of K, that can be ensured for the material and temperature involved. Different procedures are recommended for different components and operating conditions.

'The stress intensity factor as used in fracture incohanics has no relation to and must not be confused with the stress intensity used in Section III. Division 1. Furthermore, stresses referred to in this Appendix are calculated normal tensile stresses not stress intensities in a defect free stress model at the surface nearest the location of the assumed defect.

ARTICLE G-2000 VESSELS

G-2100 GENERAL REQUIREMENTS

G-2110 REFERENCE CRITICAL STRESS INTENSITY FACTOR

(a) Figure G-2210-1 is a curve showing the relationship that can be conservatively expected between the critical, or reference, stress intensity factor K_{Ia} , ksi $\sqrt{1n}$, and a temperature which is related to the reference nil-ductility temperature RT_{NDT} determined in NB-2331. This curve is based on the lower bound of static, dynamic, and crack arrest critical K_I values measured as a function of temperature on specimens of SA-533 Grade B Class 1, and SA-508-1. SA-508-2, and SA-508-3 steel. No available data points for static, dynamic, or arrest tests fall below the curve. An analytical approximation to the curve is:

 $K_{Io} = 26.78 + 1.233 \exp[0.0145(T - RT_{NDT} + 160)]$

Unless higher K_{le} values can be justified for the particular material and circumstances being considered, Fig. G-2210-1 may be used for ferritic steels which meet the requirements of NB-2331 and which have a specified minimum yield strength at room temperature of 50.0 ksi or less.

(b) For materials which have specified minimum yield strengths at room temperature greater than 50.0 ksi but not exceeding 90.0 ksi, Fig. G-2210-1 may be used provided fracture mechanics data (similar to the K_{10} data referenced in WRCB 175) are obtained on at least three heats of the material on a sufficient number of specimens to cover the temperature range of interest, including the weld metal and heat-affected zone, and provided that the data are equal to or above the curve of Fig. G-2210-1. These data shall be documented by the Owner. Where these materials of higher yield strengths (specified minimum yield strength greater than 50.0 ksi but not exceeding 90.0 ksi) are to be used in conditions where radiation may affect the material properties, the effect of radiation on the K_{10} curve

shall be determined for the material. This information shall be documented by the Owner.

G-2120 MAXIMUM POSTULATED DEFECT

The postulated defect used in this recommended procedure is a sharp, surface defect normal to the direction of maximum stress. For section thicknesses of 4 in. to 12 in., it has a depth of one-fourth of the section thickness and a length of $1\frac{1}{2}$ times the section thickness. Insert (1) For sections greater than 12 in. thick, the postulated defect for the 12 in. section is used. For sections less than 4 in. thick, the 1 in. deep defect is conservatively postulated These postulated effects of thickness were used in developing the curves of Fig. G-2214-1. Smaller defect sizes' may be used on an individual case basis if a smaller size of maximum postulated defect can be ensured. Due to the safety factors recommended here, the prevention of nonductile fracture is ensured for some of the most important situations even if the defects were to be about twice as large in linear dimensions as this postulated maximum defect.

G-2200 LEVEL A AND LEVEL B SERVICE LIMITS

G-2210 SHELLS AND HEADS REMOTE FROM DISCONTINUITIES

G-2211 Recommendations

The assumptions of this Subarticle are recommended for shell and head regions during Level A and B Service Limits.

WRCB 175 (Welding Research Council Bulletin 175) "PVRC Recommendations on Toughness Requirements for Ferritic Materials" provides procedures in Paragraph S(c)(2) for considering maximum postulated defects smaller than those described.

P.04/15

Revised 4/30/96 (CHANGES ARE CIRCLED)

INSERT 1

Defects are postulated at both the inside and outside surfaces.

INSERT 2

 (pR_i/t) , where M_m for an inside surface flaw is given by $M_m = \underbrace{1.85}_{0.926}$ for $\sqrt{t} < 2$, $M_m = \underbrace{0.926}_{0.926} \sqrt{t}$ for $2 \le \sqrt{t} \le 3.464$, $M_m = \underbrace{3.21}_{0.926}$ for $\sqrt{t} > 3.464$.

Similarly, M_m for an outside surface flaw is given by $M_m = \underbrace{1.27}_{\text{for }} \sqrt{t} < 2,$ $M_m = \underbrace{0.893}_{\text{m}} \sqrt{t}$ for $2 \le \sqrt{t} \le 3.464,$ $M_m = \underbrace{3.09}_{\text{for }} \sqrt{t} > 3.464,$

where p = internal pressure (ksi), $R_i = vessel inner radius (in.)$, t = vessel wall thickness (in.).

INSERT 3

The maximum K_1 produced by a radial thermal gradient for the postulated inside surface defect of G-2120 is $K_{1t} = 0.953 \times 10^{-3} \times CR \times t^{2.5}$, where CR is the cooldown rate in F/hr., or, for a postulated outside surface defect, $K_{1t} = 0.753 \times 10^{-3} \times HU \times t^{2.5}$, where HU is the heatup rate in F/hr.

The through-wall temperature difference associated with the maximum thermal K_I can be determined from Fig. G-2214-1. The temperature at any radial distance from the vessel surface can be determined from Fig. G-2214-2 for the maximum thermal K_I .

(a) The maximum thermal K_1 and the temperature relationship in Fig. G-2214-1 are applicable only for the conditions in G-2214.3 (a)(1) and (2).

INSERT 4

(b) Alternatively, the K_I for radial thermal gradient can be calculated for any thermal stress distribution at any specified time during cooldown for a 1/4-thickness surface defect.

For an inside surface defect during cooldown

 $K_{tr} = (1.0359C_0 + 0.6322C_1 + 0.4753C_2 + 0.3855C_3) \bullet \sqrt{\pi a}$



412 374 6337 TO 819147378364

P.05/15

Revised 4/30/96

(CHANGES ARE CIRCLED)

For an outside surface defect during heatup

$$K_{1t} = (1.043C_0 + 0.630C_1 + 0.481C_2 + 0.401C_3) \bullet \sqrt{\pi a}$$

The coefficients C_0 , C_1 , C_2 , and C_3 are determined from the thermal stress distribution at any specified time during the heatup or cooldown using

$$\sigma (x) = C_0 + C_1 (x/a) + C_2 (x/a)^2 + C_3 (x/a)^3$$

where x is a dummy variable that represents the radial distance, (in.), from the appropriate (i.e., inside or outside) surface and a is the maximum crack depth, (in.).

(c) For the startup condition, the allowable pressure vs. temperature relationship is the minimum pressure at any temperature, determined from (1) the calculated steady state results for the 1/4-thickness inside surface defect, (2) the calculated steady state results for the 1/4-thickness outside surface defect, and (3) the calculated results for the maximum allowable heatup rate using a 1/4-thickness outside surface defect.







G-2211



G-2214.3

replace

with





Material Fracture Toughness G-2212

G-2212.1 Reference Critical Stress Intensity Factor for Material. The K_{le} values of Fig. G-2210-1 are recommended.

G-2212.2 Irradiation Effects. Subarticle A-4400 of Appendix A is recommended to define the change in reference critical stress intensity factor due to irradiation.

Maximum Postulated Defect G-2213

The recommended maximum postulated defect is that described in G-2120.

Calculated Stress Intensity Factors G-2214

G-2214.1 Membrane Tension. The K, corresponding to membrane tension for the postulated defect of G-2120 is Kim = M X membrane stress where M is sections in Sig_G22141. - replace Lith Insert 2

G-2214.2 Bending Stress. The K, corresponding to

bending stress for the postulated defect of G-2120 is $K_{lb} = M_b \times$ maximum bending stress, where M_b is twothirds of the M_m chown in Fig. G 2214 I.

G-2214.3 Radial Thermal Gradient. The A, proge suced by a radial thermal gradient across a wall thick these for the postulated defect of $G \gtrsim 120$ is K = MInsert ? × remperature difference brough the Wall. °F. where M, is as shown in Fig. G-2214-2.

(a) The M, values in Fig. 0-2214-2 are applicable the conditions given in G-2214.3(a) and only for`

(1) An assumed shape of the temperature gradient is approximately as shown in Fig. G-2214 X - Z.

(2) The temperature change starts from a steady state condition and has a rate, associated with startup and shutdown, less than about 100°F/hr. The results would be overly conservative if applied to rapid temperature changes.

(b) If the conditions of G-221 3(2) are got met. wher means must be used for calculating the K prosuced by thermal stress. Fox example, the moment are fuced by the radia thermal evadient may be calculated

replace with Insert 4

44]

P.07/15



and the equivalent linear success (NB 2212.13(a)(3)] considered by the provisions of G-2214.2.

G-2214.4 Stresses Exceeding Material Yield Strength WRCB 175 provides procedures in Paraeraph 5C(3) for considering elastically calculated stresses which exceed the yield strength of the material. This method may be used in lieu of using Figs. G-2214-1 G-2214-2 and G-2214-3, which are not ap plicable for combined stresses above the material yield trength.

G-2215 Allowable Pressure

The equations given in this Subarticle provide the basis for determination of the allowable pressure at any

temperature at the depth of the postulated defect during Service Conditions for which Level A and Level B Service Limits are specified. In addition to the conservatism of these assumptions, it is recommended that a factor of 2 be applied to the calculated K, values produced by primary stresses. In shell and head regions remote from discontinuities, the only significant loadings are: (1) general primary membrane stress due to pressure; and (2) thermal stress due to thermal gradient through the thickness during startup and shutdown. Therefore, the requirement to be satisfied and from which the allowable pressure for any assumed rate of temperature change can be determined is:

$$2K_{in} + K_{ii} < K_{in} \tag{1}$$

APPENDIX G - NONMANDATORY

Fig. G-2214-2



FIG. G-2214

443.

Revised 4/30/96 (CHANCES ARE CIRCLED)



throughout the life of the component at each temperature with K_{lm} from G-2214.1, K_{ll} from G-2214.2, and K_{lm} from Fig. G-2210-1.

G-2220 NOZZLES, FLANGES, AND SHELL REGIONS NEAR GEOMETRIC DISCONTINUITIES

G-2221 General Requirements

The same general procedure as was used for the shell and head regions in G-2210 may be used for areas where more complicated stress distributions occur, but certain modifications of the procedures for determining allowable applied loads shall be followed in order to meet special situations, as stipulated in G-2222 and G-2223.

G-2222 Consideration of Membrane and Bending Stresses

(a) Equation (1) of G-2215 requires modification to include the bending stresses which may be important contributors to the calculated K_i value at a point near a flange or nozzle. The terms whose sum must be $< K_{ia}$ for normal and upset operating conditions are:

(1) $2K_{lm}$ from G-2214.1 for primary membrane stress:

(2) 2K_{1b} from G-2214.2 for primary bending stress;

(3) K_{im} from G-2214.1 for secondary membrane stress;

(4) K_{lb} from G-2214.2 for secondary bending stress.

(b) For purposes of this evaluation, stresses which result from bolt preloading shall be considered as primary.

(c) It is recommended that when the flange and adjacent shell region are stressed by the full intended bolt preload and by pressure not exceeding 20% of the preoperational system hydrostatic test pressure, minimum metal temperature in the stressed region should be at least the initial RT_{NDT} temperature for the material in the stressed regions plus any effects of irradiation at the stressed regions.

(d) Thermal stresses shall be considered as secondary except as provided in NB-3213-13(b). The K, of Fig. G-2214-2 is ant-recommended for the evaluation. of thermal stress because more complicated stress distributions are not adequately represented by the simplified approach of Fig. G-2214-2.

G-2223 Toughness Requirements for Nozzles

(a) A quantitative evaluation of the fracture toughness requirements for nozzles is not feasible at this

G-2222

APPENDIX G - NONMANDATORY

(3) K_{im} from G-2214.1 for secondary membrane stress;

(4) K_{Ib} from G-2214.2 for secondary bending stress.

(b) For purposes of this evaluation, stresses which result from bolt preloading shall be considered as primary.

(c) It is recommended that when the flange and adjacent shell region are stressed by the full intended bolt preload and by pressure not exceeding 20% of the preoperational system hydrostatic test pressure, minimum metal temperature in the stressed region should be at least the initial RT_{NOT} temperature for the material in the stressed regions plus any effects of irradiation at the stressed regions. G-2214-1

(d) Thermal stresses shall be considered as secondary except as provided in NB-3213.13(b). The K_1 of Fig. G-2214-2 is not recommended for the evaluation of thermal stress because more complicated stress distributions are not adequately represented by the simplified approach of Fig. G-2214-2 G-2214-1.

G-2223 Toughness Requirements for Nozzles

444.1

(a) A quantitative evaluation of the fracture toughness requirements for nozzles is not feasible at this

G-2223

SEP 27 '96 15:23 FR WEC

This page removed and replaced

INSERT 1

Defects are postulated at both the inside and outside surfaces.

INSERT 2

1.85

 (pR_i/t) , where M_m for an inside surface flaw is given by $M_m = (1.84 \text{ for } \sqrt{t} < 2, ----0.926$ $M_m = (1.918) \frac{1}{25} \sqrt{t} \sqrt{t} < 3.464$

$$M_{m} = \frac{3.18}{3.21} \text{ for } \sqrt{t} > 3.464. \qquad 1.77 \qquad 0.89$$

Similarly, M_m for an outside surface flaw is given by $M_m = 1.6870$ $\sqrt{t} < 2$, $M_m = 0.839$ \sqrt{t} for $2 \le \sqrt{t} \le 3.464$, $M_m = 2.921$ or $\sqrt{t} > 3.464$, $M_m = 3.09$

where p = internal pressure (ksi), $R_i = vessel inner radius (in.), t = vessel wall thickness (in.).$

INSERT 3

The maximum K_I produced by a radial thermal gradient for the postulated inside surface defect of G-2120 is $K_{It} = 0.953 \times 10^{-3} \times CR \times t^{2.5}$, where CR is the cooldown rate in F/hr., or, for a postulated outside surface defect, $K_{It} = 0.781 \times 10^{-3} \times HU \times t^{2.5}$, where HU is the heatup rate in F/hr.

The through-wall temperature difference associated with the maximum thermal K_I can be determined from Fig. G-2214-1. The temperature at any radial distance from the vessel surface can be determined from Fig. G-2214-2 for the maximum thermal K_I .

(a) The maximum thermal K_1 and the temperature relationship in Fig. G-2214-1 are applicable only for the conditions in G-2214.3 (a)(1) and (2).

INSERT 4

(b) Alternatively, the K_1 for radial thermal gradient can be calculated for any thermal stress distribution at any specified time during cooldown for a 1/4-thickness surface defect.

For an inside surface defect during cooldown

 $K_{it} = (1.0359C_0 + 0.6322C_1 + 0.4753C_2 + 0.3855C_3) \bullet \sqrt{\pi a}$



, 0.753

SEP 27 '96 15:22 FR WEC

412 374 6337 TO 819147378364

G-2223

APPENDIX G - NONMANDATORY

445

G-2400

time, but preliminary data indicate that the design defect size for nozzles, considering the combined effects of internal pressure, external loading and thermal stresses, may be a fraction of that postulated for the vessel shell. Nondestructive examination methods shall be sufficiently reliable and sensitive to detect these smaller defects.

(b) WRCB 175 provides an approximate method in Paragraph SC(2) for analyzing the inside corner of a nozzle and cylindrical shell for elastic stresses due to internal pressure stress.

(c) Fracture toughness analysis to demonstrate protection against nonductile failure is not required for portions of nozzles and appurtenances having a thickness of 2.5 in. or less, provided the lowest service temperature is not lower than RT_{NOT} plus 60°F.

G-2300 LEVEL C AND LEVEL D SERVICE LIMITS

G-2310 RECOMMENDATIONS

The possible combinations of loadings, defect sizes, and material properties which may be encountered during Level C and Level D Service Limits are too diverse to allow the application of definitive rules, and it is recommended that each situation be studied on an individual case basis. The principles given in this Appendix may be applied, where applicable, with any postulated loadings, defect sizes, and material toughness which can be justified for the situation involved.

G-2400 HYDROSTATIC TEST TEMPERATURE

(a) For system and component hydrostetic tests performed prior to loading fuel in the reactor vessel, it is recommended that hydrostatic tests be performed at a temperature not lower than RT_{NDT} plus 60°F. The 60°F margin is intended to provide protection against nonductile failure at the test pressure.

(b) For system and component hydrostatic tests performed subsequent to loading fuel in the reactor vessel, the minimum test temperature should be determined by evaluating K_i . The terms given in (1) through (4) below should be summed in determining K_i :

(1) 1.5K₁, from G-2214.1 for primary membrane stress:

(2) 1.5K₁₀ from G-2214.2 for primary bending stress;

(3) K_{Im} from G-2214.1 for secondary membrane stress;

(4) K_{1b} from G-2214.2 for secondary bending stress.

 K_{I} , calculated by summing the four values given in (1) through (4) above, shall not exceed the applicable K_{Ia} value.

(c) The system hydrostatic test to satisfy G-2400(a) or (b) should be performed at a temperature not lower than the highest required temperature for any component in the system.

This page removed and replaced

For an outside surface defect during heatup ____ 1.043

$$K_{\rm lt} = (1.079)_0 + 0.630C_1 + 0.481C_2 + 0.401C_3) \bullet \sqrt{\pi a}$$

The coefficients C_0 , C_1 , C_2 , and C_3 are determined from the thermal stress distribution at any specified time during the heatup or cooldown using

 $\sigma(x) = C_0 + C_1 (x/a) + C_2 (x/a)^2 + C_3 (x/a)^3$

where x is a dummy variable that represents the radial distance, (in.), from the appropriate (i.e., inside or outside) surface and a is the maximum crack depth, (in.).

(c) For the startup condition, the allowable pressure vs. temperature relationship is the minimum pressure at any temperature, determined from (1) the calculated steady state results for the 1/4-thickness inside surface defect, (2) the calculated steady state results for the 1/4-thickness outside surface defect, and (3) the calculated results for the maximum allowable heatup rate using a 1/4-thickness outside surface defect.





This Da





throughout the life of the component at each temperature with $K_{I_{m}}$ from G-2214.1, $K_{I_{n}}$ from G-2214.2, and $K_{I_{n}}$ from Fig. G-2210-1.

Those plants having low temperature overpressure protection (LTOP) systems can use the following load and temperature conditions to provide protection against failure during reactor start-up and shutdown operation due to low temperature overpressure events that have been classified as Service Levels A or B events. LTOP systems shall be effective at coolant temperatures less than 200°F or at coolant temperatures corresponding to a reactor vessel metal temperature less than $RT_{NOT} + 50°F$, whichever is greater.²³ LTOP systems shall limit the maximum pressure in the vessel to 110% of the pressure determined to satisfy Eq. (1).

A93 93

The coolant temperature is the reactor coolant inlet temperature.

The vessel metal temperature is the temperature at a distance one fourth of the vessel section thickness from the inside wetted surface in the vessel beltline region. RT_{our} is the highest adjusted reference temperature (for weld or base metal in the beltline region) at a distance one fourth of the vessel section thickness from the vessel wetted inner surface as determined by Regulatory Guide 1.99, Rev. 2.

G-2220 NOZZLES, FLANGES, AND SHELL REGIONS NEAR GEOMETRIC DISCONTINUITIES

G-2221 General Requirements

The same general procedure as was used for the shell and head regions in G-2210 may be used for areas where more complicated stress distributions occur, but certain modifications of the procedures for determining allowable applied loads shall be followed in order to meet special situations, as stipulated in G-2222 and G-2223.

G-2222 Consideration of Membrane and Bending Stresses

(a) Equation (1) of G-2215 requires modification to include the bending stresses which may be important contributors to the calculated K_i value at a point near a flange or nozzle. The terms whose sum must be $< K_{I_P}$ for normal and upset operating conditions are:

(1) 2K₁ from G-2214.1 for primary membrane stress;

(2) $2K_{ib}$ from G-2214.2 for primary bending stress;

his

G-2223

page removed and replaced

G-2214.34

G-2222

APPENDIX G - NONMANDATORY

(3) K_{in} from G-2214.1 for secondary membrane stress:

(4) K_{ie} from G-2214.2 for secondary bending stress.

(b) For purposes of this evaluation. stresses which result from bolt preloading shall be considered as primary.

(c) It is recommended that when the flange and adjacent shell region are stressed by the full intended bolt preload and by pressure not exceeding 20% of the preoperational system hydrostatic test pressure, minimum metal temperature in the stressed region should be at least the initial RT_{NDT} temperature for the material in the stressed regions plus any effects of irradiation at the stressed regions.

(d) Thermal success shall be considered as secondary except as provided in NB-3212:13(b). The K, of Fig. G 2214-2 is not recommended for the evaluation of thermal stress, because more complicated stress distributions are not adequately represented by the simplified approach of Fig. G-2214-2.

G-2223 Toughness Requirements for Nozzles

(a) A quantitative evaluation of the fracture toughness requirements for nozzles is not feasible at this

restore to original wording

ATTACHMENT V

CALCULATIONS OF STRESS INTENSITY FACTORS

χ.

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC. INDIAN POINT UNIT NO. 2 DOCKET NO. 50-247 OCTOBER, 1996

.