

123 Main Street  
White Plains, New York 10601  
914 681.6846



October 7, 1993  
IPN-93-119

**Ralph E. Beedle**  
Executive Vice President  
Nuclear Generation

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

Subject: **Indian Point 3 Nuclear Power Plant**  
**Docket No. 50-286**  
**Supplement to Proposed Changes to Technical**  
**Specifications Regarding Extending Engineered Safety Features**  
**Systems Testing to Accommodate a 24 Month Operating Cycle**

Reference: NYPA letter, R.E. Beedle to the NRC Document Control Desk, dated  
May 21, 1993 (IPN-93-040).

Dear Sir:

The Authority recently proposed changing the frequency of engineered safety features systems testing to accommodate a 24 month operating cycle (see Reference). The safety evaluation that accompanied the proposed changes included a commitment to test the time delay relays (Agastats) associated with the engineered safety features at intervals no greater than 22.5 months (18 months + 25%). Based on discussions held with our NRC Project Manager, the Authority is transmitting the attached Technical Specification pages 4.5-1 and 4.6-1, to be used in place of pages 4.5-1 and 4.6-1 that were submitted with the referenced letter. These new pages incorporate the Authority's commitment regarding the time delay relay test intervals into the Technical Specifications.

Attachment II to this letter includes the commitments made by the Authority with this submittal. If you have any questions, please contact Mr. P. Kokolakis.

Very truly yours,

A handwritten signature in black ink, appearing to read 'R. Beedle', written over a horizontal line.

Ralph E. Beedle

att: as stated  
cc: see next page

9310130324 931007  
PDR ADDCK 05000286  
P PDR

ADD 1/1

cc: U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Resident Inspector's Office  
Indian Point Unit 3  
U.S. Nuclear Regulatory Commission  
P.O. Box 337  
Buchanan, NY 10511

Ms. Donna Ross  
Division of Policy Analysis & Planning  
Empire State Plaza  
Building Number 2 - 16th Floor  
Albany, NY 12223

Mr. Nicola F. Conicella, Proj. Manager  
Project Directorate I-1  
Division Of Reactor Projects I/II  
U.S. Nuclear Regulatory Commission  
Mail Stop 14B2  
Washington, DC 20555