



May 10, 1994
IPN-94-058

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, DC 20555

SUBJECT: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
Proposed Changes to the Technical Specifications
Regarding Minimum Temperature for Criticality

Dear Sir:


This application for amendment to the Indian Point 3 Technical Specifications proposes to revise Section 3.1.C. 3 and Table 4.1-1 of Appendix A of the Operating License. The proposed revision to Section 3.1.C. 3 will require the reactor coolant average temperature (T_{avg}) to be no lower than 540°F during critical operation. The proposed change will also require that T_{avg} be restored to $\geq 540^\circ\text{F}$ within 15 minutes if T_{avg} is less than 540°F, or the plant be placed in hot shutdown within the following 15 minutes. The proposed change in Table 4.1-1 entitled, "Minimum Frequencies for Checks, Calibrations and Tests," will add the requirement for T_{avg} instrument check frequency to be reduced to 30 minutes when the T_{avg} deviation and low T_{avg} alarms are not reset and the control banks are above zero steps. This application also proposes revision to the Bases to reflect that the minimum temperature for criticality provides assurance that the reactor is operated within the bounds of the safety analyses. The proposed application also includes an administrative change to correct some typographical errors on page 3.1-25 of the Technical Specifications.

Enclosed for filing is the signed original of a document entitled, "Application for Amendment to Operating License," together with Attachments I and II, comprising a statement of the proposed changes to the Technical Specifications and the Safety Evaluation. The commitments for this change have been submitted to the NRC as part of Licensee Event Report 93-046-00. An additional commitment is in Attachment III.

In accordance with 10 CFR 50.91, a copy of this application and the associated attachments are being submitted to the designated New York State official.

If you have any questions, please contact Mr. P. Kokolakis.

Very truly yours,


W. A. Josiger
Acting Executive Vice President
Nuclear Generation

att: as stated
cc: see next page

9405180042 940510
PDR ADDCK 05000286
P PDR

ADD 11

cc: U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector's Office
Indian Point Unit 3
U.S. Nuclear Regulatory Commission
P.O. Box 337
Buchanan, NY 10511

Ms. Donna Ross
New York State Energy Office
Division of Policy Analysis & Planning
Empire State Plaza
Building Number 2 - 16th Floor
Albany, NY 12223

Mr. Nicola F. Conicella, Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14 B2
Washington, DC 20555