

**BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION**

In the Matter of )  
**NEW YORK POWER AUTHORITY** )      Docket No. 50-286  
Indian Point 3 Nuclear Power Plant )


**APPLICATION FOR AMENDMENT TO THE OPERATING LICENSE**

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the New York Power Authority, as holder of Facility Operating License No. DPR-64, hereby applies for an amendment to the Technical Specifications contained in Appendix A of this license.

This application for amendment to the Indian Point 3 Technical Specifications proposes to remove the Boron Injection Tank (BIT) bypass valves from the list of containment isolation valves in Tables 3.6-1 and 4.4-1. The valves are located in the Safety Injection System, and a modification will be performed to remove the valves and seal the associated penetration pathway to maintain containment integrity. Additionally, the application proposes to add the BIT outlet valves to the list of containment isolation valves in Table 3.6-1 to accommodate testing of the Safety Injection pumps.


The proposed changes to the Technical Specifications are included as Attachment I to this application. The Safety Evaluation is included as Attachment II.

**NEW YORK POWER AUTHORITY**

  
William A. Josiger  
Acting Executive Vice President  
Nuclear Generation

**STATE OF NEW YORK  
COUNTY OF WESTCHESTER**

Subscribed and Sworn to before me  
this 25<sup>th</sup> day of July, 1994.

  
Notary Public

**GERALDINE STRAND**  
Notary Public, State of New York  
No. 4991272  
Qualified in Westchester County  
Commission Expires Jan 27, 1996

9408020171 940725  
PDR ADDCK 05000286  
PDR

**ATTACHMENT I TO IPN-94-094**

**PROPOSED TECHNICAL SPECIFICATION CHANGES REGARDING  
CONTAINMENT ISOLATION VALVES ON THE SAFETY INJECTION SYSTEM**

**NEW YORK POWER AUTHORITY  
INDIAN POINT 3 NUCLEAR POWER PLANT  
DOCKET NO. 50-286  
DPR-64**