



August 4, 1994
IPN-94-102

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: **Indian Point 3 Nuclear Power Plant**
Docket No. 50-286
Proposed Changes to Technical Specifications Associated with the
Allowable Percent of Rated Power for Inoperable Main Steam Safety Valves
and the Correction of Action Statements Associated with
Inoperable Main Steam Line Isolation Instrumentation

Dear Sir:

This application for amendment to the Indian Point Unit 3 (IP3) Technical Specifications proposes to revise Sections 3.4 and 3.5 of Appendix A of the Operating License. The proposed revisions to Technical Specification Section 3.4 would reduce the maximum allowable percent of rated power associated with inoperable Main Steam Safety Valves. These proposed changes would reflect a revised assumption for calculating the maximum allowable percent of rated power associated with inoperable Main Steam Safety Valves. The proposed revisions to Technical Specification Section 3.5 correct administrative errors introduced by License Amendment 44, dated May 10, 1982, and clarify the action statements associated with inoperable high containment pressure (Hi-Hi Level) instrumentation.

Enclosed for filing is the signed original of a document entitled, "Application for Amendment to Operating License," together with Attachments I and II, comprising a statement of the proposed changes to the technical specifications and the associated Safety Evaluation. This letter contains no new commitments.

In accordance with 10 CFR 50.91, a copy of this application and the associated attachments are being submitted to the designated New York State official.


090613

9408110232 940804
PDR ADOCK 05000286
PDR

ADD 11

If you have any questions regarding this letter, please contact Mr. P. Kokolakis.

Very truly yours,


W. A. Josiger
Acting Executive Vice President
Nuclear Generation

att: as stated

cc: U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector's Office
Indian Point Unit 3
U.S. Nuclear Regulatory Commission
P.O. Box 337
Buchanan, NY 10511

Ms. Donna Ross
New York State Energy Office
Division of Policy Analysis & Planning
Empire State Plaza
Building Number 2 - 16th Floor
Albany, NY 12223

Mr. Nicola F. Conicella, Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14 B2
Washington, DC 20555