

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
POWER AUTHORITY OF THE STATE OF NEW YORK ) Docket No. 50-286  
Indian Point 3 Nuclear Power Plant )

**APPLICATION FOR AMENDMENT TO OPERATING LICENSE**

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application for amendment to the Indian Point Unit 3 (IP3) Technical Specifications proposes to revise Section 4.4 of Appendix A of the Operating License. The proposed change would allow a one time extension to the leakage rate test interval for Residual Heat Removal (RHR) containment isolation valves AC-732, AC-741, AC-MOV-743, AC-MOV-744, and AC-MOV-1870. The leak rate tests for these valves will be performed prior to  $T_{avg}$  exceeding 350°F.

The proposed changes to the technical specifications are included as Attachment I to this application. The Safety Evaluation is included as Attachment II. The commitments associated with this application are included as Attachment III.


POWER AUTHORITY OF THE  
STATE OF NEW YORK



By  
William J. Cahill, Jr.  
Executive Vice President  
and Chief Nuclear Officer

STATE OF NEW YORK  
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me  
this 8<sup>th</sup> day of December 1994



Notary Public

**KATHLEEN D. GALLAGHER**  
Notary Public, State of New York  
No. 5004481  
Qualified in Westchester County  
Commission Expires Nov. 16, 1996