

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of the license.

This application for amendment to Section 3.7 of the Indian Point 3 Technical Specifications proposes to change the minimum amount of fuel oil required for each emergency diesel generator fuel oil storage tank. This change is the result of a recent modification which replaced the existing fuel oil indicators with more accurate ones.


The proposed changes to the Technical Specifications are included as Attachment I to this application. The Safety Evaluation is included as Attachment II.

POWER AUTHORITY OF THE
STATE OF NEW YORK


By
William J. Cahill, Jr.
Chief Nuclear Officer

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me
this 23rd day of February 1995


Notary Public

EILEEN E. O'CONNOR
Notary Public, State of New York
No. 4991062
Qualified in Westchester County
Commission Expires January 21, 1996