

C. Containment Temperature

1. The reactor shall not be taken above the cold shutdown condition unless the containment ambient temperature is greater than 50°F.
2. Containment ambient temperature shall not exceed 130°F when the reactor is above the cold shutdown condition. If the temperature is greater than 130°F, reduce the temperature to within the limit within 8 hours, or be in hot shutdown within the next 6 hours and in cold shutdown within the following 30 hours.
3. Containment ambient temperature as specified in 3.6.C.1 and 3.6.C.2 shall be the arithmetic average of temperatures measured at no fewer than 4 locations, at least once per 24 hours.

D. Containment Vent and Purge System

The reactor shall not be taken above the cold shutdown condition unless the containment vent isolation valves (PCV - 1190, - 1191, - 1192) are closed or limited to a maximum valve opening angle of 60° (90° - full open) by mechanical means.

The reactor shall not be taken above the cold shutdown condition unless the containment purge supply and exhaust isolation valves (FCV - 1170, - 1171, - 1172, - 1173) are closed.

If the above conditions cannot be met within one hour, the reactor shall be in the hot shutdown condition within six hours and in the cold shutdown condition within the next 30 hours.

Basis

The Reactor Coolant System must be in the cold shutdown condition in order to relax containment integrity. When the Reactor Coolant System is in the cold shutdown condition, the pressurizer may have an internal temperature above 200°F for purposes of drawing and maintaining a steam bubble during heatup. Operation in this manner ensures that, in case of an accidental RCS coolant release under cold shutdown conditions, the ensuing offsite radiation doses will be within the limits of 10 CFR 100.

The shutdown margins are selected on the type of activities that are being carried out. The shutdown margin requirement of specification 3.8.D when the vessel head bolts are less than fully tensioned precludes criticality during refueling. When the reactor head is not to be removed, the specified cold shutdown margin of 1% Δ k/k precludes criticality in any occurrence.

3.6-2

Amendment No. 88, 98,

Revised by letter dated March 16, 1995

9503230166

9503230166 950316
PDR ADOCK 05000286
P PDR