## BEFORE THE UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of POWER AUTHORITY OF THE STATE OF NEW YORK Indian Point 3 Nuclear Power Plant

Docket No. 50-286

## APPLICATION FOR AMENDMENT TO THE OPERATING LICENSE

)

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the Power Authority of the State of New York, as holder of the Facility Operating License No. DPR-64, hereby applies for an amendment to the Technical Specifications contained in Appendix A of the license.

This application for amendment proposes to delete a footnote regarding accumulator level and pressure instrumentation from Table 4.1-1, "Minimum Frequencies for Checks, Calibrations and Tests of Instrument Channels." The footnote requires that a minimum of two accumulators be interconnected for the purpose of cross checking instrumentation in the event that one of the two pressure or level instrument channels on an accumulator is declared inoperable.

The proposed changes to the Technical Specifications are included as Attachment I to this application, and the Safety Evaluation is included as Attachment II.

POWER AUTHORITY OF THE STATE OF NEW YORK

William J. Califit, Jr. Chief Nuclear Officer

STATE OF NEW YORK COUNTY OF WESTCHESTER Subscribed and sworn to before me

this 12 day of March

PDR

**Notary Public** 

7603170065 76031

PDR

BARBARA ANN TAGGART NOTARY PUBLIC, State of New York No. 4851437 Quatified in Putnam County Commission Expires Jan. 27, 19

ADOCK 05000286