

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the Matter of  
POWER AUTHORITY OF THE STATE OF NEW YORK )  
Indian Point 3 Nuclear Power Plant )

Docket No. 50-286

**APPLICATION FOR AMENDMENT TO THE OPERATING LICENSE**

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the Power Authority of the State of New York, as holder of the Facility Operating License No. DPR-64, hereby applies for an amendment to the Technical Specifications contained in Appendix A of the license.

This application for amendment to the Indian Point 3 Technical Specification proposes to revise the definition of Containment Integrity in Section 1.10 and revise Section 3.6 and Table 3.6-1 for consistency. Several valves are being added to Table 3.6-1 for consistency with the revised definition in Section 1.10.

Additionally, the application proposes to include footnote (7) as a superscript to valves SP-SOV-506 and SP-SOV-507 in Table 4.4-1, "Containment Isolation Valves."

The proposed changes to the Technical Specification are presented in Attachment I to this application. The Safety Evaluation is included in Attachment II. A mark-up of the affected Technical Specification pages is provided in Attachment III.

POWER AUTHORITY OF THE  
STATE OF NEW YORK


HARRY P. SALMON JR.  
VICE PRESIDENT NUCLEAR  
OPERATIONS



James Knubel  
Senior Vice President and  
Chief Nuclear Officer

STATE OF NEW YORK  
COUNTY OF WESTCHESTER

Subscribed and sworn to before me  
this 29<sup>th</sup> day of MAY 1997.

— HARRY P. SALMON, JR. —  


Notary Public

CHRISTINA LEITMANN  
Notary Public, State of New York  
No. 01LE5070948  
Qualified in Putnam County  
Commission Expires January 6, 1999

9706060104 970529  
PDR ADOCK 05000286  
PDR