September 19, 1990

Docket No. 50-286

Distribution:

Docket File	EJordan
NRC/Local PDRs	GHill(4)
PDI-1 Rdg	Wanda Jones
SVarga	JCalvo
RWessman	ACRS(10)
CVogan	GPA/PA
RACapra	OC/LFMB
OGC	DHagan
DNeighbors	Plant File
JLinville	LPhillips

Mr. John C. Brons
Executive Vice President - Nuclear Generation
Power Authority of the State of New York
123 Main Street
White Plains, New York 10601

Dear Mr. Brons:

SUBJECT: ISSUANCE OF AMENDMENT FOR INDIAN POINT 3 (TAC NO. 77201)

The Commission has issued the enclosed Amendment No. 104 to Facility Operating License No. DPR-64 for the Indian Point Nuclear Generating Unit No. 3. The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated July 26, 1990.

The amendment revises the Technical Specifications to incorporate a cycle-specific change regarding the substitution of two failed fuel rods, located in assembly T53 at the core center, with two stainless steel rods.

Also included in this amendment is a correction to Technical Specification page 5.3-2 which incorporates text previously approved by Amendment No. 86 but inadvertently deleted by Amendment No. 101.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Joseph D. Neighbors, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:
1. Amendment No. 104 to DPR-64
2. Safety Evaluation

cc: w/enclosures
See next page

PDI-1	PDI-1	OGC	PDI
CVogan	DNeighbors:rsc	J. Hull	RACapra
9-5-90	9/5/90	9/7/90	9/19/90

DOCUMENT NAME: AMENDMENT IP3/77201

9010020340 900919
PDR ADOCK 05000286
P PDC

ML083779684

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 19, 1990

Docket No. 50-286

Mr. John C. Brons
Executive Vice President - Nuclear Generation
Power Authority of the State of New York
123 Main Street
White Plains, New York 10601

Dear Mr. Brons:

SUBJECT: ISSUANCE OF AMENDMENT FOR INDIAN POINT 3 (TAC NO. 77201)

The Commission has issued the enclosed Amendment No. 104 to Facility Operating License No. DPR-64 for the Indian Point Nuclear Generating Unit No. 3. The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated July 26, 1990.

The amendment revises the Technical Specifications to incorporate a cycle-specific change regarding the substitution of two failed fuel rods, located in assembly T53 at the core center, with two stainless steel rods.

Also included in this amendment is a correction to Technical Specification page 5.3-2 which incorporates text previously approved by Amendment No. 86 but inadvertently deleted by Amendment No. 101.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

Joseph D. Neighbors

Joseph D. Neighbors, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:
1. Amendment No. 104 to DPR-64
2. Safety Evaluation

cc: w/enclosures
See next page

Mr. John C. Brons
Power Authority of the State
of New York

cc:

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. Gerald C. Goldstein
Assistant General Counsel
Power Authority of the State
of New York
1633 Broadway
New York, New York 10019

Mr. Phillip Bayne, President
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. Joseph E. Russell
Resident Manager
Indian Point 3 Nuclear Power Plant
Post Office Box 215
Buchanan, New York 10511

Mr. George M. Wilverding, Manager
Nuclear Safety Evaluation
Power Authority of the State of New York
123 Main Street
White Plains, New York 10601

Mr. Peter Kokolakis, Director
Nuclear Licensing
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223

Mr. William Josiger, Vice President
Operations and Maintenance
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Resident Inspector
Indian Point 3 Nuclear Power Plant
U.S. Nuclear Regulatory Commission
Post Office Box 337
Buchanan, New York 10511

Mr. Charles W. Jackson
Manager, Nuclear Safety and Licensing
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenues
Buchanan, New York 10511

Mr. A. Klausmann, Vice President
Quality Assurance
Power Authority of the State of New York
1633 Broadway
New York, New York 10019

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, New York 10511

Mr. F. X. Pindar
Quality Assurance Superintendent
Indian Point 3 Nuclear Power Plant
Post Office Box 215
Buchanan, New York 10511

Mr. R. Beedle, Vice President
Nuclear Support
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. S. S. Zulla, Vice President
Nuclear Engineering
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271