

December 8, 1994

Mr. William J. Cahill, Jr.
Executive Vice President - Nuclear Generation
Power Authority of the State of New York
123 Main Street
White Plains, NY 10601

SUBJECT: ADMINISTRATIVE ERROR IN ISSUANCE OF AMENDMENT NO. 149 - INDIAN
POINT NUCLEAR GENERATING UNIT NO. 3 (TAC NO. M89463)

Dear Mr. Cahill:

On July 25, 1994, the NRC issued Amendment No. 149 to the Indian Point Nuclear Generating Unit No. 3, Technical Specifications (TSs) in response to your application dated May 10, 1994. This amendment revised, in part, TS Table 4.1-1 entitled, "Minimum Frequencies for Checks, Calibrations and Tests," by adding a requirement to conduct a T_{avg} instrument check every 30 minutes whenever the " T_{avg} deviation and low T_{avg} alarms" are not reset and the control banks are above zero steps. However, as indicated by your letter of October 13, 1994, it was subsequently discovered that the alarm nomenclature should have been " $T_{avg} - T_{ref}$ deviation" not " T_{avg} deviation" as issued in the amendment. This change is an administrative change; therefore, the safety evaluation supporting Amendment No. 149 remains valid. Enclosed is the correct Sheet 1 of 6 from TS Table 4.1-1 that should have been issued with Amendment No. 149. Please update the Indian Point Nuclear Generating Unit No. 3, TS accordingly.

Sincerely,

Original signed by

Nicola F. Conicella, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-286

Enclosure: As stated

cc w/encl: See next page

DOCUMENT NAME: H:\IP3\IP389463

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDI-1 <i>del</i>	C	PM:PDI-1	E	PM:PDI-1	E	D:PDI-1		
NAME	CVogan <i>facv</i>		JHarold:cn <i>JH</i>		NConicella <i>gn</i>		MCase <i>MR</i>		
DATE	12/5/94		12/6/94		12/6/94		11/6/94		

OFFICIAL RECORD COPY

003780498

120025

9412130093 941208
PDR ADOCK 05000286
P PDR

NRC FILE CENTER COPY

CP-1

DF01

ed. h



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 8, 1994

Mr. William J. Cahill, Jr.
Executive Vice President - Nuclear Generation
Power Authority of the State of New York
123 Main Street
White Plains, NY 10601

SUBJECT: ADMINISTRATIVE ERROR IN ISSUANCE OF AMENDMENT NO. 149 - INDIAN
POINT NUCLEAR GENERATING UNIT NO. 3 (TAC NO. M89463)

Dear Mr. Cahill:

On July 25, 1994, the NRC issued Amendment No. 149 to the Indian Point Nuclear Generating Unit No. 3, Technical Specifications (TSs) in response to your application dated May 10, 1994. This amendment revised, in part, TS Table 4.1-1 entitled, "Minimum Frequencies for Checks, Calibrations and Tests," by adding a requirement to conduct a T_{avg} instrument check every 30 minutes whenever the " T_{avg} deviation and low I_{avg} alarms" are not reset and the control banks are above zero steps. However, as indicated by your letter of October 13, 1994, it was subsequently discovered that the alarm nomenclature should have been " $T_{avg} - T_{ref}$ deviation" not " T_{avg} deviation" as issued in the amendment. This change is an administrative change; therefore, the safety evaluation supporting Amendment No. 149 remains valid. Enclosed is the correct Sheet 1 of 6 from TS Table 4.1-1 that should have been issued with Amendment No. 149. Please update the Indian Point Nuclear Generating Unit No. 3, TS accordingly.

Sincerely,

A handwritten signature in cursive script, appearing to read "N. F. Conicella", is written above the typed name.

Nicola F. Conicella, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-286

Enclosure: As stated

cc w/encl: See next page

William J. Cahill, Jr.
Power Authority of the State
of New York

cc:

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Gerald C. Goldstein
Assistant General Counsel
Power Authority of the State
of New York
1633 Broadway
New York, NY 10019

Mr. Robert G. Schoenberger
First Executive Vice President
and Chief Operating Officer
Power Authority of the State
of New York
123 Main Street
White Plains, NY 10601

Mr. Leslie M. Hill
Resident Manager
Indian Point 3 Nuclear Power Plant
P.O. Box 215
Buchanan, NY 10511

Ms. Charlene D. Faison
Director Nuclear Licensing
Power Authority of the State
of New York
123 Main Street
White Plains, NY 10601

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, NY 12223

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Union of Concerned Scientists
Attn: Mr. Robert D. Pollard
1616 P Street, NW, Suite 310
Washington, DC 20036

Indian Point Nuclear Generating
Station Unit No. 3

Resident Inspector
Indian Point 3 Nuclear Power Plant
U.S. Nuclear Regulatory Commission
P.O. Box 337
Buchanan, NY 10511

Mr. Charles W. Jackson
Manager, Nuclear Safety and
Licensing
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenues
Buchanan, NY 10511

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Mr. Richard L. Patch, Director
Quality Assurance
Power Authority of the State
of New York
123 Main Street
White Plains, NY 10601

TABLE 4.1-1 (Sheet 1 of 6)

MINIMUM FREQUENCIES FOR CHECKS, CALIBRATIONS AND TESTS OF INSTRUMENT CHANNELS				
Channel Description	Check	Calibrate	Test	Remarks
1. Nuclear Power Range	S	D (1) M (3)*	Q (2)** Q (4)	1) Heat balance calibration 2) Bistable action (permissive, rod stop, trips) 3) Upper and lower chambers for axial offset 4) Signal to ΔT
2. Nuclear Intermediate Range	S (1)	N.A.	P (2)	1) Once/shift when in service 2) Verification of channel response to simulated inputs
3. Nuclear Source Range	S (1)	N.A.	P (2)	1) Once/shift when in service 2) Verification of channel response to simulated inputs
4. Reactor Coolant Temperature	S (2)	24M	Q (1)	1) Overtemperature ΔT , overpower ΔT , and low T_{avg} 2) Normal Instrument check interval is once/shift T_{avg} instrument check interval reduced to every 30 minutes when: - $T_{avg} - T_{ref}$ deviation and low T_{avg} alarms are not reset and, - Control banks are above 0 steps
5. Reactor Coolant Flow	S	24M	Q	
6. Pressurizer Water Level	S	18M	Q	
7. Pressurizer Pressure	S	18M	Q	High and Low

Amendment No. 38, 83, 74, 93, 107, 123, 128, 137, 140, 149, 150

9412140138 941208
PDR ADOCK 05000286
PDR

DATED: December 8, 1994

CORRECTION TO AMENDMENT NO. 149 TO FACILITY OPERATING LICENSE NO. DPR-64 -
INDIAN POINT UNIT 3

Docket File

PUBLIC

PDI-1 Reading

S. Varga, 14/E/4

J. Zwolinski, 14/H/3

M. Case

C. Vogan

J. Harold

N. Conicella

OGC

D. Hagan, 3302 MNBB

G. Hill (2), P1-22

C. Grimes, 11/F/23

ACRS (4)

OPA

OC/LFDCB

PD plant-specific file

C. Cowgill, Region I

cc: Plant Service list