

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.8001



William A. Josiger
Resident Manager

September 9, 1988
IP3-88-058
JAS-88-110B

License No. 50-286
Docket No. DPR-64

Mr. William T. Russell
Regional Administrator
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Subject: NRC Bulletin No. 88-05
Nonconforming Materials Supplied by Piping
Supplies, Inc. at Folsom, New Jersey
and West Jersey Manufacturing Company
at Williamstown, New Jersey

- References:
1. NRC Bulletin No. 88-05: Nonconforming Materials Supplied by Piping Supplies, Inc. at Folsom, New Jersey and West Jersey Manufacturing Company at Williamstown, New Jersey, dated May 6, 1988.
 2. NRC Bulletin No. 88-05, Supplement 1, dated June 15, 1988.
 3. NRC Bulletin No. 88-05, Supplement 2, dated August 3, 1988.

Dear Mr. Russell:

Reference (1) required licensees to submit information regarding materials supplied by Piping Supplies, Incorporated (PSI) at Folsom, New Jersey and West Jersey Manufacturing Company (WJM) at Williamstown, New Jersey. Licensees were also requested to take actions to assure that materials comply with ASME Code and design specification requirements or are suitable for their intended service, or replace such materials.

Reference (2) limited the scope of the requested materials review to only flanges and fittings.

8809150205 880909
PDR ADOCK 05000286
G PNU


IE11
11

Reference (3) modified the schedule for actions licensees were requested to perform in References (1) and (2) and provided further clarification.

Attachment I provides the requested information and a discussion of the Authority's actions with regard to References (1), (2) and (3).

Should you or your staff have any further questions regarding this matter, please contact Mr. M. F. Peckham of my staff.

Sincerely,


W. A. Josiger
Resident Manager
Indian Point 3 Nuclear Power Plant


WAL:JAS:lh

Attachment

cc: Document Control Desk (original)
Mail Station PI-137
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Resident Inspector's Office
Indian Point 3 Nuclear Power Plant
U.S. Nuclear Regulatory Commission
P.O. Box 337
Buchanan, NY 10511

SUBSCRIBED AND SWORN TO
BEFORE ME THIS 9th DAY
OF September 1988.



LORRIE A. HAFNER
Notary Public, State of New York
No. 4928710, Dutchess County
Term Expires May 2, 1990

ATTACHMENT I

As a result of NRC Bulletin No. 88-05 and its supplements, the Authority conducted a review of Indian Point 3 purchase orders for flanges and fittings to determine if any materials were supplied by West Jersey Manufacturing Company (WJM), Piping Supplies, Incorporated (PSI). This review consisted of 615 purchase orders from January, 1976 through June, 1988.

Out of the 615 purchase orders reviewed, one purchase order, 78-IP-1972, written to Davidson Pipe Supply, Inc., revealed that 24 flanges had been received from WJM. Table 1 provides the specification, size, pressure rating and heat number of these 24 flanges. These flanges were purchased for use in a non-safety related turbine gland supply and exhaust steam piping system. The flanges were never installed and all 24 have been drawn out of stock and segregated by the Quality Control Department. One flange from each heat number was forwarded to a testing laboratory for analysis. This information will be submitted to the utility database established by NUMARC.

Table 1

<u>Number</u>	<u>Size</u>	<u>Pressure</u> (lbs.)	<u>Specification</u>	<u>Heat No.</u>
12	1 1/2"	600	WN/RF A-105, Gr. 2	HR685
12	2"	600	WN/RF A-105, Gr. 2	H80A3X