Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.8001

New York Power Authority

L. M. Hill
Site Executive Officer

February 20, 1996
IPN-96-016

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

SUBJECT: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
License No. DPR-64
Licensee Event Report # 96-003-00
Automatic Actuation of Undervoltage Logic Designed to Strip Safety Buses and Initiate Signal for Emergency Diesel Generator Start

Dear Sir:

The attached Licensee Event Report (LER) 96-003-00 is hereby submitted as required by 10CFR50.73. This event is of the type defined in 10CFR50.73(a)(2)(iv). Also, attached is the commitment made by the Authority in this LER.

Very truly yours,

L. M. Hill
Site Executive Officer
Indian Point 3 Nuclear Power Plant

Attachment

cc: See next page

260118

9602270272 960220
PDR ADOCK 05000286
S PDR

IE22

cc: Mr. Thomas T. Martin
Regional Administrator
Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406-1415

INPO Record Center
700 Galleria Parkway
Atlanta, Georgia 30339-5957

U.S. Nuclear Regulatory Commission
Resident Inspectors' Office
Indian Point 3 Nuclear Power Plant

Attachment I
List of Commitments

Number	Commitment	Due
IPN-96-016-01	NPO training will be conducted on the lessons learned from LER 96-003, including the requirement to set up the proper working conditions prior to starting a job.	July 8, 1996