

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.8001



L. M. Hill
Resident Manager

April 19, 1995
IPN-95-049

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

SUBJECT: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
License No. DPR-64
Licensee Event Report # 95-006-00
"Plant Outside Design Basis Due to Failure to Analyze Loss of
Ventilation Systems In Appendix R Analysis"

REFERENCE: 1. NYPA letter, W. J. Cahill, Jr. to NRC (IPN-95-039), "Updated
Information Concerning the Authority's 10 CFR 50, Appendix R
Analysis," dated March 28, 1995.

Dear Sir:

The attached Licensee Event Report (LER) 95-006-00 is hereby submitted as required
by 10CFR50.73. This event is of the type defined in 10CFR50.73(a)(2)(ii)(B). Also
attached are commitments made by the Authority in this LER.

The reported event was identified during an evaluation of the Appendix R issues
identified in Reference 1. NYPA is still reviewing several questions raised on the
reportability decisions of that evaluation. Also, NYPA plans to update Reference 1 to
advise the NRC of the issues identified and the enhancements / corrective actions
made as a result of our review of the Fire Protection and Appendix R Programs.

Very truly yours,

A handwritten signature in black ink, appearing to read 'L. M. Hill', written over the typed name.

L. M. Hill

Resident Manager
Indian Point 3 Nuclear Power Plant

Attachment
cc: See next page

9504250245 950419
PDR ADDCK 05000286
S PDR

IF 22
11

cc: Mr. Thomas T. Martin
Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406-1415

U.S. Nuclear Regulatory Commission
Resident Inspectors' Office
Indian Point 3 Nuclear Power Plant

INPO Records Center
700 Galleria Parkway
Atlanta, Georgia 30339-5957

Attachment 1
List of Commitments

Number	Commitment	Due
IPN-95-049-01	Additional guidance is being prepared for operator action. Procedure ONOP-FP-1 is being revised to indicate how to prevent a spurious loss of ventilation and provide a methodology for restoration of ventilation following spurious isolation.	May 19, 1995
IPN-95-049-02	A commitment was made to revise the Fire Protection/Appendix R procedure (FPES-04B) to address areas required. These areas will include changes to Appendix R strategy / commitments. This revises IPN-95-003-03	June 30, 1995
IPN-95-049-03	LER 95-006-00 will be updated to report the cause of the event and an evaluation of the effects on public health and safety.	July 31, 1995