

Indian Point 3  
Nuclear Power Plant  
P.O. Box 215  
Buchanan, New York 10511  
914 736.8001



**New York Power  
Authority**

**Joseph E. Russell**  
Resident Manager

July 16, 1992  
IP-NRC-92-047

License No. 50-286  
Docket No. DPR-64

Mr. Thomas T. Martin  
Regional Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Dear Mr. Martin:

This correspondence provides information required by the Special Reports section (6.9.2) of the Indian Point Unit Three (IP3) Technical Specifications.

Technical Specification 3.14.C, "Penetration Fire Barriers", subsection 2, states that, "If the requirements of 3.14.C.1 are not met and the equipment in these areas are (sic) required to be operable:...Restore the non-functional fire barrier penetration(s) to functional status within seven days or submit a report to the Commission pursuant to specification 6.9.2.f within the next 30 days outlining the action taken, the cause of the non-functional penetration and plans for restoring the fire barrier penetration(s) to functional status."

On June 23, 1992, control building fire barrier penetrations to the 480V switchgear room were opened to pull cable for installation of 125 volt DC system modifications recently described in LER 92-006.

In accordance with technical specifications, an hourly fire watch was verified to be implemented at the time the fire barrier was declared inoperable, and continued until the penetration was closed July 13, 1992.


200040

9207230148 920716  
PDR ADOCK 05000286  
S PDR

*JE 22*

Should you or your staff have any questions regarding this event, please contact Mr. B. Ray of my staff.

Sincerely,



Joseph E. Russell  
Resident Manager  
Indian Point Three Nuclear Power Plant

jer/wje/rj

cc: U.S. Nuclear Regulatory Commission (original)  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

IP3 Resident Inspector  
Indian Point 3  
U.S. Nuclear Regulatory Commission  
P.O. Box 337  
Buchanan, New York 10511