

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.8001



**New York Power
Authority**

John H. Garrity
Resident Manager

June 17 1993
IPN-93-065

Document Control Desk
Mail Station PI-137
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
Technical Specification Special Report

Dear Sir:

The Authority is submitting this correspondence to provide information required by Special Reports Section 6.9.2 of Indian Point 3 Technical Specifications. This special report is for a non-functional fire barrier that was not restored within seven days.

On July 2, 1992, a door (fire barrier) between 31 emergency diesel generator compartment and the control building became non-functional in that it would not latch closed. We established a continuous fire watch in accordance with Technical Specifications. After expiration of the seven day limiting condition of operation, the required special report was not submitted within thirty days due to a personnel error. On July 12, 1992, we restored the barrier by repairing the door.

The Authority performed an audit on Technical Specification special reports and on May 26, 1993, identified that the above special report was not submitted. We did not identify any other missed special report during this audit. We apprised personnel involved with this error of their failure to meet their responsibilities for reporting special events. We also revised administrative procedure AP-8, Reportability Manual, to make departmental managers responsible for completing written reports to the NRC for events/conditions within their respective scope of responsibility. The Authority's above corrective actions were taken to preclude recurrence of this event.

Very truly yours,

John H. Garrity
Resident Manager
Indian Point Three Nuclear Power Plant

JHG/djc

cc: see next page

9306240250 930617
PDR ADDCK 05000286
F PDR

IF 22
1/0

cc: Mr. Thomas T. Martin
Regional Administrator - Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Indian Point 3