

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.8001



John H. Garrity
Resident Manager

January 7, 1994
IPN-94-004

Docket No. 50-286
License No. DPR-64

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Stop PI-137
Washington, D.C. 20555

Dear Sir:

Enclosed you will find the monthly operating report relating to Indian Point 3 Nuclear Plant for the month of December 1993.

Very truly yours,

A handwritten signature in black ink that reads 'JH Garrity'.

John H. Garrity
Resident Manager
Indian Point 3 Nuclear Power Plant

JHG:dc

Enclosure

cc: Mr. Thomas T. Martin, Regional Administrator
Region I
U.S. Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

INPO Records Center
700 Galleria Parkway
Atlanta, Georgia 30339-5957

150002

9401140232 931231
PDR ADOCK 05000286
R PDR

Handwritten initials 'LFE' and the date '1/11' in black ink.

OPERATING DATA REPORT

Docket No. 50-286
 Date 1-04-94
 Completed By T. Orlando
 Telephone (914) 736-8340

OPERATING STATUS

Notes

1. Unit Name: Indian Point No. 3 Nuclear Power Plant
2. Reporting Period: December 1993
3. Licensed Thermal Power (MWt): 3025
4. Nameplate Rating (Gross MWe): 1013
5. Design Electrical Rating (Net MWe): 965
6. Maximum Dependable Capacity (Gross MWe): 1000
7. Maximum Dependable Capacity (Net MWe): 965
8. If Changes Occur in Capacity Ratings (Items Number 3 through 7) Since Last Report. Give Reasons: _____

9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons for Restrictions, If Any: _____

	This Month	Yr. to Date	Cumulative
11. Hours In Reporting Period	744	8,760	151,993
12. Number of Hours Reactor Was Critical	0	1,303.54	91,890.14
13. Reactor Reserve Shutdown Hours	0	0	0
14. Hours Generator On-Line	0	1,292.77	89,462.16
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	0	3,682,359	254,069,702
17. Gross Electrical Energy Generated (MWH)	0	1,234,160	79,388,605
18. Net Electrical Generated (MWH)	0	1,192,553	76,357,136
19. Unit Service Factor	0	14.8	58.9
20. Unit Availability Factor	0	14.8	58.9
21. Unit Capacity Factor (Using MDC Net)	0	14.1	53.3*
22. Unit Capacity Factor (Using DER Net)	0	14.1	52.1
23. Unit Forced Outage Rate	100	85.1	20.3

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
*Weighted Average

25. If Shut Down At End Of Report Period. Estimated Date of Startup: Undetermined

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-286
UNIT IP-3
DATE 1-04-94
COMPLETED BY T. Orlando
TELEPHONE (914) 736-8340

MONTH December 1993

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

SUMMARY OF OPERATING EXPERIENCE

DECEMBER 1993

On March 5, with the unit at hot shutdown, a decision was made by plant management to place the plant in the cold shutdown condition. The unit reached cold shutdown on March 7, at 1018 hours. This decision was made in order to address plant administrative concerns, implement the "Performance Improvement Plan" (PIP), and to perform plant maintenance which had originally been scheduled for a planned outage in May, 1993.

The unit was off line for the entire reporting period.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-286
 UNIT NAME INDIAN POINT NO. 3
 DATE 1-04-94
 COMPLETED BY T. Orlando
 TELEPHONE (914) 736-8340

REPORT MONTH December 1993

NO.	DATE	TYPE 1	DURATION (HOURS)	REASON 2	SHUTTING DOWN REACTOR 3	LICENSEE EVENT REPORT #	SYSTEM CODE 4	COMPONENT CODE 5	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
4	930226	F	744	B	1	93-005-01	SH	INSTRU X	THE UNIT WAS REMOVED FROM SERVICE IN ORDER TO PERFORM TESTING ON THE PLANTS AMSAC SYSTEM.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment
B-Maintenance or Test
C-Refueling
D- Regulatory Restriction

3
Method
1-Manual
2-Manual Scram
3-Automatic Scram
4-Other (Explain)

4
Exhibit - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)
 5 **Exhibit - Same Source**