

Indian Point 3  
Nuclear Power Plant  
P.O. Box 215  
Buchanan, New York 10511  
914 736.8001



L. M. Hill  
Resident Manager

February 15, 1995  
IPN-95- 014

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Stop P1-37  
Washington, D.C. 20555


Subject: Indian Point 3 Nuclear Power Plant  
Docket No. 50-286  
License No. DPR-64  
Monthly Operating Report for January 1995

Dear Sir:

The attached monthly operating report, for the month of January 1995, is hereby submitted in accordance with Indian Point 3 Nuclear Power Plant Technical Specification 6.9.1.4.

The Authority is making no commitments in this letter.

Very truly yours,

  
L. M. Hill  
Resident Manager  
Indian Point 3 Nuclear Power Plant

LMH/cbr

Enclosure

cc: See next page

220077

9502220169 950131  
PDR ADOCK 05000286  
R PDR

IF24  
11

cc: Thomas T. Martin  
Regional Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406-1415

U.S. Nuclear Regulatory Commission  
Resident Inspectors' Office  
Indian Point 3 Nuclear Power Plant

John J. McOscar, Director  
Division of Resource Management and Administration  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406-1415

INPO Records Center  
700 Galleria Parkway  
Atlanta, Georgia 30339-5957

**OPERATING DATA REPORT**

DOCKET NO. 50-286  
 DATE 02-01-95  
 COMPLETED BY T. Orlando  
 TELEPHONE (914) 736-8340

**OPERATING STATUS**

1. Unit Name: Indian Point No. 3 Nuclear Power Plant
2. Reporting Period: January 1995
3. Licensed Thermal Power (MWt): 3025
4. Nameplate Rating (Gross MWe): 1013
5. Design Electrical Rating (Net MWe): 965
6. Maximum Dependable Capacity (Gross MWe): 1000
7. Maximum Dependable Capacity (Net MWe): 965
8. If Changes Occur in Capacity Ratings (Items Number 3 through 7) Since Last Report Give Reasons: \_\_\_\_\_
9. Power Level to Which Restricted, If Any (Net MWe): \_\_\_\_\_
10. Reasons for Restrictions, If Any: \_\_\_\_\_

	This Month	Yr. to Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>744</u>	<u>161,617</u>
12. Number of Hours Reactor Was Critical	<u>0</u>	<u>0</u>	<u>91,890.14</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>0</u>	<u>0</u>	<u>89,462.16</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>254,069,702</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>79,388,605</u>
18. Net Electrical Generated (MWH)	<u>0</u>	<u>0</u>	<u>76,357,136</u>
19. Unit Service Factor	<u>0</u>	<u>0</u>	<u>55.4</u>
20. Unit Availability Factor	<u>0</u>	<u>0</u>	<u>55.4</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0</u>	<u>0</u>	<u>50.1*</u>
22. Unit Capacity Factor (Using DER Net)	<u>0</u>	<u>0</u>	<u>49.0</u>
23. Unit Forced Outage Rate	<u>100</u>	<u>100</u>	<u>27.0</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):  
 \_\_\_\_\_  
 \_\_\_\_\_

25. If Shut Down At End Of Report Period. Estimated Date of Startup: 3/20/95

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

\* Weighted Average

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-286  
UNIT IP-3  
DATE 02-01-95  
COMPLETED BY T. Orlando  
TELEPHONE (914) 736-8340

MONTH JANUARY 1995

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

**UNIT SHUTDOWNS AND POWER REDUCTIONS**

DOCKET NO. 50-286  
 UNIT NAME INDIAN POINT NO. 3  
 DATE 02-01-95  
 COMPLETED BY T. Orlando  
 TELEPHONE (914) 736-8340

REPORT MONTH JANUARY 1995

NO.	DATE	TYPE 1	DURATION (HOURS)	REASON 2	METHOD OF SHUTTING DOWN REACTOR 3	LICENSEE EVENT REPORT #	SYSTEM CODE 4	COMPONENT CODE 5	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
1	930226	F	744	B	1	93-005-02	IE	INSTRU X	THE UNIT WAS REMOVED FROM SERVICE IN ORDER TO PERFORM TESTING ON THE PLANT'S AMSAC SYSTEM.

**1**  
 F: Forced  
 S: Scheduled

**2**  
 Reason:  
 A-Equipment  
 B-Maintenance or Test  
 C-Refueling  
 D- Regulatory Restriction

**3**  
 Method  
 1-Manual  
 2-Manual Scram  
 3-Automatic Scram  
 4-Other (Explain)

**4**  
 Exhibit - Instructions  
 for Preparation of Data  
 Entry Sheets for Licensee  
 Event Report (LER) File  
 (NUREG - 0161)

**5**  
 Exhibit - Same Source

## SUMMARY OF OPERATING EXPERIENCE

JANUARY 1995

On March 5, 1993, with the unit at hot shutdown, a decision was made by plant management to place the plant in the cold shutdown condition. The unit reached cold shutdown on March 7, at 1018 hours. This decision was made in order to address plant administrative concerns, implement the "Performance Improvement Plan" (PIP), and to perform plant maintenance which had originally been scheduled for a planned outage in May, 1993.

The plant is addressing the administrative concerns using the Restart and Continuous Improvement Plan, which superceded the "Performance Improvement Plan".

The unit was off line for the entire reporting period.