Nuclear Power Plant P.O. Box 215 Buchanan, New York 10511 914 736.8001



Robert J. Barrett Plant Manager

May., 14, 1996 IPN-96-060

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

Subject: Indian Point 3 Nuclear Power Plant Docket No. 50-286 License No. DPR-64 Monthly Operating Report for April 1996

Dear Sir:

The attached monthly operating report, for the month of April 1996, is hereby submitted in accordance with Indian Point 3 Nuclear Power Plant Technical Specification 6.9.1.4.

The Authority is making no commitments in this letter.

 $\overline{}$ 

200138

Very truly yours,

our

Robert J Barrett Plant Manager Indian Point 3 Nuclear Power Plant

Attachment

cc: See next page 9605200266 960430 PDR ADOCK 05000286 PDR

Docket No. 50-286 IPN-96-060 Page 2 of 2

Thomas T. Martin Regional Administrator Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406-1415

U.S. Nuclear Regulatory Commission Resident Inspectors' Office Indian Point 3 Nuclear Power Plant

John J. McOscar, Director Division of Resource Management and Administration Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406-1415

INPO Records Center 700 Galleria Parkway Atlanta, Georgia 30339-5957

cc:





DOCKET NO. DATE COMPLETED BY TELEPHONE IPN-96-060 ATTACHMENT I PAGE 1 of 4

50-286
5-1-96
T. Orlando
(914) 736-8340
<u>1. Orlando</u> (914) 736-8340

#### **OPERATING STATUS**

- 1. Unit Name: Indian Point No. 3 Nuclear Power Plant
- 2. Reporting Period: \_\_\_\_\_ April 1996
- 3. Licensed Thermal Power (MWt): 3025
- 4. Nameplate Rating (Gross MWe):
   1013

   5. Design Electrical Rating (Net MWe):
   965
- 6. Maximum Dependable Capacity (Gross MWe): \_\_\_\_\_\_1000
- Maximum Dependable Capacity (Net MWe): \_\_\_\_\_\_965
- 8. If Changes Occur in Capacity Ratings (Items Number 3 through 7) Since Last Report Give Reasons:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reasons for Restrictions, If Any:

		This Month	Yr-to-Date	Cumulative
11.	Hours In Reporting Period	719	2903	172,536
12.	Number Of Hours Reactor Was Critical	654.92	723.25	94,486.78
13.	Reactor Reserve Shutdown Hours	0	0	0
14.	Hours Generator On-Line	582.18	582.18	91,743.01
15.	Unit Reserve Shutdown Hours	0	0	0
16.	Gross Thermal Energy Generated (MWH)	1,618,000	1,619,042	260,347,923
17.	Gross Electrical Energy Generated (MWH)	539,240	539,240	81,459,145
18.	Net Electrical Energy Generated (MWH)	520,474	520,474	78,349,137
19.	Unit Service Factor	81.0	20.1	53.2
20.	Unit Availability Factor	81.0	20.1	53.2
21.	Unit Capacity factor (Using MDC Net)	75.0	18.6	48.2*
22.	Unit Capacity Factor (Using DER Net)	75.0	18.6	47.1
23.	Unit Forced Outage Rate	19.0	79.9	31.2

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period. Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

\* Weighted Average

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	<u>50-286</u>
UNIT	<u>IP-3</u>
DATE	<u>5-1-96</u>
COMPLETED BY	<u>T. Orlando</u>
TELEPHONE	<u>(914) 736-8340</u>
IPN-96-060	
ATTACHMENT I	
PAGE 2 of 4	

#### MONTH APRIL, 1996

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	0	17	968
2	1	18	968
3	0	19	967
4	0	20	968
5	0	21	967
6	13	22	967
7	202	23	967
8	455	24	968
9	770	25	969
10	897	26	967
11	948	27	968
12	954	28	970
13	974	29	970
14	975	30	970
15	975	31	
16	970		
	· · · · · · · · · · · · · · · · · · ·		

### INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

### UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO.	50-286
UNIT NAME	INDIAN POINT NO. 3
DATE	5-1-96
COMPLETED BY	T. Orlando
TELEPHONE	(914) 736-8340
IPN-96-060	
ATTACHMENT I	•
PAGE 3 of 4	*

## REPORT MONTH \_ APRIL 1996

NO.	DATE	TYPE 1	DURATION (HOURS)	REASON 2	METHOD OF SHUTTING DOWN REACTOR 3	LICENSEE EVENT	SYSTEM CODE 4	COMPONENT CODE 5	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
2	950914 960402	F	38.92 97.90	F	1	95-018-00 96-009-00	xx	GENERA X GENERA D	DURING A CONTROLLED UNIT SHUTDOWN FOR REPAIR OF A HYDROGEN LEAK IN THE GENERATOR HYDROGEN COOLER THE REACTOR WAS MANUALLY TRIPPED AND THE TURBINE AUTOMATICALLY TRIPPED DUE TO AN ALARM FOR A HIGH MAIN GENERATOR STATOR DIFFERENTIAL TEMPERATURE DUE TO STATOR COOLER GAS BINDING. THE OUTAGE WAS EXTENDED TO FACILITATE REPAIRS TO OTHER PLANT SYSTEMS. MANUALLY TRIPPED THE REACTOR AND
									THE TURBINE AUTOMATICALLY TRIPPED IN RESPONSE TO AN ALARM FOR A HIGH DIFFERENTIAL TEMPERATURE IN THE MAIN GENERATOR STATOR. THE ALARM WAS CAUSED BY REDUCED COOLING FLOW IN THE STATOR COOLERS DUE TO INADEQUATE VENTING AND FLOW BALANCING.
1 F: Forc S: Sch	ed eduled	2 Re A- B- C- D- E- G- H-	ason: Equipment Maintenance o Refueling Regulatory Res Operator Train Administrative Operational En Other (Explain	r Test striction ing & Licens ror	3 Metho 1-Man 2-Man 3-Auto 4-Othe see Examination	od: ual ual Scram omatic Scram er (Explain)	4 Exhibit for Pre Entry S Event F (NURE)	G - Instructions paration of Data Sheets for Licens Report (LER) File G - 0161)	5 Exhibit 1 - Same Source ee

DOCKET NO. IPN-96-060 ATTACHMENT I PAGE 4 of 4

50<u>-286</u>

### SUMMARY OF OPERATING EXPERIENCE

#### **APRIL 1996**

The Indian Point Unit No. 3 Nuclear Power Plant was synchronized to the bus for a total of 582.18 hours producing a gross generation of 539,240 MWE. The reactor had been brought critical on March 29, at 0340 hours and the unit was synchronized to the bus on April 2, at 1455 hours. At approximately 1612 hours, when power was approximately 13 percent, operators initiated a manual reactor trip (and a turbine trip occurred automatically) in response to an alarm for a high differential temperature on the unit's main generator stator. The stator high differential temperature was due to a reduction of service water flow to the 33 hydrogen cooler as a result of gas binding and inadequate cooling water flow balance between the four hydrogen coolers of the main generator stator. The event was reported in LER 96-009. After revision of plant procedures, the reactor was brought critical on April 5, at 0817 hours. The hydrogen coolers were vented and flow balanced, the unit was synchronized to the bus on April 6, at 1806 hours and a controlled load increase ensued. The unit achieved 99 percent reactor power on April 12, at 1915 hours, and remained on line at approximately 99 percent reactor power for the remainder of the reporting period. The unit was administratively controlled at approximately 99 percent power while troubleshooting the automatic control system for boric acid makeup.