

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.8001



**New York Power
Authority**

Robert J. Barrett
Site Executive Officer

February 21, 1997
IPN-97-021

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

SUBJECT: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
License No. DPR-64
Licensee Event Report # 97-002-00
**Containment Isolation Valves for the Hydrogen Monitoring
System Were Open During Testing But Not Listed in the
Technical Specification Table of Non-Automatic Valves Open
Continuously or Intermittently Due to a Personnel Error;
A Condition Prohibited by Technical Specifications**

Dear Sir:

The attached Licensee Event Report (LER) 97-002-00 is hereby submitted as required
by 10 CFR 50.73. This event is of the type defined in 10 CFR 50.73 (a)(2)(i)(B).

Also attached is the commitments made by the Authority in this LER.

Very truly yours,

Robert J. Barrett
Site Executive Officer
Indian Point 3 Nuclear Power Plant

Attachment

cc: See next page

030030

9703030490 970221
PDR ADOCK 05000286
S PDR



11
Ier

cc: Hubert J. Miller
Regional Administrator
Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406-1415

INPO Record Center
700 Galleria Parkway
Atlanta, Georgia 30339-5957

U.S. Nuclear Regulatory Commission
Resident Inspectors' Office
Indian Point 3 Nuclear Power Plant

Commitment List

Number	Commitment	Due
IPN-97-021-01	Submit a proposed revision to Technical Specification Table 3.6-1 to include the hydrogen monitoring system sample line's CIV valves.	April 30, 1997
IPN-97-021-02	The FSAR will be revised to correct discrepancies identified during development of a Safety Evaluation regarding the unique configuration of the CIV for the hydrogen monitoring system.	December 31, 1997