

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.3001



Robert J. Barrett
Site Executive Officer

May 27, 1997
IPN-97-068

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555


SUBJECT: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
License No. DPR-64
Licensee Event Report # 97-004-00
**The Fuel Storage Building Emergency Ventilation System Was
Inoperable During Movement Of the Cask Crane Over the Spent
Fuel Pit Due To Failure To Perform All Required Testing;
A Condition Prohibited By Technical Specifications**

Dear Sir:

The attached Licensee Event Report (LER) 97-004-00 is hereby submitted as required by 10 CFR 50.73. This event is of the type defined in 10 CFR 50.73 (a)(2)(i)(B).

Also attached is the commitments made by the Authority in this LER.

Very truly yours,


Robert J. Barrett
Site Executive Officer
Indian Point 3 Nuclear Power Plant

1/1
Jerr

Attachment

cc: See next page

030012



9706030264 970527
PDR ADOCK 05000286
S PDR

Docket No. 50-286

IPN-97-068

Page 2 of 2

cc: Hubert J. Miller
Regional Administrator
Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406-1415

INPO Record Center
700 Galleria Parkway
Atlanta, Georgia 30339-5957

U.S. Nuclear Regulatory Commission
Resident Inspectors' Office
Indian Point 3 Nuclear Power Plant

Commitment List

Number	Commitment	Due
IPN-97-068-01	The test procedure for the FSB EVS, 3PT-32A will be revised to note that when declaring the FSB EVS inoperable for the conditions listed in TS 4.5.A.6.c, then each of the four tests identified in TS 4.5.A.6.c shall be performed.	May 31, 1997
IPN-97-068-02	The Operations Manager will instruct licensed operators on the use of TS section 4 before declaring a system operable.	June 27, 1997
IPN-97-068-03	Test procedures for the other TS Air Filtration Systems will be revised to incorporate appropriate wording to note that when declaring the system inoperable for the conditions listed in the TS, testing identified in the TS shall be performed.	June 27, 1997